


The Connecticut General Assembly

Legislative Commissioners' Office

Edwin J. Maley, Jr.
Commissioner
Leonard A. Fasano
Commissioner

Nicholas Bombace
Director



Legislative Office Building
Suite 5500
Hartford, Connecticut
06106-1591
(860) 240-8410
fax (860) 240-8414
e-mail: leo@cga.ct.gov

Memorandum

To: Senator James Maroney
Representative Nicole Klarides-Ditria
Senator John Kissel
Representative Tom Arnone

From: Catriona Stratton and Christopher J. Cordima

Date: August 30, 2022

Subject: Proposed 2022 Connecticut State Fire Prevention Code - Resubmittal

This is a resubmittal of the proposed **2022 Connecticut State Fire Prevention Code** that was rejected without prejudice at the committee's meeting on June 28, 2022. The resubmittal addresses some of the substantive concerns and technical corrections noted in the June 28, 2022 memorandum, except as noted below. An additional substantive concern and additional technical corrections are also noted below.

In addition to the resubmitted Connecticut State Fire Prevention Code, the agency has provided for the committee's consideration a written explanation of the changes not made by the agency in response to the June 28, 2022 memorandum, including any item listed in the "Additional Comments" section of said memorandum. The agency declined to make some of the technical corrections that were recommended in the June 28, 2022 memorandum for format consistency and other reasons, on the basis that those technical corrections would result in a difference from the underlying model code. However, the model code is being revised in other ways in the agency's submission and the agency's failure to make these corrections results in inconsistencies throughout the state code.

Attached are the pages of the resubmittal of the proposed **2022 Connecticut State Prevention Code**. There are handwritten comments on the pages of the proposed code referenced in the table below that make recommendations for corrections or seek further clarification.

Substantive Concerns:

1. On page 6, Section 1.6 states that "The local fire marshal for a jurisdiction or the State Fire Marshal shall order **hazardous conditions** contrary to the provisions of this code to be remedied in accordance with Connecticut General Statutes Section 29-291c, as amended by Public Act 21-165. An order to vacate all or part of a building may be issued by a local fire marshal or local police officer in accordance with section 29-306 of the Connecticut General Statutes when **severe hazardous conditions** exist." (Emphasis added.)

The terms "hazardous conditions" and "severe hazardous conditions" are not defined. The language in the proposed code may be construed to require that *only* hazardous conditions be remedied, rather than *any* condition that violates the Connecticut State Fire Prevention Code or the Connecticut State Fire Safety Code, as set forth in section 29-291c of the Connecticut General Statutes. Additionally, the language in the proposed code may be construed such that an order to vacate may be issued *only* where severe hazardous conditions exist, rather than pursuant to the terms of section 29-306 of the Connecticut General Statutes.

The agency should rewrite this section to be consistent with the statutory text, or, if it purposely decides not to rewrite this section, the agency should provide an explanation of its reason and how said section may be interpreted in a manner so as not to conflict with sections 29-291c and 29-306 of the Connecticut General Statutes.

Finally, the phrase "as amended by Public Act 21-165" should be deleted because, as the provision is currently drafted in the proposed code, there may be confusion about whether a local fire marshal or the State Fire Marshal may order any remedies that are the result of any subsequent amendments to section 29-291c of the Connecticut General Statutes, or if a local fire marshal or the State Fire Marshal are limited to that specific version of said Section 29-291c when ordering remedies.

2. On page 23, the definition of "Fireworks" is inconsistent with the definition of "Fireworks" in section 29-356 of the Connecticut General Statutes. The agency indicated that it addressed the substantive concern noted in the June 28, 2022 memorandum and stated the definition "has been clarified". However, no changes were made to the

definition of “Fireworks” in the resubmittal. The definition of “Fireworks” may be made consistent with the statutory definition by stating that “Fireworks” has the same meaning as provided in section 29-356 of the Connecticut General Statutes and includes any device that meets the definition of 1.3G fireworks and 1.4G fireworks, but excludes sparklers and fountains, as defined in section 29-356 of the Connecticut General Statutes.

Additional Comments:

LCO COMMENTS	Page Numbers
Technical corrections	1-3, 5-7, 9, 11-13, 15-18, 20-30, 32-39, 41-43, 45, 47, 48, 50-55, 57
Seek clarification	2, 19, 21 (4 items), 41

Recommendation:

<p>Approval in whole with technical corrections with deletions with substitute pages Disapproval in whole or in part X Rejection without prejudice</p>
--

Authorizing Statute and Statutes Referenced in this Memorandum

Sec. 29-291e. Procedure for adoption and amendment of State Fire Prevention Code.

(a) For the purposes of this section, "proposed code" means a proposal by the State Fire Marshal, in coordination with the advisory committee for a new State Fire Prevention Code or for a change in, addition to or repeal of any provision of the State Fire Prevention Code and "advisory committee" means the advisory committee established under subsection (b) of section 29-291a.

(b) Notwithstanding the provisions of chapter 54, the adoption of the State Fire Prevention Code and any amendments thereto shall not be required to comply with the provisions of chapter 54, except as provided in this section.

(c) Prior to the adoption of the State Fire Prevention Code and any amendments thereto, the State Fire Marshal shall (1) post any proposed code, a statement of purpose for which the proposed code is proposed, a fiscal note associated with compliance with the proposed code prepared pursuant to section 4-168 and a regulatory flexibility analysis prepared pursuant to section 4-168a on the Internet web site of the Department of Administrative Services, (2) give notice electronically to the joint standing committee of the General Assembly having cognizance of matters relating to public safety and security, (3) give notice to any person who has requested the State Fire Marshal for advance notice of the proposed code adoption proceedings, (4) provide for a public comment period of forty-five days following the posting of such proposed code, fiscal note and regulatory flexibility analysis, and (5) hold a public hearing on the proposed code not less than twenty nor more than thirty-five days after such posting.

(d) After the close of the public comment period, the State Fire Marshal, in coordination with the advisory committee, shall respond to each written and oral comment respecting the proposed code received during the public comment period and at the public hearing. Such response shall include any change made to the proposed code if applicable, and the rationale for such change. The State Fire Marshal shall post such response on the Internet web site of the Department of Administrative Services not later than thirty days after the close of the public comment period.

(e) The State Fire Marshal, in coordination with the advisory committee, shall create and maintain a code-making record for each proposed code, submit such code-making record electronically to the standing legislative regulation review committee and the joint standing committee of the General Assembly having cognizance of matters relating to

public safety and security, and post such code-making record on the Internet web site of the Department of Administrative Services. Such code-making record shall include, but need not be limited to: (1) The final wording of the proposed code in a format consistent with a nationally recognized model building code, (2) the fiscal note prepared pursuant to subsection (c) of this section, (3) the regulatory flexibility analysis prepared pursuant to subsection (c) of this section, (4) all written and oral comments received during the public comment period, and (5) the response to such comments prepared pursuant to subsection (d) of this section.

(f) The standing legislative regulation review committee shall have not more than forty-five days from the date the code-making record is submitted to the committee pursuant to subsection (e) of this section to convene a meeting to approve, disapprove or reject without prejudice the proposed code, in whole or in part. If the proposed code is withdrawn, the State Fire Marshal shall resubmit the proposed code and the committee shall have not more than forty-five days from the date of such resubmittal to convene a meeting to approve, disapprove or reject without prejudice the resubmitted proposed code. If the committee notifies the State Fire Marshal in writing that it is waiving its right to convene a meeting or does not act on a proposed code or a resubmitted proposed code, as the case may be, within such forty-five-day period, the proposed code or resubmitted proposed code shall be deemed to be approved by the committee.

(g) If the committee disapproves a proposed code, in whole or in part, the committee shall notify the State Fire Marshal of the disapproval and the reasons for the disapproval. The State Fire Marshal shall not take any action to implement such disapproved code, except that the State Fire Marshal may submit a substantively new proposed code in accordance with the provisions of this section, provided the General Assembly may reverse such disapproval in accordance with the provisions of section 4-171.

(h) If the committee rejects a proposed code without prejudice, in whole or in part, the committee shall notify the State Fire Marshal of the reasons for the rejection and the State Fire Marshal shall resubmit the proposed code in revised form to the committee not later than thirty days after the date of rejection without prejudice. Each resubmission of the proposed code under this subsection shall include a summary of any revisions to the proposed code. The committee shall have not more than forty-five days after the receipt of the resubmittal to review and take action on such resubmitted proposed code in the same manner as provided in subsection (f) of this section.

(i) The State Fire Prevention Code or any amendment thereto approved or deemed approved by the committee pursuant to subsection (f) of this section is effective and enforceable against any person or party upon its posting on the Internet web site of the Department of Administrative Services, except that: (1) If a later date is required by statute or specified in the code, the later date is the effective date, and (2) a code may not be effective before the effective date of the public act requiring or permitting the code. Such posting shall include a statement by the State Fire Marshal certifying that the electronic copy of the code is a true and accurate copy of the code approved or deemed approved in accordance with subsection (f) of this section. The electronic copy of the State Fire Prevention Code posted on the Internet web site of the Department of Administrative Services shall be the official version for all purposes, including all legal and administrative proceedings.

(j) No provision of the State Fire Prevention Code or any amendment thereto adopted after May 31, 2016, is valid unless adopted in substantial compliance with the requirements of this section. A proceeding to contest any provision of the code on the ground of noncompliance with the requirements of this section shall be commenced within two years from the effective date of the code.

(k) The State Fire Marshal shall advise the public concerning how to obtain a copy of the State Fire Prevention Code and any amendments thereto.

Sec. 29-291c. State Fire Prevention Code and Fire Safety Code: Abatement of certain conditions, injunction, citation, penalties. (a) When the State Fire Marshal or a local fire marshal ascertains that there exists in any building, or upon any premises, a condition that violates the State Fire Prevention Code or Fire Safety Code, the State Fire Marshal or local fire marshal shall order such condition remedied by the owner or occupant of such building or premises. Any such remedy shall be in conformance with all building codes, ordinances, rules and regulations of the municipality involved. Such owner or occupant shall be subject to the penalties prescribed by subsection (e) of this section and, in addition, may be fined fifty dollars a day for each day's continuance of each violation, to be recovered in a proper action in the name of the state.

(b) Upon failure of an owner or occupant to abate or remedy a violation pursuant to subsection (a) of this section within a reasonable period of time specified by the State Fire Marshal or the local fire marshal, the local fire marshal shall promptly notify, in writing,

the prosecuting attorney having jurisdiction in the municipality in which such violation or condition exists of all of the relevant facts. The local fire marshal may request the chief executive officer, any official of the municipality authorized to institute actions on behalf of the municipality in which the hazard exists or the State Fire Marshal, to apply to any court of equitable jurisdiction for an injunction against such owner or occupant for the purpose of closing or restricting from public service or use the place or premises containing the violation or condition until the violation or condition has been remedied, or the State Fire Marshal may apply for such an injunction without such request.

(c) The State Fire Marshal or any local fire marshal empowered to enforce the State Fire Prevention Code or Fire Safety Code may, as an alternative to issuing an order pursuant to subsection (a) of this section, give the owner or occupant a written citation for any violation of the applicable code. No such citation may be issued if the owner or occupant has been previously issued a citation for the same violation by the State Fire Marshal or the local fire marshal within six months prior to the current violation. Such citation shall contain the name and address, if known, of the owner or occupant, the specific offense charged and the time and place of the violation. The citation shall be signed by the State Fire Marshal or local fire marshal and shall be signed by the owner or occupant in acknowledgment that such citation has been received. The State Fire Marshal or local fire marshal shall, if practicable, deliver a copy of the citation to the owner or occupant at the time and place of the violation or shall use some other reasonable means of notification. Any person who is issued a citation for violation of any provision of the State Fire Prevention Code or Fire Safety Code in accordance with this subsection shall be fined not more than two hundred fifty dollars.

(d) If a local fire marshal issues a citation pursuant to subsection (c) of this section, the state shall remit to the municipalities in which the violations occurred ninety per cent of the proceeds of the fine and shall remit to the State Treasurer the remaining ten per cent. If the State Fire Marshal issues a citation pursuant to said subsection, the state shall remit to the State Treasurer the entire proceeds of the fine. Each clerk of the Superior Court or the Chief Court Administrator, on or before the thirtieth day of January, April, July and October in each year, shall certify to the Comptroller the amount due for the previous quarter under this subsection to each municipality served by the office of the clerk or official.

(e) In addition to the fine prescribed in subsection (a) of this section, any person who violates any provision of the State Fire Prevention Code or Fire Safety Code shall be fined

not less than two hundred dollars or more than one thousand dollars or be imprisoned not more than six months, or both.**Sec. 29-306. (Formerly Sec. 29-53). Abatement of fire hazards: Order to remove or remedy; penalties; notification of officials; order to vacate; review by State Fire Marshal.** (a) When the local fire marshal ascertains that there exists in any building, or upon any premises, (1) combustible or explosive matter, dangerous accumulation of rubbish or any flammable material especially liable to fire, that is so situated as to endanger life or property, (2) obstructions or conditions that present a fire hazard to the occupants or interfere with their egress in case of fire, or (3) a condition in violation of the statutes relating to fire prevention or safety, or any regulation made pursuant thereto, the remedy of which requires construction or a change in structure, the local fire marshal shall order such materials to be immediately removed or the conditions remedied by the owner or occupant of such building or premises. Any such removal or remedy shall be in conformance with all building codes, ordinances, rules and regulations of the municipality involved. Any person, firm or corporation which violates any provision of this subsection shall be fined not more than one hundred dollars or be imprisoned not more than three months, or both, and, in addition, may be fined fifty dollars a day for each day's continuance of each violation, to be recovered in a proper action in the name of the state.

(b) Upon failure of an owner or occupant to abate a hazard or remedy a condition pursuant to subsection (a) of this section within a reasonable period of time as specified by the local fire marshal, such local fire marshal shall promptly notify in writing the prosecuting attorney having jurisdiction in the municipality in which such hazard exists of all the facts pertaining thereto, and such official shall promptly take such action as the facts may require, and a copy of such notification shall be forwarded promptly to the State Fire Marshal. The local fire marshal may request the chief executive officer or any official of the municipality authorized to institute actions on behalf of the municipality in which the hazard exists, or the State Fire Marshal, for the purpose of closing or restricting from public service or use such place or premises until such hazard has been remedied, to apply to any court of equitable jurisdiction for an injunction against such owner or occupant; or the State Fire Marshal, on his own initiative, may apply to such court for such injunction. When such hazard is found to exist upon premises supervised or licensed by a state department or agency, the State Fire Marshal shall promptly notify the administrator of such department or agency of his findings and shall issue orders for the elimination of such hazard.

(c) If the local fire marshal or a local police officer determines that there exists in a

building a risk of death or injury from (1) blocked, insufficient or impeded egress, (2) failure to maintain or the shutting off of any fire protection or fire warning system required by the Fire Safety Code or State Fire Prevention Code, (3) the storage of any flammable or explosive material without a permit or in quantities in excess of any allowable limits pursuant to a permit, (4) the use of any firework or pyrotechnic device without a permit, or (5) exceeding the occupancy limit established by the State Fire Marshal or a local fire marshal, such fire marshal or police officer may issue a verbal or written order to immediately vacate the building. Such fire marshal or police officer shall notify or submit a copy of such order to the State Fire Marshal if such marshal or officer anticipates that any of the conditions specified in subdivisions (1) to (5), inclusive, of this subsection cannot be abated in four hours or less from the time of such order. Upon receipt of any such notification or copy, the State Fire Marshal shall review such order to vacate, and after consultation with the local fire marshal or local police officer, determine whether to uphold, modify or reverse such order, with any further conditions the State Fire Marshal deems appropriate to protect any person from injury. A violation of such order shall be subject to the penalties under section 29-291c.

Sec. 29-356. (Formerly Sec. 29-96). Definitions. As used in sections 29-356 to 29-365, inclusive:

(1) "Fireworks" means and includes any combustible or explosive composition, or any substance or combination of substances or article prepared for the purpose of producing a visible or an audible effect by combustion, explosion, deflagration or detonation, and includes blank cartridges, toy pistols, toy cannons, toy canes or toy guns in which explosives are used, the type of balloons which require fire underneath to propel the same, firecrackers, torpedoes, skyrockets, Roman candles, Daygo bombs, and any fireworks containing any explosive or flammable compound, or any tablets or other device containing any explosive substance, except that the term "fireworks" shall not include sparklers and fountains and toy pistols, toy canes, toy guns or other devices in which paper caps manufactured in accordance with the regulations of the United States Interstate Commerce Commission or its successor agency for packing and shipping of toy paper caps are used and toy pistol paper caps manufactured as provided therein.

(2) "Sparklers" means a wire or stick coated with pyrotechnic composition that produces a shower of sparks upon ignition.

(3) "Fountain" means any cardboard or heavy paper cone or cylindrical tube containing pyrotechnic mixture that upon ignition produces a shower of colored sparks or smoke. "Fountain" includes, but is not limited to, (A) a spike fountain, which provides a spike for insertion into the ground, (B) a base fountain which has a wooden or plastic base for placing on the ground, or (C) a handle fountain which is a handheld device with a wooden or cardboard handle.

2022 Connecticut State Fire Prevention Code Connecticut Amendments to NFPA 1™ - Fire Code; 2021 edition

Chapter 1

Administration

(Add) **1.0 Title, Administration, and Applicability.**

(Add) **1.0.1 Adopted Standard.**

The following standard promulgated by the National Fire Protection Association (NFPA) is hereby adopted as part of this code:

NFPA 1, *Fire Code*™ of the National Fire Protection Association, (NFPA 1), 2021 edition, with ANNEXES A, C, and F except as amended, altered or deleted and by the addition of certain provisions as indicated in Section 1.0.2 of this Code.

This standard is available from the National Fire Protection Association, One Batterymarch Park, Quincy, Massachusetts 02169-7471; telephone 1-800-344-3555, www.nfpa.org.

— (Add) **1.0.2 Connecticut Amendments**^

The NFPA 1, *Fire Code*™, as amended, altered, deleted, or added to, is found in Chapters 1 through 75, inclusive, of this Code.

— (Add) **1.0.3 Connecticut Amendment Conventions**^ The model code adopted is amended to meet the needs of the State of Connecticut as identified by the following conventions:

- (1) A section or subsection in the Connecticut Amendments preceded by "Amd" indicates the substitution of this provision.
- (2) A section or subsection in the Connecticut Amendments preceded by "Del" indicates the deletion of this provision.
- (3) A section or subsection in the Connecticut Amendments preceded by "Add" indicates the addition of this provision.

— (Add) **1.0.4** The term Connecticut State Fire Safety Code or the nomenclature CSFSC shall mean the Connecticut State Fire Safety Code adopted pursuant to section 29-292 of the Connecticut General Statutes. The term Connecticut State Building Code or the nomenclature CSBC shall mean the Connecticut State Building Code adopted pursuant to section 29-252 of the Connecticut General Statutes.

(Add) **1.0.5** This code and its referenced standards shall be administered as provided in chapter 541 of the Connecticut General Statutes.

(Add) **1.0.6** No person shall remove or modify any fire protection system or feature installed or maintained under the provisions of the CSFSC or the CSBC, unless otherwise permitted by those codes. (Buildings and structures, and parts thereof, processes, and activities that occur in all buildings and structures regulated by this Code.) Other requirements of this Code shall be maintained in a safe condition as prescribed by the referenced standards. Devices or safeguards required by the CSFSC or the CSBC shall be maintained to provide the level of protection to which they were designed in conformance with the code edition under which installed.

(Amd) **1.1.1** The scope includes, but is not limited to, the following:

- (1) For the purposes of prevention of fire and other related emergencies.
- (2) Oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in all buildings and structures regulated by the code and the areas adjacent to such buildings and structures.
- (3) Inspections of permanent and temporary processes, equipment, systems and other fire and related life safety situations.
- (4) Fire and life safety education of fire brigades, employees, responsible parties and the general public.
- (5) Maintenance, repairs, servicing, and testing of fire protection systems and equipment.
- (6) Use, storage, and handling of medical gas systems.
- (7) Access requirements for fire department operations.
- (8) Hazards from outside fires in vegetation, trash, building debris and other materials.
- (9) Regulation and control of special events, including, but not limited to, assemblage of people, exhibits, trade shows, amusement parks, haunted houses, outdoor events and other similar special temporary and permanent occupancies.
- (10) Combustibles that contribute to fire spread, fire load and smoke production.
- (11) Storage, use, processing, handling, and on-site transportation of flammable and combustible gases, liquids and solids.
- (12) Storage, use, processing, handling and on-site transportation of hazardous materials.
- (13) Conditions affecting firefighter safety.
- (14) Provisions for detached private dwellings occupied by one or two families and townhouses with respect to smoke alarms and carbon monoxide detectors as specified in the Connecticut State Building Code (CSBC) and subject to the specific inspection criteria for smoke detection and warning equipment of section 29-305 of the Connecticut General Statutes.
- (15) Provisions for theatrical performances, sporting or athletic events, using flame effects before an audience or in the production of television, motion picture or other performances.
- (16) Enhance the enforcement capabilities of local fire marshals.

(Add) **1.1.1.1 Provisions in Excess of Code Requirements.** Nothing in this code shall be construed to prohibit a better type of construction, additional means of egress, additional

*incomplete sentence
is this an attempt to refer to or match language of Sec. 29-291a?*

safeguards or safety features, or an otherwise safer condition than that specified by the minimum requirements of this code.

(Add) **1.1.1.2** This Code shall **not** apply to the following:

- (1) Detached one- and two-family dwellings and multiple single-family dwellings attached side-by-side (townhouse as defined in the 2021 International Residential Code portion of the 2022 Connecticut State Building Code) not more than three stories in height with each dwelling having a separate means of egress.
- (2) Buildings designed, constructed and occupied in accordance with the provisions of the 2021 International Residential Code portion of the 2022 Connecticut State Building Code. Such buildings shall be deemed single-family dwellings for the application of this code and section 29-305 of the Connecticut General Statutes.
- (3) Portable grandstand and bleachers providing seating for fewer than 100 persons located outside of a building.
- (4) Any federal agency performing construction or operating on federally owned land or on leased land totally under the control of the federal government.
- (5) The installation, alteration or repair of generation, transmission, distribution, metering or other related equipment that is under the ownership and control of public service companies as defined in section 16-1 of the Connecticut General Statutes.

(Amd) **1.1.2 Title.** The Connecticut State Fire Prevention Code (CSFPC) and the adopted standards, as amended, shall be known as the 2022 Connecticut State Fire Prevention Code, hereinafter referred to as "the Code" or "this Code".

(Amd) **1.3.2.2** Where no applicable codes, standards, or requirements are set forth in this Code or contained within other laws, codes, regulations, ordinances, or by-laws adopted by the authority having jurisdiction (AHJ), compliance with applicable codes and standards of NFPA or other nationally recognized standards, as are approved, shall be deemed as prima facie evidence of compliance with the intent of this Code. *remove underline*

(Add) **1.3.3.3** References to NFPA 101®, Life Safety Code®, within the body of the model document shall be considered references to the 2022 Connecticut State Fire Safety Code adopted pursuant to section 29-292 of the Connecticut General Statutes.

(Add) **1.3.3.4** References to the NFPA 5000®, or The Building Code within the body of this code shall be considered references to the Connecticut State Building Code (CSBC) adopted pursuant to section 29-252 of the Connecticut General Statutes.


(Amd) **1.3.6.1** Buildings permitted for construction on or after January 1, 2006₁ shall comply with Part III of the CSFSC and the CSBC. *remove underline*

(Amd) **1.3.6.2** Buildings in existence or permitted for construction prior to January 1, 2006₁ shall comply with Part IV of the CSFSC.

(Amd) **1.3.6.3** Repairs, renovations, alterations, reconstruction, change of occupancy and additions to buildings shall conform to this Code, the CSFSC, and the CSBC to the extent called for by those codes.

(Add) **1.3.6.4**

2022 CONNECTICUT STATE FIRE PREVENTION CODE APPLICATION FLOW CHART



(Amd) **1.3.7 Severability.**

(Add) **1.3.7.1** If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

(Add) **1.3.7.2** In the event any part or provision of this code is held to be illegal or void, this shall not have the effect of making void or illegal any of the other parts or provisions of this code which are determined to be legal, and it shall be presumed that this code would have been adopted without such illegal or ~~invalid~~ parts or provisions.

(Del) **1.4.1.1 Compliance with Subsequent Editions of Referenced Publications.** Delete section.

(Del) **1.4.1.1.1** Delete section.

(Del) **1.4.1.1.2** Delete section.

(Del) **1.4.2 Alternatives.** Delete section.

(Amd) **1.4.3 Variations or Exemptions.** Buildings, facilities or properties with equivalencies, alternatives or modifications accepted by the State Fire Marshal pursuant to section 29-296 of the Connecticut General Statutes shall be considered as conforming to this code. The use of performance based criteria evaluated by the State Fire Marshal as an equivalency to this code shall be by the variance of exemption as outlined in Connecticut General Statutes ~~Section 29-296~~.

(Del) **1.4.4** Delete section.

(Del) **1.4.5** Delete section.

(Del) **1.4.6** Delete section.

(Add) **1.4.6 Authority Having Jurisdiction, Review of Decision.**

(a) For the purposes of this code adopted pursuant to section 29-291a of the Connecticut General Statutes, the authority having jurisdiction (AHJ) shall mean the State Fire Marshal regarding the proper administration, application, interpretation and modification of the requirements contained in this code.

(b) The local fire marshal shall make the initial determination concerning compliance with the provisions of this code, except as expressly provided in the wording of a section or in subsections (c) and (d) of this section. Upon the request of any person determined to have the right to appeal or when the State Fire Marshal has reason to believe that such local fire marshal has misconstrued or misinterpreted any provision of this code, the initial determination of a local fire marshal may be reviewed by the State Fire Marshal.

(c) The State Fire Marshal shall make the determination concerning compliance with this code on state-owned property.

(d) Where this code enables a local municipality or fire district to adopt a portion of this code by local ordinance as permitted by section 7-148 of the Connecticut General Statutes, the local fire marshal having jurisdiction shall be deemed the authority having jurisdiction. Any decision made by any such authority pursuant to a local ordinance may not be appealed to the State Fire

Marshal.

(e) Except as provided in subsection (d) of this section, a decision of the local fire marshal may be reviewed by the State Fire Marshal in accordance with section 29-291d of the Connecticut General Statutes.

Section 29-291c of the

(Amd) 1.6 Abatement of Hazards; Penalty

See substantive concern

(a) The local fire marshal for the fire marshal's respective jurisdiction or the State Fire Marshal shall order hazardous conditions contrary to the provisions of this code to be remedied in accordance with Connecticut General Statutes ~~Section 29-291c as amended by Public Act 21-165~~. An order to vacate all or part of a building may be issued by a local fire marshal or local police officer in accordance with section 29-306 of the Connecticut General Statutes when severe hazardous conditions exist. The penalty for the failure to remedy or abate such hazards shall be as ~~described~~ *delete* prescribed in section 29-291c of the Connecticut General Statutes.

(b) Pursuant to section 29-291c of the Connecticut General Statutes, section 1.6.1 of this code lists those sections of this code for which a citation may be issued.

(Add) 1.6.1 Enforcement by Citations

The following chapters or sections of this code may be enforced through the use of the citation process pursuant to section 29-291c of the Connecticut General Statutes.

<u>Chapter /Section</u>	<u>Subject Matter</u>
Section 1.12	Operating without a permit required by local ordinance
Section 10.13.9	Provisions for naturally cut (Christmas) trees
Sections 10.7, 13.1.7	Failure to maintain or the shutting off of any fire protection or fire warning system required by the Connecticut State Fire Safety Code
Sections 14.4.1, 14.4.3, 14.4.3.1	Blocked, insufficient or impeded egress
Chapter 16	Safeguards during building construction, alteration, and demolition operations
Section 20.1.5.10.4	Exceeding the established occupancy limit- assembly occupancies
Section 20.12.5	Storage and display of sparklers and fountains
Chapter 41	Hot work operations
Section 50.5	Procedures for use and maintenance of commercial cooking equipment
Section 65.4	Flame effects before an audience
Section 65.10	Sale, handling, and storage of fireworks, sparklers, and fountains
Section 69.3.13.1	Patio heaters

Section 69.4.1.3

Filling, evacuation, or transporting an LP cylinder or tank without the authorization of the owner of the tank.

(Del) **1.7.2* Minimum Qualifications to Enforce This Code.** Delete section.

(Del) **1.7.3 Interpretations, Rules, and Regulations.** Delete section.

(Del) **1.7.4 Enforcement Assistance.** Delete section.

(Del) **1.7.5 Delegation of Authority.** Delete section.

(Del) **1.7.6.1* Enforcement Assistance.** Delete section.

(Amd) **1.7.6.1** The State Fire Marshal or local fire marshal may accept reports of the building official concerning a code compliance review or inspection in lieu of conducting an in-person review or inspection.

(Del) **1.7.6.2** Delete section.

(Amd) **1.7.7 Inspections.**

(a) Each local fire marshal, the State Fire Marshal and their respective designees shall conduct inspections as prescribed in section 29-305 of the Connecticut General Statutes of buildings, processes, and facilities regulated by this code within their jurisdictions. (The inspections required by this section shall be the entire building the occupancy is located in, NOT just that portion of the building containing the occupancy.)

(b) The minimum requirements for the frequency of inspections conducted pursuant to section 29-305 of the Connecticut General Statutes shall be as follows: (Note: Definitions of classifications are found in Chapter 3 of the Connecticut State Fire Safety Code.)

indent (1) Annual inspections for the occupancy classifications; all R Residential, A-1, A-2, E, H-1, I-1, I-2 including small I-2, M selling consumer fireworks [sparklers and fountains] (1.4G), and H-3 containing consumer fireworks [sparklers and fountains] (1.4G).

(1) (2) Inspections every two years for the occupancy classifications; A-3, H-2, I-3, I-4, B-Medical, B-College, and Ambulatory Health Care.

(2) (3) Inspections every three years for occupancy classifications; B, H-3, M, S-1, A-4 and A-5.

(3) (4) Inspections every four years for the occupancy classifications; F-1, F-2, H-4, H-5, S-2 and U.

(c) For the purpose of determining compliance with the review of design and construction plans, drawings, and specifications for existing occupancies subject to an abatement order for violations of this code, each local fire marshal, the State Fire Marshal and their respective designees may conduct inspections as often as may be necessary during the work required to correct the violation for the purpose of satisfying themselves that all work is in accordance with the approved plans and specifications and this code. (Note: New fire protection systems, electrical, and mechanical work shall conform to the requirements of the Connecticut State Fire Safety Code.)

(Del) **1.7.7.1*** Delete section.

(Del) **1.7.7.2** Delete section.

(Del) 1.7.7.3 Delete section.

(Del) 1.7.7.4 Delete section.

(Del) 1.7.7.5 Delete section.

(Amd) **1.7.8.1 Authority to Abate of Fire Hazards.** See section 29-306 of the Connecticut General Statutes.

(Del) 1.7.8.2 Delete section.

(Del) 1.7.2.3 Delete section.

(Del) **1.7.9 Interference with Enforcement.** Delete section.

(Del) **1.7.10 Impersonation.** Delete section.

(Del) **1.7.11 Investigation.** Delete section in its entirety.

(Amd) **1.7.12.1** For the purpose of determining compliance with the review of design and construction plans, drawings, and specifications for existing occupancies subject to an abatement order for violations of this code, the AHJ shall have the authority to require an applicant to submit plans and specifications to assure compliance with the applicable codes and standards.

(Amd) **1.7.12.2** Detailed plans and specifications for existing occupancies subject to an abatement order for violations of this code shall be submitted by the permit applicant to the local fire marshal having jurisdiction to demonstrate compliance with section 29-263 of the Connecticut General Statutes.

(Amd) **1.7.12.3** A municipality or fire district may, by ordinance, establish a fee for construction document review conducted pursuant to Sections 1.7.12.1 or 1.7.12.2 of this code, provided the municipality or fire district prescribes the manner in which this schedule of fees shall be posted for public view.

(Del) 1.7.12.4 Delete section.

(Del) 1.7.12.5 Delete section.

(Del) 1.7.12.6 Delete section.

(Del) 1.7.12.8 Delete section.

(Del) 1.7.12.9 Delete section.

(Amd) **1.7.16.1.** Refer to section 29-306 of the Connecticut General Statutes.

(Amd) **1.7.16.2** Refer to section 29-306 of the Connecticut General Statutes.

(Del) **1.7.16.3** Delete section.

(Del) **1.7.16.4** Delete section.

(Amd) **1.7.17.1** The AHJ shall have the authority to require standby fire personnel or an approved fire watch when potentially hazardous conditions or a reduction in a life safety feature exist due to the type of performance, display, exhibit, occupancy, contest, or activity; an impairment to a fire protection feature; or the number of persons present.

(Del) **1.7.17.2** Delete section.

(Del) **1.7.17.2.1** Delete section.

fix font size

(Amd) **1.7.17.3*** Such standby fire personnel or fire watch personnel shall be subject to the AHJ's orders at all times and shall be identifiable and remain on duty during the times such places are open to the public, when such activity is being conducted, or as required by the AHJ.

(Del) **1.8 Duties and Powers of the Incident Commander.** Delete section in its entirety.

(Amd) **1.9.1** See section 29-298 of the Connecticut General Statutes.

- (Del) **1.9.2** Delete Section.

- (Del) **1.9.3** Delete Section.

(Del) **1.10 Fire Code Board of Appeals.** Delete section in its entirety.

(Del) **1.11.4 Emergency Response Records.** Delete section in its entirety.

(Amd) **1.12.1** A municipality or fire district, by ordinance, may establish requirements and a fee schedule for permits, certificates, notices, approvals, or orders pertaining to fire control and fire hazards pursuant to Section 1.12 of this code. The local fire marshal shall issue such permits, certificates, notices, approvals or orders.

(Amd) **1.12.8** Permits as specified by the ordinance shall be required in accordance with Tables 1.12.8(a), 1.12.8(b), 1.12.8(c), and 1.12.8(d) of this code.

(Amd) **Table 1.12.8(a) Permit Requirements.**

remove underline

Table 1.12.8(a) Permit Requirements		
Operations and Materials	Permit Required	Cross Reference Section No.
Additive Manufacturing	To conduct industrial additive manufacturing operations	46.1.2
Aerosol Products	To store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 lb. (226.8kg)	61.1.2
Aircraft Fuel Servicing	To provide aircraft fuel servicing	42.10.1.2

Aircraft Hangars	To service or repair aircraft	21.1.1
Airport Terminal Buildings	To operate an airport terminal building	21.2.2.1
Ambulatory Health Care Occupancy	To operate an ambulatory health care occupancy	20.6.1.1
Ammonium Nitrate	To store	Chapter 74
Apartment Buildings and Dormitories	To operate an apartment building or dormitory	20.9.1.1
Assembly Occupancies	To operate an assembly occupancy	20.1.1.1
Automatic Fire Suppression System	To operate or remove from service any automatic fire suppression system and related equipment--final system certification and periodic inspection/testing afterward	13.1.1.1, 50.4.2
Automobile Wrecking Yards	To operate automobile wrecking yards	22.2
Automotive Fuel Servicing	To provide automotive fuel servicing	42.1.2
Battery System	To operate stationary lead-acid battery systems having an electrolyte capacity of more than 100 gal (379 L) in sprinklered buildings or 50 gal (189 L) in nonsprinklered buildings	52.1.2
Business Occupancies	To operate a business occupancy	20.13.1.1
Candles, Open Flames, and Portable Cooking	To use in connection with assembly areas, dining areas of restaurants or drinking establishments	20.1.1.1
Cannabis Growing, Processing, or Extrication Facilities	For the alteration or operation of a cannabis growing, processing, or extraction facility.	38.2
Cellulose Nitrate Film	To store, handle or use	20.15.7.2
Cellulose Nitrate Plastic	To store or handle more than 25 lbs. (11.3kg)	43.1.1.6
Cleanrooms	To operate	23.3
Combustible Fibers	To store or handle combustible fibers greater than 100 ft ³ . (2.8 m ³)	45.1.4
Combustible Material Storage	To store more than 2500 ft. ³ (70.8 m ³) gross volume	10.19.2; 19.1.1; 31.2
Commercial Rubbish-Handling Operation	To operate	19.1.1
Compressed Gases	(1) To store, use, or handle compressed gasses in excess of the amounts listed in Table 1.12.8(b) of this code (2) To repair damage to, abandon, remove, place temporarily out of service, close, or substantially modify a compressed gas system when the compressed	63.1.2

	gases in use or storage exceeds the amount listed in Table 1.12.8(b) of this code	
Cooking Operations – Mobile and Temporary	To locate or operate mobile and temporary cooking operations	50.8.1.2
Covered Mall Buildings	Additional requirements for facilities that utilize mall area for exhibits or displays	20.1.5.5.1
Crop mazes	To operate a crop maze	10.14.12.1
Cryogenics	To produce, store, or handle cryogenics in excess of amounts listed in Table 1.12.8(c) of this code Exception: Where federal or other state regulations apply or for a fuel system of a vehicle	63.1.2
Cutting and Welding Operation	To operate within a jurisdiction	41.1.5
Day-care Occupancies	To operate a day-care occupancy	20.3.1.4.1
Drycleaning Plants	To engage in business of dry-cleaning or to change to a more hazardous cleaning solvent	24.2
Dust-Producing Operations	To operate a grain elevator, flour mill, starch mill, feed mill, or plant pulverizing aluminum, coal, cocoa, magnesium, spices, sugar, or other similar combustible material	40.2
Educational Occupancy	To operate an educational occupancy	20.2.1.1
Energy Storage Systems	To install and operate energy storage systems exceeding Tables 52.2.1 and 52.3.1 of this Code	52.1.2
Exhibit and Trade Shows	To operate all exhibits and trade shows held within a jurisdiction	20.1.5.5.1
Fire Alarm and Detection Systems and Related Equipment	To operate or remove from service any fire alarm and detection equipment and related equipment	13.1.1.1
Fire Hydrants and Water-Control Valves	To use a fire hydrant or operate a water-control valve intended for fire suppression purposes on private property	13.1.1.1
Fire Pumps and Related Equipment	To operate or remove from service any fire pumps, jockey pumps, controllers, generators, or related equipment	13.1.1.1
Flame Effects	To use flame effects before an audience	65.4.2
Flammable and Combustible Liquids	(1) To use or operate, repair, or modify a pipeline for the on-site transportation of flammable or combustible liquids	66.1.5

	<p>(2) To store, handle, or use Class I liquids in excess of 5 gallons or in excess of 10 gallons outside a building</p> <p>Exception to #2: A permit is not required for the following:</p> <ul style="list-style-type: none"> (A) To store or use Class I liquids in the fuel tank of a motor vehicle, aircraft, motor boat, mobile power plant, or mobile heating plant unless such storage, in the opinion of the AHJ, would cause an unsafe condition (B) To store or use paints, oils, varnishes, or similar flammable mixtures when such liquids are stored for maintenance, painting, or similar purposes for a period of not more than 30 days <p>(3) To store, handle, or use Class II or Class III A liquids in excess of 25 gallons in a building or in excess of 60 gallons outside a building</p> <p>Exception to #3: Fuel oil used in conjunction with oil-burning equipment.</p> <p>(4) To remove Class I or Class II liquids from an underground storage tank used for fueling motor vehicles by any means other than an approved, stationary on-site pumps normally used for dispensing purposes</p> <p>(5) To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel dispensing stations, refineries, distilleries, and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed, or used</p> <p>(6) To alter, clean, repair, line with a protective coating, remove, abandon, place temporarily out of service, or otherwise dispose of a flammable or combustible liquid tank</p>	
Fruit Ripening	To operate a fruit ripening process	63.1.2
Hazardous Materials	<ul style="list-style-type: none"> (1) To store, transport on site, dispense, use, or handle hazardous materials in excess of the amounts listed in Table 1.12.8 (d) of this code (2) To repair, abandon, remove, place temporarily out of service, close, or substantially modify a storage facility or other area regulated by Chapter 60 of this code when the hazardous materials 	Chapter 60

	in use or storage exceed the amounts listed in Table 1.12.8(d) of this Code	
Health Care Facility	<i>←</i> (3) To operate a health care occupancy	20.4.1.1
High-Piled Combustible Storage	To use any building or portion thereof as a high-piled storage area exceeding 500 ft. ² (46.45 m ²)	20.15.8.2
Hot Work Operations	To conduct hot work. For additional permit requirements for hot work operations, see Section 41.1.5 of this code	41.1.5
Hotels	To operate a hotel, motel or bed and breakfast establishment	20.8.1.1
Industrial Occupancies	To operate an industrial occupancy	20.14.2
Industrial Ovens and Furnaces	To operate industrial ovens and furnaces covered by Chapter 51 of this code	51.1.2
Laboratories	To operate	26.2
Liquefied Petroleum Gases	To store, use, handle, or dispense LP-Gas of 125 gallons (water capacity) aggregate capacity or greater	42.1.2, 69.1.2
Liquid- or Gas-Fueled Vehicles	To display, compete, or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings	20.1.5.5.1
Lodging or Rooming Houses and Bed and Breakfast Establishments	To operate a lodging and rooming house or a bed and breakfast establishment. <i>delete</i>	20.10.1.1
Lumberyards and Woodworking Plants	To store lumber exceeding 100,000 board ft.	31.2
Marine Craft Fuel Servicing	To provide marine craft fuel servicing	42.1.2
Mercantile Occupancies	To operate a mercantile occupancy	20.12.1.1
Motion Picture and Television Production Studio Soundstages and Approved Production Facilities	To design, construct, operate, and maintain soundstages and approved production facilities used in motion picture and television industry productions	32.2
Organic Coatings	To operate and maintain a facility that manufactures organic coatings	43.1.1.6
<i>delete extra row</i>		
Organic Peroxide Formulations	To store, transport on site, use, or handle materials in excess of amounts listed in Tables 1.12.8(c) and (d) of this code	Chapter 75
Outside Storage of Tires	To store more than 500 tires outdoors	33.1.2
Oxidizers	To store, transport on site, use, or handle materials in excess of amounts listed in Tables 1.12.8(c) and (d) of this code	Chapter 70

Places of Assembly, Including Special Amusement Buildings	To operate a place of assembly	20.1.1.1
Pyrotechnic Articles (Fireworks, Sparklers and Fountains)	To manufacture, store, or sell pyrotechnic articles, including sparklers and fountains	65.10.1.2
Pyroxylin Plastics	To store, handle, assemble, or manufacture pyroxylin plastics	43.1.1.6
Refrigeration Equipment	To operate a mechanical refrigeration unit or system regulated by this code	53.1.2
Repair Garages and Service Stations	To operate service stations and repair garages	30.1.1.3, 30.2.1.1
Residential Board and Care Occupancies – Including Bed & Breakfast Establishments	To operate a residential board and care occupancy	20.5.1.1
Rooftop Heliports	To operate a rooftop heliport	21.3.2.1
Solvent Extraction	To store, use and handle	44.3
Sparklers and Fountains	To sell, handle on-site, manufacture and store sparklers and fountains	65.5.2, 65.10.1.2
Special Outdoor Events, Carnivals, and Fairs	To locate and operate special outdoor events, carnivals, and fairs	10.14.1
Special Structures and High-Rise Buildings	To operate special structures and high-rise buildings	20.16.1.1.1
Spraying or Dipping of Flammable Finish	To operate any spray room, spray booth, or preparation work station, or to conduct a spraying or dipping operation utilizing flammable or combustible liquids or powder coatings	43.1.1.6
Standpipe System	To operate or remove from service any standpipe system and related equipment	13.1.1.1
Storage Occupancies	To operate a storage occupancy	20.15.2
Tar Kettles and Rubberized Asphalt Melters	To place a tar kettle, placement shall be obtained prior to the placement of a tar kettle	16.8.1.2, 16.8.3.2
Tire Storage	To use an open area or portion thereof to store in excess of 500 tires	33.1.2; 34.1.2
Torch-Applied Roofing Operation	To use a torch to apply roofing materials	16.7.1
Wood Products	To store chips, hogged material, lumber or plywood in excess of 200 ft ³ (5.7 m ³)	31.2

*Maintenance performed in accordance with this Code is not considered a modification and does

not require a permit.

(Amd) **1.13 Licenses.**

(Del) **1.13.1** Delete section.

(Del) **1.13.2** Delete section.

(Del) **1.13.3** Delete section.

(Del) **1.13.4** Delete section.

(Del) **1.13.5** Delete section.

(Del) **1.13.6** Delete section.

(Del) **1.13.7** Delete section.

(Del) **1.13.8** Delete section.

(Del) **1.13.9** Delete section.

(Del) **1.13.10** Delete section.

(Amd) **1.13.11** Any individual or company to whom a license has been granted shall, upon request, produce and show proper identification and the license to anyone for whom that individual or company seeks to render services or to the AHJ.

(Del) **1.13.12** Delete section in its entirety.

(Amd) **1.14.1** Detailed plans and specifications for processes and material handling, modifications to existing processes and material handling and other conditions regulated by this code, shall be submitted by the applicant to the local fire marshal having jurisdiction to demonstrate compliance with this code and applicable referenced standards.

(Del) **1.14.3** Delete section.

(Del) **1.15.2** Delete section.

(Del) **1.15.3** Delete section.

(Del) **1.15.4** Delete section.

(Amd) **1.16.1 Where Required.** Whenever the AHJ determines a violation(s) of this Code, a written notice shall be issued to confirm such determination. Refer also to section 29-305 of the Connecticut General Statutes.

(Del) **1.16.2** Delete section in its entirety.

(Del) **1.16.3 Destruction or Removal of Notice.** Delete section.

(Del) **1.16.4 Penalties.** Delete section in its entirety.

(Amd) **1.16. 5 Abatement.** Refer to section 29-291c of the Connecticut General Statutes.

Chapter 2

Referenced Publications

(Amd) **2.1.1.2*** Compliance with individual specific sections contained in subsequent edition referenced publications and not the entire referenced publication shall only be approved by the AHJ through technical documentation submitted in compliance with sections 1.4.1 and 1.4.3 of this Code.

(Add) **2.1.2** Existing buildings or installations that do not comply with the provisions of the following referenced publications shall be permitted to be continued in service, provided the lack of conformity with these standards does not present a serious hazard to occupants as determined by the authority having jurisdiction.

(Amd) **2.2 NFPA Publications.** National Fire Protection Association. 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101, www.nfpa.org

Standard reference number	Title
NFPA 2	Hydrogen Technologies Code, 2020 edition
NFPA 10	Standard for Portable Fire Extinguishers, 2018 edition
NFPA 11	Standard for Low-, Medium-, and High-Expansion Foam, 2016 edition
NFPA 12	Standard on Carbon Dioxide Extinguishing Systems, 2018 edition
NFPA 12A	Standard on Halon 1301 Fire Extinguishing Systems, 2018 edition
NFPA 13	Standard for the Installation of Sprinkler Systems, 2019 edition
NFPA 13D	Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes, 2019 edition
NFPA 13R	Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies, 2019 edition
NFPA 14	Standard for the Installation of Standpipe and Hose Systems, 2019 edition
NFPA 15	Standard for Water Spray Fixed Systems for Fire Protection, 2017 edition
NFPA 16	Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems, 2019 edition
NFPA 17	Standard for Dry Chemical Extinguishing Systems, 2021 edition
NFPA 17A	Standard for Wet Chemical Extinguishing Systems, 2021 edition
NFPA 20	Standard for the Installation of Stationary Pumps for Fire Protection, 2019 edition

NFPA 22	Standard for Water Tanks for Private Fire Protection, 2018 edition
NFPA 24	Standard for the Installation of Private Fire Service Mains and Their Appurtenances, 2019 edition
NFPA 25	Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2020 edition
NFPA 30	Flammable and Combustible Liquids Code, 2021 edition
NFPA 30A	Code for Motor Fuel Dispensing Facilities and Repair Garages, 2021 edition
NFPA 30B	Code for the Manufacture and Storage of Aerosol Products, 2019 edition
NFPA 31	Standard for the Installation of Oil-Burning Equipment, 2020 edition
NFPA 32	Standard for Drycleaning Facilities, 2016 edition
NFPA 33	Standard for Spray Application Using Flammable or Combustible Liquids, 2018 edition
NFPA 34	Standard for Dipping, Coating and Printing Processes Using Flammable or Combustible Liquids, 2018 edition
NFPA 35	Standard for the Manufacture of Organic Coatings, 2016 edition
NFPA 36	Standard for Solvent Extraction Plants, 2017 editions <i>delete</i>
NFPA 37	Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines, 2021 edition
NFPA 40	Standard for the Storage and Handling of Cellulose Nitrate Film, 2019 edition
NFPA 45	Standard on Fire Protection for Laboratories Using Chemicals, 2019 edition
NFPA 51	Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes, 2018 edition
NFPA 51B	Standard for Fire Prevention During Welding, Cutting, and Other Hot Work, 2019 edition
NFPA 52	Vehicular Natural Gas Fuel Systems Code, 2019 edition
NFPA 54	National Fuel Gas Code, 2021 edition
NFPA 55	Compressed Gases and Cryogenic Fluids Code, 2020 edition
NFPA 56	Standard for Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems, 2020 edition
NFPA 58	Liquefied Petroleum Gas Code, 2020 edition
NFPA 59	Utility LP-Gas Plant Code, 2021 edition
NFPA 59A	Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG), 2019 edition
NFPA 61	Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities, 2020 edition
NFPA 68	Standard on Explosion Protection by Deflagration Venting, 2018 edition
NFPA 69	Standard on Explosion Prevention Systems, 2019 edition
NFPA 70®	National Electrical Code®, 2020 edition, as amended by the Connecticut State Building Code
NFPA 72®	National Fire Alarm and Signaling Code®, 2019 edition

NFPA 75	Standard for the Fire Protection of Information Technology Equipment, 2020 edition
NFPA 76	Standard for the Fire Protection of Telecommunications Facilities, 2020 edition
NFPA 80	Standard for Fire Doors and Other Opening Protectives, 2019 edition
NFPA 82	Standard on Incinerators and Waste and Linen Handling Systems and Equipment, 2019 edition
NFPA 85	Boiler and Combustion Systems Hazards Code, 2019 edition
NFPA 86	Standard for Ovens and Furnaces, 2019 edition
NFPA 88A	Standard for Parking Structures, 2019 edition
NFPA 90A	Standard for the Installation of Air-Conditioning and Ventilating Systems, 2021 edition
NFPA 90B	Standard for the Installation of Warm Air Heating and Air-Conditioning Systems, 2021 edition
NFPA 91	Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Particulate Solids, 2020 edition
NFPA 92	Standard for Smoke Control Systems, 2018 edition
NFPA 96	Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, 2021 edition
NFPA 99	Health Care Facilities Code, 2021 edition
NFPA 101®	Life Safety Code® – 2021 edition as amended by Part IV of the Connecticut State Fire Safety Code.
NFPA 102	Standard for Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures, 2016 edition
NFPA 105	Standard for Smoke Door Assemblies and Other Opening Protectives, 2019 edition
NFPA 110	Standard for Emergency and Standby Power Systems, 2019 edition
NFPA 111	Standard on Stored Electrical Energy Emergency and Standby Power Systems, 2019 edition
NFAP 115	Standard for Laser Fire Protection, 2020 edition
NFPA 120	Standard for Fire Prevention and Control in Coal Mines, 2020 edition
NFPA 122	Standard for Fire Prevention and Control in Metal/Nonmetal Mining and Metal Mineral Processing Facilities, 2020 edition
NFPA 130	Standard for Fixed Guideway Transit and Passenger Rail Systems, 2020 edition;
NFPA 140	Standard on Motion Picture and Television Production Studio Soundstages, Approved Production Facilities, and Production Locations, 2018 edition
NFPA 160	Standard for the Use of Flame Effects Before an Audience, 2021 edition
NFPA 170	Standard for Fire Safety and Emergency Symbols, 2018 edition
NFPA 204	Standard for Smoke and Heat Venting, 2018 edition

NFPA 211	Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances, 2019 edition
NFPA 220	Standard on Types of Building Construction, 2021 edition
NFPA 221	Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls, 2018 edition
NFPA 232	Standard for the Protection of Records, 2017 edition
NFPA 241	Standard for Safeguarding Construction, Alteration, and Demolition Operations, 2019 edition
NFPA 251	Standard Methods of Test of Fire Resistance of Building Construction and Materials, 2006 edition
NFPA 252	Standard Methods of Fire Tests of Door Assemblies, 2017 edition
NFPA 253	Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source, 2019 edition
NFPA 257	Standard on Fire Test for Window and Glass Block Assemblies, 2017 edition
NFPA 259	Standard Test Method for Potential Heat of Building Materials, 2018 edition
NFPA 260	Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture, 2019 edition
NFPA 261	Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes, 2018 edition
NFPA 265	Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile or Expanded Vinyl Wall Coverings on Full Height Panels and Walls, 2019 edition
NFPA 286	Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth, 2019 edition
NFPA 288	Standard Methods of Fire Tests of Horizontal Fire Door Assemblies Installed in Horizontal Fire Resistance-Rated Assemblies, 2017 edition
NFPA 289	Standard Method of Fire Test for Individual Fuel Packages, 2019 edition
NFPA 302	Fire Protection Standard for Pleasure and Commercial Motor Craft, 2020 edition
NFPA 303	Fire Protection Standard for Marinas and Boatyards, 2021 edition
NFPA 307	Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves, 2021 edition
NFPA 312	Standard for Fire Protection of Vessels During Construction, Conversion, Repair, and Lay-Up, 2021 edition
NFPA 318	Standard for the Protection of Semiconductor Fabrication Facilities, 2021 edition - <i>doesn't exist, 2018 or 2022?</i>
NFPA 326	Standard for Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair, 2020 edition
NFPA 385	Standard for Tank Vehicles for Flammable and Combustible Liquids, 2017 edition
NFPA 400	Hazardous Materials Code, 2019 edition

NFPA 407	Standard for Aircraft Fuel Servicing, 2017 edition
NFPA 408	Standard for Aircraft Hand Portable Fire Extinguishers, 2017 edition
NFPA 409	Standard on Aircraft Hangars, 2016 edition
NFPA 410	Standard on Aircraft Maintenance, 2020 edition
NFPA 415	Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways, 2016 edition
NFPA 418	Standard for Heliports, 2016 edition
NFPA 423	Standard for Construction and Protection of Aircraft Engine Test Facilities, 2016 edition
NFPA 484	Standard for Combustible Metals, 2019 edition
NFPA 495	Explosive Materials Code, 2018 edition
NFPA 498	Standard for Safe Havens and Interchange Lots for Vehicles Transporting Explosives, 2018 edition
NFPA 501	Standard on Manufactured Housing, 2017 edition
NFPA 501A	Standard for Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities, 2017 edition
NFPA 502	Standard for Roads Tunnels, Bridges and Other Limited Access Highways, 2020 edition
NFPA 505	Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operations, 2018 edition
NFPA 601	Standard for Security Services in Fire Loss Prevention, 2020 edition
NFPA 652	Standard on the Fundamentals of Combustible Dust, 2019 edition
NFPA 654	Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids, 2020 edition
NFPA 655	Standard for Prevention of Sulfur Fires and Explosions, 2017 edition
NFPA 664	Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities, 2020 edition
NFPA 701	Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2019 edition
NFPA 703	Standard for Fire-Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials, 2021 edition
NFPA 704	Standard System for the Identification of the Hazards of Materials for Emergency Response, 2017 edition
NFPA 720	Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2015 edition
NFPA 750	Standard on Water Mist Fire Protection Systems, 2019 edition
NFPA 780	Standard for the Installation of Lightning Protection Systems, 2020 edition
NFPA 801	Standard for Fire Protection for Facilities Handling Radioactive Materials, 2020 edition
NFPA 804	Standard for Fire Protection for Advanced Light Water Reactor Electric Generating Plants, 2020 edition

NFPA 805	Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants, 2020 edition
NFPA 820	Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2020 edition
NFPA 850	Recommended Practice for Fire Protection for Electric Generating Plants and High Voltage Direct Current Converter Stations, 2020 edition <i>delete</i>
NFPA 853	Standard for the Installation of Fuel Cell Power Systems, 2020 edition <i>g</i>
NFPA 855	Standard for the Installation of Energy Storage Systems, 2020 edition
NFPA 909	Code for the Protection of Cultural Resource Properties – Museums, Libraries, and Places of Worship, 2017 edition
NFPA 914	Code for the Protection of Historic Structures, 2019 edition
NFPA 1122 <i>what edition? 2018?</i>	Code for Model Rocketry. - See the Regulations of Connecticut State Agencies adopted under the authority of section 29-367 of the Connecticut General Statutes, known as the Connecticut Model Rocketry Code.
NFPA 1124	Code for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles, 2006 edition
NFPA 1125	Reference section 29-367 of the Connecticut General Statutes and the Regulations of Connecticut State Agencies adopted pursuant there-to.
NFPA 1126	Standard for the Use of Pyrotechnics Before a Proximate Audience, 2021 edition
NFPA 1127	Reference section 29-367 of the Connecticut General Statutes and the Regulations of Connecticut State Agencies adopted pursuant there-to.
NFPA 1142	Standard on Water Supplies for Suburban and Rural Fire Fighting, 2017 edition
NFPA 1144	Standard for Reducing Structure Ignition Hazards from Wildland Fire, 2018 edition
NFPA 1194	Standard for Recreational Vehicle Parks and Campgrounds, 2021 edition
NFPA 1600	Standard on Continuity, Emergency, and Crisis Management, 2019 edition
NFPA 1963	Standard for Fire Hose Connections, 2019 edition
NFPA 2001	Standard on Clean Agent Fire Extinguishing Systems, 2018 edition
NFPA 2010	Standard for Fixed Aerosol Fire-Extinguishing Systems, 2020 edition
NFPA 2113	Standard on Selection, Care, Use, and Maintenance of Flame-Resistant Garments for Protection of Industrial Personnel Against Short-Duration Thermal Exposure from Fire, 2020 edition
NFPA 5000® <i>what edition?</i>	Building Construction and Safety Code® – Any reference in this code to NFPA 5000 shall mean a reference to the Connecticut State Building Code adopted pursuant to section 29-252 of the Connecticut General Statutes in effect at the time of construction. See the State Building Code. <i>Connecticut</i>

Both the title and edition are missing.

(Amd) **2.3.6 ASME Publications.** American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990 www.asme.org

ASME A13.1, Scheme for the Identification of Piping Systems, 2015 edition
ASME A17.1, Safety Code for Elevators and Escalators, 2013 edition - See the Regulations of Connecticut State Agencies adopted under the authority of section 29-192 of the Connecticut General Statutes, known as the Connecticut Safety Code for Elevators and Escalators
ASME A17.3, Safety Code for Existing Elevators and Escalators, 2013 edition- See the Regulations of Connecticut State Agencies adopted under the authority of section 29-192 of the Connecticut General Statutes, known as the Connecticut Safety Code for Elevators and Escalators.
ASME B31, Code for Pressure Piping, 2012 edition
ANSI/ASME B31.1, Power Piping, 2018 edition
ANSI/ASME B31.3, Process Piping, 2016 edition
ASME Boiler and Pressure Vessel Code, 2021 edition
ASME Code for Unfired Pressure Vessels, 2015 edition

fix font size

(Amd) **2.3.12 ICC Publications.** International Code Council, 500 New Jersey Avenue, NW, 6th Floor, Washington, DC 20001-2070.
 ICC A117.1 *Accessible and Usable Buildings and Facilities.* As adopted by the Connecticut State Building Code adopted pursuant to section 29-252 of the Connecticut General Statutes.

(Add) **2.3.24 Regulations of Connecticut State Agencies.** State of Connecticut - Department of Emergency Services and Public Protection

Connecticut Fireworks and Special Effects Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-357 of the Connecticut General Statutes.
Connecticut Explosives Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-349 of the Connecticut General Statutes.
Connecticut Model Rocketry Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-367 of the Connecticut General Statutes.

(Add) **2.3.25 Regulations of Connecticut State Agencies.** State of Connecticut - Department of Administrative Services

Connecticut State Building Code. Adopted under the authority of section 29-252 of the Connecticut General Statutes.
Connecticut State Fire Safety Code. Adopted under the authority of section 29-292 of the Connecticut General Statutes.

Chapter 3

Definitions

(Amd) **3.3.29* Building.** Any structure used or intended for supporting or sheltering any use or occupancy. For application of this code, each portion of a building which is completely separated from other portions by fire walls which have been designed and constructed in accordance with the Connecticut State Building Code and have been approved by the building official shall be considered separate buildings.

(Amd) **3.3.42 Certificate of Fitness.** A written document issued by the State Fire Marshal or the Commissioner of the Department of Emergency Services and Public Protection to any person for the purpose of granting permission to such person to conduct or engage in any operation or act for which certification is required. Where specified in this code, certificate of fitness shall mean license.

(Amd) **3.3.99 Dwelling Unit.** One or more rooms arranged for the use of one or more individuals living together, providing complete, independent living facilities, including permanent provisions for living, sleeping, eating, cooking and sanitation.

(Amd) **3.3.136 Fireworks.** Any composition or device for the purpose of producing a visible or an audible effect for entertainment purposes by combustion, *deflagration* or *detonation* that meets the definition of 1.3G fireworks or 1.4G fireworks. See also section 29-356 of the Connecticut General Statutes. Sparklers and Fountains. See definition under Sparklers and Fountains.

See
Substantive
Concern.

Fireworks, 1.3G. Large fireworks devices, which are *explosive materials*, intended for use in fireworks displays and designed to produce audible or visible effects by combustion, *deflagration* or *detonation*. Such 1.3G fireworks include, but are not limited to, firecrackers containing more than (130 milligrams) (2 grains) of explosive composition, aerial shells containing more than 40 grams of pyrotechnic composition and other display pieces which exceed the limits for classification as 1.4G fireworks. Such 1.3G fireworks are also identified as Fireworks, UN-0335 pursuant to 49 CFR 172.101.

Fireworks, 1.4G. Small fireworks devices containing restricted amounts of pyrotechnic composition designed primarily to produce visible or audible effects by combustion or *deflagration* which comply with the construction, chemical composition and labeling requirements for Fireworks, UN-0336 pursuant to CFR 172.101 and set forth in 16 CFR Parts 1500 and 1507.

(Add) **3.3.136.2.1 Sparklers and fountains.** The terms "sparklers" and "fountains" have the same meanings as provided in section 29-356 of the Connecticut General Statutes.

(Amd) **3.3.199.5* Business Occupancy.** An occupancy used for the transaction of business other than mercantile. A business occupancy shall also include a training and skill development not in a school or academic program.

(Add) **3.3.199.5.1 In-home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services that employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit shall be classified as a single family dwelling.

(Add) **3.3.199.5.2 Group B College Occupancies.** A building, structure, or portion thereof that is of a Group B Business occupancy classification and associated with a facility of higher

education above the twelfth grade. This definition does not include training or skill development facilities.

remove underline
(Add) **3.3.199.5.3 Group B Medical Occupancies.** Group B medical and dental occupancies that provide services or treatment for four or more patients who may simultaneously be rendered incapable of taking action for self-preservation under emergency conditions. The occupancy shall include, but not be limited to, the following:

- (1) Outpatient clinics with general anesthesia or life-support equipment;
- (2) Dental centers providing treatment under general anesthesia;
- (3) One-day surgical centers;
- (4) Physician's offices providing treatment under general anesthesia.

Facilities such as the above that do not provide general anesthesia or life-support equipment simultaneously to four or more patients shall be classified as Group B Business occupancy.

(Add) **3.3.199.7.1* Self-preservation (day-care occupancy).** The ability of a client to evacuate a day-care occupancy without direct intervention by a staff member. Clients under the age of 3 years shall be considered incapable of self-preservation.

(Amd) **3.3.199.8* Detention and Correctional Occupancy.** An occupancy, other than one whose primary intended use is healthcare, ambulatory health care, or residential board and care, used to lawfully incarcerate or lawfully detain four or more persons under varied degrees of restraint or security where such occupants are mostly incapable of self-preservation because of security measures not under the occupants' control.

(Amd) **3.3.199.9* Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.

(Amd) **3.3.199.10* Educational Occupancy.** An occupancy used for educational purposes through the twelfth grade by six or more persons for four or more hours per day or more than 12 hours per week. Training and skill development not within a school or academic program shall be classified as business occupancies.

(Add) **3.3.199.15.1 In-home Industrial Occupancies, other than High Hazard Industrial Occupancies.** Customary in-home industrial occupancies, located within a single-family dwelling premises, in which processing, assembling, mixing, packaging, finishing, decorating or repair operations are conducted and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling premises, shall be classified as a single-family residential occupancy.

remove underline
(Add) **3.3.199.17.1 Bed and Breakfast or Bed and Breakfast Establishment.** A building:

1. That provides sleeping accommodations to the public for a fee for no more than 16 persons with guest rooms limited to the first or second floor of the structure, *and*
2. Where the owner occupies the facility or an adjacent property as his or her primary place of residence, *and*
3. Where cooking or food warming of any type is not allowed in guest rooms, and

4. That has a maximum of three stories in height and does not contain a mixed occupancy.

— (Amd) **3.3.199.25 One- and Two-Family Dwelling.** One ^{fix size} and two-family dwellings include buildings containing not more than two dwelling units in which each dwelling unit is occupied by members of a single family with not more than six (6) outsiders, if any, accommodated in rented rooms.

— (Amd) **3.3.199.25.1 ~~One- and Two-Family Dwelling Unit.~~** ^{delete} A building that contains not more than two dwelling units, each dwelling unit is occupied by members of a single family with not more than six (6) outsiders, if any, accommodated in rented rooms.

Chapter 4 General Requirements

(Del) **4.3 Compliance Options.** Delete section in its entirety.

(Del) **4.4.1 Multiple Safeguards.** Delete section in its entirety.

(Del) **4.4.2 Appropriateness of Safeguards.** Delete section.

(Del) **4.4.3.1.3** Delete section.

(Del) **4.4.4* Occupant Notification.** Delete section.

(Del) **4.4.5 Vertical Openings.** Delete section.

(Del) **4.5.1.2** Delete section.

(Del) **4.5.2 Historic Structures and Cultural Resource Buildings.** Delete section.

(Del) **4.5.5 Warrant of Fitness.** Delete section in its entirety.

(Amd) **4.5.7.1** Repairs, renovations, alterations, reconstruction, change of occupancy and additions to buildings shall conform to the CSFSC and the CSBC to the extent called for by those codes. See Section 1.3.6.3 of this Code.

(Amd) **4.5.8.1** Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature is required for compliance with the provisions of this code, the CSFSC or the CSBC, such device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or other feature shall thereafter be continuously maintained in accordance with applicable NFPA requirements.

(Del) Chapter 5 Performance-Based Option.

Delete chapter in its entirety.

(Add) **Chapter 5**

Reserved

(Del) **Chapter 6**
Classification of Use/Occupancy

Delete Chapter in its entirety.

Chapter 6
(Add) **Classification of Use/Occupancy**

(Add) **6.1 Classification of occupancy.** The classification of occupancy for a building shall be in accordance with the Connecticut State Fire Safety Code.

Chapter 10

General Safety Requirements

(Amd) **10.1.1** Every new and existing building or structure shall be constructed, arranged equipped, maintained and operated in accordance with the CSBC, CSFSC and this code so as to provide a reasonable level of life safety, property protection and public welfare from the actual and potential hazards created by fire, explosion and other hazardous conditions.

(Amd) **10.1.2*** Every new and existing building shall comply with this code, the CSFSC and the CSBC.

(Amd) **10.1.3 Building Code.** The building code shall mean the Connecticut State Building Code adopted pursuant to section 29-252 of the Connecticut General Statutes.

(Amd) **10.1.4.1** Where structural elements have structural damage, the AHJ shall be permitted to require a technical analysis prepared in accordance with section 1.15 of this code to determine if structural repairs are necessary to restore structural integrity. Where structural elements have visible damage, the building official shall be notified in writing.

(Del) **10.1.4.2** Delete section.

(Amd) **10.2.6** All records required to be kept shall be maintained until their useful life has been served, as required by law.

(Amd) **10.2.7.1** Inspections shall be in accordance with Section 1.7.7 of this code.

(Del) **10.2.7.2** Delete section.

(Del) **10.2.7.3** Delete section.

(Del) **10.2.7.4** Delete section.

(Amd) **10.3.4.1** In any building or structure, whether or not a physical alteration is needed, a change from one use or occupancy classification to another shall be in accordance with the Connecticut State Fire Safety Code and the Connecticut State Building Code.

(Amd) **10.4.1** Persons shall not fail to leave a building when notified to do so in accordance with section 7-313e of the Connecticut General Statutes, as a result of a known or perceived emergency.

(Amd) **10.5.1 Where Required.** Emergency egress and relocation drills conforming to the provisions of this code and the CSFSC shall be conducted as specified by the provisions of Chapter 20 of this code. Drills shall be designed in cooperation with the local authorities and shall consider the needs of the physically challenged.

(Add) **10.5.1.1 Fire Drills. Crisis Response Drills.** Each local and regional board of education shall provide for a fire drill and a crisis response drill to be held in the schools of such board in accordance with section 10-231 of the Connecticut General Statutes.

~~(b) Each such board shall substitute a crisis response drill for a fire drill once every three months and shall develop the format of such crisis response drill in consultation with the appropriate local law enforcement agency. A representative of such agency may supervise and participate in any such crisis response drill.~~

(Del) **10.10.1 Permits.** Delete section in its entirety.

(Del) **10.10.2** Delete section.

(Del) **10.10.3 Outdoor Fires.** Delete section in its entirety.

(Del) **10.10.4 Open Fires.** Delete section in its entirety.

(Del) **10.10.5 Fire Attendants.** Delete section in its entirety.

(Del) **10.10.8 Incinerators and Fireplaces.** Delete section in its entirety.

(Del) **10.10.10 Discontinuance.** Delete section. *remove underline*

(Add) **10.11.1.9 Fire Fighter Safety Building Marking System.** Where required by the AHJ, buildings and structures shall have firefighter safety building marking system signs installed per the criteria in Annex C of this code.

(Del) **10.11.3 Stairway Identification.** Delete section in its entirety.

(Add) **10.11.3.1 Stairway Identification.** Enclosed stairs serving five or more stories shall comply with the CSFSC and the Connecticut State Building Code.

(Del) **10.12 Seasonal and Vacant Buildings and Premises.** Delete section in its entirety and

replace with the following:

(Add) **10.12 Vacant Buildings and Premises.**

(Add) **10.12.1 General.** Temporarily unoccupied buildings, structures, premises or portions thereof, including tenant spaces, shall be safeguarded and maintained in accordance with this section.

(Add) **10.12.1.1 Abandoned Premises.** Buildings, structures and premises for which an owner cannot be identified or located by dispatch of a certificate of mailing to the last known or registered address, and which persistently or repeatedly become unprotected or unsecured; which have been occupied by unauthorized persons or for illegal purposes; or which present a danger of structural collapse or fire spread to adjacent properties shall be considered abandoned, declared unsafe and abated or demolished in accordance with this code.

(Add) **10.12.2 Safeguarding Vacant Premises.** Temporarily unoccupied buildings, structures, premises or portions thereof shall be secured and protected in accordance with this section.

(Add) **10.12.2.1 Security.** Exterior openings and interior openings accessible to other tenants or unauthorized persons shall be boarded, locked, blocked or otherwise protected to prevent entry by unauthorized individuals. The AHJ is authorized to placard, post signs, erect barrier tape or take similar measures as necessary to secure public safety.

(Add) **10.12.2.2 Fire Protection.** Fire alarm, sprinkler and standpipe systems shall be maintained in an operable condition at all times.

Exceptions:

- (1) When the premises have been cleared of all combustible materials and debris and, in the opinion of the AHJ, the type of construction, fire separation distance and security of the premises do not create a fire hazard.
- (2) Where buildings will not be heated and fire protection systems will be exposed to freezing temperatures, fire alarm and sprinkler systems may be placed out of service and standpipes may be maintained as dry systems (without an automatic water supply), provided the building has no contents or storage and windows, doors and other openings are secured to prohibit entry by unauthorized persons.

(Add) **10.12.2.3 Fire Separation.** Fire-resistance-rated partitions, fire barriers and fire walls separating vacant tenant spaces from the remainder of the building shall be maintained.

(Add) **10.12.3 Removal of Combustibles.** Persons owning, occupying or having charge or control of a vacant building or portion thereof, shall remove all accumulations of combustible materials and flammable or combustible waste or rubbish from such space and shall securely lock or otherwise secure doors, windows and other openings to prevent entry by unauthorized persons. Such persons shall maintain the premises clear of waste or hazardous materials.

Exceptions:

- (1) Buildings or portions of buildings undergoing additions, alterations, repairs or change of occupancy under a valid permit in accordance with the CSBC.
- (2) Seasonally occupied buildings.

remove underline

(Add) **10.12.4 Removal of hazardous materials.** Persons owning, or in charge or control of, a vacant building or portion thereof, shall remove all accumulations of hazardous materials as defined by this code.

(Del) **10.13.2 Exterior Vegetation.** Delete section in its entirety.

(Del) **10.14.12.4 Fireworks.** Delete section in its entirety.

(Add) **10.14.13 Fireworks and Special Effects.** The use of display fireworks and special effects shall comply with the regulations adopted pursuant to section 29-357a of the Connecticut General Statutes.

(Del) **10.17 Parade Floats.** Delete section in its entirety.

(Del) **10.20.1.3** Delete section.

Chapter 11 Building Services

(Add) **11.0 General.** In addition to this code, the requirements for building services for the operation of a building shall be in accordance with the Connecticut State Fire Safety Code and the Connecticut State Building Codes. *delete*

(Amd) **11.1.2.3 Abandoned wiring.** Abandoned cables that are able to be accessed without causing damage, or requiring demolition to the building, shall be tagged for future use or removed.

(Amd) **11.2.1 Air-Conditioning, Heating, Ventilating Ductwork, and Related Equipment.** Air-conditioning, heating, ventilating ductwork, and related equipment shall be in accordance with the CSFSC and the CSBC; and NFPA 90A or NFPA 90B as applicable, unless such installations are approved existing installations, which shall be permitted to be continued in service.

(Amd) **11.2.2 Ventilating or Heat-Producing Equipment.** Ventilating or heat-producing equipment shall be in accordance with the CSFSC and the CSBC; and NFPA 31, NFPA 54, NFPA 70®, NFPA 211⁹, NFPA 91, as applicable, unless such installations are approved existing installations, which shall be permitted to be continued in service. *or*

(Del) **11.3 Elevators, Escalators, and Conveyors.** Delete section in its entirety. Note See Chapter 538 of this Code for the requirements for elevators, escalators, and lifts. *↑*

(Amd) **11.4 Utilities** *bold* Equipment using fuel gas and related gas piping shall be in accordance with the CSFSC and the CSBC; and NFPA 54 or NFPA 58 as applicable. (See Chapter 69 for LP-Gas fuel supply and storage installations.) *↓*

(Amd) **11.5.1.1** The installation of stationary liquid fuel-burning appliances, including but not limited to industrial-, commercial-, and residential-type steam, hot water, or warm air heating appliances; domestic-type range burners; space heaters; and portable liquid fuel-burning equipment shall comply with the CSFSC, the CSBC, Section 11.5 of this Code, and NFPA 31, as applicable.

(Add) **11.5.2.4 Statutory requirements.** Refer to sections 29-318, 29-318a, 29-318b, and 29-

General Statutes

- 318c of the Connecticut [^]for space heaters and unvented fuel-burning room heaters.
(Amd) **11.5.4 Vents.** All chimneys, smokestacks, or similar devices for conveying smoke or hot gases to the outer air and the stoves, furnaces, incinerators, boilers, or any other heat-producing devices or appliances shall be installed and maintained in accordance with the CSFSC and ~~SBC~~ ^{CSBC}, and NFPA 54 and NFPA 211 [^]as applicable.
- (Amd) **11.6.1.1** Waste chutes and laundry chutes shall be separately enclosed by walls or partitions in accordance with the CSFSC, the CSBC, and provisions of Section 12.7 of this Code, as applicable.
- (Amd) **11.8.1** Newly installed smoke-control systems shall be inspected by the AHJ and tested in accordance with the criteria established in the design documents approved by the AHJ, the CSFSC and the CSBC.
- (Amd) **11.9 Emergency Command Center.** Where required, emergency command centers shall comply with the CSFSC [^]the ~~SBC~~ ^{CSBC}, and ~~Section 11.9~~ ^{this section} as applicable.
- (Del) **11.10 In-Building Emergency Responder Communication Systems.** Delete section in its entirety.
- (Add) **11.10 In-Building Emergency Responder Communication Systems.**
- (Add) **11.10.1** Where ^{remove dash} installed, two-way radio communication enhancement systems shall be maintained at an operational level in accordance with NFPA 1221.
- (Del) **11.12 Photovoltaic Systems.** Delete section in its entirety.
- (Add) **11.12 Ground Mounted Photovoltaic Systems.**
- (Add) **11.12.1 General.** ^{remove underscore}
- (Add) **11.12.1.1** Ground mounted photovoltaic systems shall be designed and installed in accordance with this section.
- (Add) **11.12.1.2** Electrical portions of ground mounted photovoltaic systems shall be designed and installed in accordance with NFPA 70.
- (Add) **11.12.1.3 Permits.** Permits shall be in accordance with Section 1.12.8 of this Code.
- (Add) **11.12 1.4 Clearances.** A clear area of 10 ft. (3048 mm) around ground-mounted photovoltaic installations shall be maintained.
- (Add) **11.12.1.5 Vegetation Management Plan.** A vegetation management plan or noncombustible base acceptable to the AHJ shall be approved and maintained under and around the installation where required by the AHJ.

Chapter 12

Features of Fire Protection

(Amd) **12.3.1** The design and construction of fire walls and fire barriers that are required to separate buildings or subdivide a building to prevent the spread of fire shall comply with Section 12.3 of this code and the CSFSC.

(Del) **12.3.2* Quality Assurance for Penetrations and Joints.** Delete section in its entirety.

(Amd) **Table 12.6.9.1.1**

Table 12.6.9.1.1 Provisions for Christmas Trees by Occupancy

Occupancy	No Trees Permitted	Cut Tree Permitted With Automatic Sprinkler System	Cut Tree Permitted Without Automatic Sprinkler System	Balled Tree Permitted
Ambulatory health care				X
Apartment buildings		Within Unit	Within Unit	X
Assembly				X
Board and care				X
Business		X		X
Day-care		X		X
Detention and correctional	X			
Dormitories			X**	X
Educational				X
Health care				X
Hotels				X
Industrial		X	X	X
Lodging and rooming		X		X

Mercantile		X		X
Storage		X	X	X

** Cut trees in dwelling units that are associated with supervisory personnel in dormitory occupancies are permitted subject to the approval of the AHJ.

(Add) **12.7.6.2.3.1** Doors having a 20-minute fire protection rating or door assemblies consisting of door frames constructed of at least $\frac{3}{4}$ in. thick hardwood stock and 1 $\frac{3}{4}$ in. thick solid core doors that are self-closing and positive latching may be used in vertical openings and exit enclosures, provided the building has at least partial automatic sprinkler protection in accordance with the CSFSC. These systems shall include (1) either a sprinkler or fire detector opposite the center of and inside any door that opens into the exit of a partial system, and (2) the provisions for occupant notification in accordance with the CSFSC. *remove underline*

(Add) **12.7.6.2.4.1** Existing $\frac{1}{2}$ -hour vertical shafts, other than exits, may be protected by 20-minute fire doors in existing buildings.

(Add) **12.7.6.2.4.1.1** In existing vertical shafts, other than exits, fire window assemblies shall be permitted as follows: *remove underline*

- (1) One-hour walls and partitions with $\frac{3}{4}$ -hour fire window assemblies.
- (2) One-half hour walls and partitions with $\frac{1}{3}$ -hour fire window assemblies.

(Amd) **Table 12.7.6.2.2 Minimum Fire Protection Ratings for Opening Protectives in Fire-Resistance-Rating Assemblies.**

Component	Walls and Partitions (hr.)	Fire Door Assemblies (hr.)	Fire Window Assemblies (hr.)
Elevator hoistway	2	1 $\frac{1}{2}$	NP
	1	1	NP
Vertical shafts (including stairways, exits, and refuse chutes)	2	1 $\frac{1}{2}$	NP
	1	1	NP ($\frac{3}{4}$ in other than exits)
Other than exits	$\frac{1}{2}$	$\frac{1}{3}$	($\frac{1}{3}$ in other than exits)
Fire barriers	2	1 $\frac{1}{2}$	NP
	1	$\frac{3}{4}$	$\frac{3}{4}$
Horizontal exits	2	1 $\frac{1}{2}$	NP
Exit access corridors ¹	1	$\frac{1}{3}$	$\frac{3}{4}$
	$\frac{1}{2}$	$\frac{1}{3}$	$\frac{1}{3}$
Smoke barriers ¹	$\frac{1}{2}$	$\frac{1}{3}$	$\frac{3}{4}$
Smoke partitions ^{1,2}	$\frac{1}{2}$	$\frac{1}{3}$	$\frac{1}{3}$

Note: NP = not permitted.

1. Fire doors are not required to have a hose stream test per NFPA 252.
2. For residential board and care, see the CSFSC.

Chapter 13 Fire Protection Systems

(Add) **13.1.1.2** The requirements for fire protection systems in buildings are specified in the Connecticut State Fire Safety Code.

(Del) **13.1.3 Integrated Fire Protection and Life Safety System Tests.** Delete section in its entirety.

(Amd) **13.1.6** Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and a copy shall also be forwarded to the AHJ either by hard copy or electronic means by the technician performing the testing or maintenance.

(Add) **13.1.9.1 Systems Out of Service.** *delete space* Where a required fire protection system is out of service for more than 4 hours in a 24-hour period, the fire department and the AHJ shall be notified immediately and, where required by the AHJ, the building shall be either evacuated or an approved fire watch shall be provided for all occupants left unprotected by the shutdown until the fire protection system has been returned to service. Where utilized, fire watches shall be provided with not less than one approved means for notification of the fire department and their only duty shall be to perform constant patrols of the protected premises and keep watch for fires.

(Del) **13.1.12*** Delete section.

(Del) **13.2.2 Where Required.** Delete section in its entirety.

(Add) **13.2.2 Where Required.**

(Add) **13.2.2.1** Where required by the CSFSC, the CSBC or the referenced codes or standards listed in Chapter 2, the standpipe system shall be installed in accordance with Section 13.2.1 of this Code.

(Amd) **13.2.3.1** A standpipe system installed in accordance with the CSFSC or this code shall be properly maintained to provide at least the same level of performance and protection as designed.

(Add) **13.2.3.3.1** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Amd) **13.3.1.1** Automatic sprinklers shall be installed and maintained in full operating condition in buildings as required by the CSFSC, the CSBC or in the codes and standards referenced in Chapter 2 of this Code.

(Add) **13.3.1.9.** Buildings provided with standby electrical power for the purpose of continuing operations or occupancy shall provide standby power for any electric fire pump installed to provide an adequate water supply or minimum operating pressure to a required automatic sprinkler system, except that existing installations may be continued in service subject to the approval of the authority having jurisdiction. Standby electrical power in accordance with NFPA 70®, and NFPA 110, Type 60 shall be provided. The standby power system shall have a capacity and rating sufficient to supply all required equipment. Selective load pickup and load shedding shall be permitted in accordance with NFPA 70®.

(Del) **13.3.2 Where Required.** Delete section in its entirety.

(Add) **13.3.2 Where required.**

(Add) **13.3.2.1** Where required by the CSFSC, the CSBC or the referenced codes or standards listed in Chapter 2 of this Code, the automatic sprinkler system shall be installed in accordance with Section 13.3.1.2.

(Add) **13.3.3.2.1 Maintenance of NFPA 13D Systems.**

(Add) **13.3.3.2.1.1** A minimum monthly maintenance program shall include:

- (1) Visually inspecting all sprinklers to ensure against obstruction of spray.
- (2) Inspecting all valves to ensure they are open.
- (3) Checking the pressure of air used with dry systems.
- (4) Checking the water level in storage tanks.

(Add) **13.3.3.2.1.2** A minimum quarterly maintenance program shall include:

- (1) Testing of all water flow alarms.
- (2) Testing of the alarm system.

(Add) **13.3.3.2.1.3** Operated or damaged sprinklers shall be replaced with sprinklers having the same performance characteristics as the original equipment.

(Add) **13.3.3.2.1.4** Any sprinklers that have been painted outside the factory shall be replaced with a new listed sprinkler.

(Amd) **13.3.3.4.3.1*** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Add) **13.4.4.1** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be

included in the report.

(Add) **13.5.4.3** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Amd) **13.6.1.2* Where Required.** Fire extinguishers shall be provided where required by the CSFSC, the CSBC, as specified in Table 13.6.1.2 of this code and the referenced codes and standards listed in Chapter 2 of this code.

Table 13.6.1.2 Portable Fire Extinguishers Required

Occupancy / Use	Where Required After 10/01/2018	Where Required Before 10/01/2018
Ambulatory health care group B medical occupancies	Yes	Yes
Apartment and dormitory group R-2 occupancies ^a	No	No
Assembly group A occupancies ^b	Yes	No
Bed and Breakfast Establishments Group R-1 occupancies ^f	Yes	Yes
Business group B occupancies, including Group B medical, Group B college.	Yes	No
Day-care group I-4 & E occupancies	Yes	No
Detention and correctional group I-3 occupancies ^{c, d}	Yes	Yes
Educational group E occupancies	Yes	No
Health care group I-1 and I-2 occupancies	Yes	Yes
Hotel group R-1 occupancies	Yes	No
Industrial group F occupancies	Yes	No
Industrial group H occupancies	Yes	Yes
Lodging and rooming house group R-1 and R-2 occupancies	Yes	No
Mercantile group M occupancies	Yes ^g	No ^g
One- and two-family dwelling occupancies	No	No
Residential board and care, group R-4 & small I-2 occupancies	Yes	No
Storage group S and H occupancies ^e	Yes	No

remove underline

^a Portable fire extinguishers shall be permitted to be located at exterior locations or interior locations so that all portions of the buildings are within 75 ft. (22.8 m) of travel distance to an extinguishing unit.

^b Portable fire extinguishers are not required in seating or outdoor performance areas.

^c Access to portable fire extinguishers shall be permitted to be locked.

^d Portable fire extinguishers shall be permitted to be located at staff locations only.

^e In storage areas where forklift, powered industrial truck, or cart operators are the primary occupants, fixed extinguishers, as specified in NFPA 10, need not be provided when all of the following requirements are met:

(1) Use of vehicle-mounted extinguishers is approved by the AHJ.

(2) Each vehicle is equipped with a 10 lb., 4A:80-B:C extinguisher affixed to the vehicle using a mounting bracket approved by the extinguisher manufacturer or the AHJ for vehicular use.

(3) Not less than two spare extinguishers of equal or greater rating are available onsite to replace a discharged extinguisher.

(4) Vehicle operators are trained in the proper operation and use of the extinguisher.

(5) Inspections of vehicle-mounted extinguishers are performed daily.

^f Portable fire extinguishers shall be provided in bed and breakfast establishments as required by the CSFSC or this code.

^g New and existing mercantile occupancies selling sparklers and fountains shall have a minimum of (2) dedicated 2-A water fire extinguishers at the location of the sparklers and fountains.

^{two}
(Add) **13.6.1.2.1** Portable fire extinguishers shall be required in all occupancies, outside and immediately adjacent to the entrance to all special hazardous areas except general storage areas. If the only entrance to a special hazardous area is from the exterior of the building, the fire extinguisher may be located just inside the entrance door.

(Add) **13.6.1.2.2** Portable fire extinguishers shall be required where commercial cooking equipment is utilized.

(Amd) **13.7.1.1.1** Where fire alarm systems or automatic fire detectors are required by the CSFSC, the CSBC or the referenced codes or standards listed in Chapter 2 of this Code, they shall be provided and installed in accordance with NFPA 70 and NFPA 72.

(Del) **13.7.1.4** Delete section.

(Add) **13.7.1.4.2.1** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Amd) **13.7.1.8.1** Where required by the CSFSC or the CSBC, single and multiple station smoke alarms shall be installed in accordance with NFPA 72.

(Del) **13.7.1.8.3 Smoke Alarms in Sleeping Rooms.** Delete section in its entirety.

(Del) **13.7.1.8.4.** Delete section.

(Del) **13.7.1.8.5 Specific Location Requirements.** Delete section in its entirety.

(Del) **13.7.1.8.8** Delete section.

(Del) **13.7.1.8.9** Delete section.

(Add) **13.7.1.8.1.1** Unless otherwise provided by the manufacturer's instructions, smoke alarms shall not remain in service longer than 10 years from the date of manufacture. Combination smoke/carbon monoxide alarms shall be replaced when the end-of-life signal activates or 10 years from the date of manufacture, whichever comes first, unless otherwise provided by the manufacturer's instructions.

(Amd) **13.7.1.8.7** Smoke alarms shall receive their operating power as follows:

- (1) In buildings for which a building permit for new occupancy was issued on or after October 1, 1985, smoke alarms shall be powered by both alternating current (AC) and batteries (DC).
- (2) In buildings for which a building permit for new occupancy was issued on or after October 1, 1976, but prior to October 1, 1985, smoke alarms shall be powered by the household electrical service.
- (3) In buildings for which a building permit for new occupancy was issued prior to October 1, 1976, smoke alarms may be battery powered.

(Amd) **13.7.1.8.8*** Where two or more smoke alarms are required within a dwelling unit, suite of rooms, or similar area, they shall be arranged so that operation of any smoke alarm shall cause the alarm of all smoke alarms within the dwelling unit, suite of rooms, or similar area to sound, except when:

- (1) Otherwise permitted by another section of this code.
- (2) Configurations provide equivalent distribution of the alarm signal.
- (3) Installations existed prior to October 16, 1989.

(Add) **13.7.1.9.5.9** When selective occupant notification is utilized in accordance with the CSFSC or this code, the portions of the building that do not receive the initial notification of alarm shall be separated from areas that do receive the initial notification of the alarm by construction having a fire resistance rating of at least 1 hour.

(Add) **13.7.1.9.6.9** In mall buildings, notification within the mall shall be in accordance with the CSFSC.

(Amd) **13.7.1.14 Carbon Monoxide (CO) Detection and Warning Equipment.** Where required by the CSFSC, CSBC, or this code, carbon monoxide (CO) detection and warning equipment shall be provided in accordance with NFPA 72.

(Add) **13.7.1.14.1** Unless otherwise provided by the manufacturer's instructions, carbon monoxide alarms and combination smoke/carbon monoxide alarms shall be replaced when the end-of-life signal activates or 10 years from the date of manufacture, whichever occurs first.

remove underline

(Del) **13.7.1.15* Risk Analysis for Mass Notification Systems.** Delete section in its entirety.

(Del) **13.7.2 Where Required and Occupancy Requirements.** Delete section in its entirety.

(Add) **13.7.3.2.4.6.1** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged

by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Amd) **13.8 Other Fire Protection Systems.** Where other fire protection systems are required to be installed by the provisions the CSFSC, CSBC or this Code, or are installed with the approval of the AHJ as an alternative or equivalency or by a condition of a modification, the design and installation of the system shall comply with the appropriate standards listed in Table 13.8.1 of this Code and the system shall be tested and maintained in accordance with the appropriate national standard. Records and documentation shall be in accordance with Section 13.1.6 of this Code.

**(Del) Chapter 14
Means of Egress**

— (Del) **Chapter 14** Delete Chapter in its entirety.

**(Add) Chapter 14
Means of Egress**

(Add) **14.1 Application.** Means of egress requirements in buildings shall comply with the Connecticut State Fire Safety Code.

**(Del) Chapter 15
Fire Department Service Delivery Concurrent Evaluation.**

— (Del) **Chapter 15** Delete Chapter in its entirety.

**(Del) Chapter 16
Safeguarding Construction, Alteration, and Demolition Operations**

— (Del) **Chapter 16** Delete Chapter in its entirety.

(Add) Chapter 16
Safeguarding Construction, Alteration, and Demolition Operations

(Add) **16.1.1** Structures undergoing construction, alteration or demolition operations including those in underground locations shall comply with the CSFSC.

(Del) Chapter 17
Wildland Urban Interface.

(Del) **Chapter 17** Delete Chapter in its entirety.

Chapter 18
(Amd) Fire Department Access

(Amd) **18.1 General.** Fire department access shall comply with this chapter.

(Del) **18.2.3.4 Traffic Signal Pre-emption.** Delete section.

(Del) **18.3 Water Supplies.** Delete section in its entirety.

(Del) **18.4 Fire Flow Requirements for Buildings.** Delete section in its entirety.

(Del) **18.5.1 Fire Hydrant Locations and Distribution.** Delete section.

(Del) **18.5.1.3** Delete section.

(Del) **18.5.2 Detached One- and Two-Family Dwellings.** Delete section.

(Del) **18.5.3 Buildings Other Detached One- and Two-Family Dwellings.** Delete section.

(Del) **18.5.4 Minimum Number of Fire Hydrants and Fire Flows.** Delete section in its entirety.

Chapter 19
Combustible Waste and Refuse

(Del) **19.1.8 Vehicles or Conveyances Used to Transport Combustible Waste or Refuse.** Delete section in its entirety.

(Amd) **19.2.1.4.1** The requirements of ^{Section of this code} 19.2.1.4 shall not apply to building areas protected by an approved automatic sprinkler system installed throughout in accordance with Section 13.3.1.2.

^{of this code}

Chapter 20 Occupancy Fire Safety

(Amd) **20.1 Assembly Occupancies Including Assembly Groups A-1, A-2, A-3, A-4 and A-5.**

(Amd) **20.1.1 Application.** Assembly Occupancies Including Assembly Groups A-1, A-2, A-3, A-4 and A-5 shall comply with the CSFSC and this section.

(Del) **20.1.3 Interior Finish.** Delete section in its entirety.

(Add) **20.1.3.1 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.1.5.3 Open Flame Devices and Pyrotechnics.** No open flame devices or pyrotechnic devices shall be used in any assembly occupancy, unless otherwise permitted by one of the following:

(1) Pyrotechnic special effect devices shall be permitted to be used on stages before proximate audiences for ceremonial or religious purposes, as part of a demonstration in exhibits, or as part of a performance, provided that both of the following criteria are met:

(a) Precautions satisfactory to the AHJ are taken to prevent ignition of any combustible material.

(b) Use of the pyrotechnic device complies with Section 65.3 of this Code.

(2) Flame effects before an audience shall be permitted in accordance with Section 65.4 and approved by the State Fire Marshal.

(3) Open flame devices shall be permitted to be used in the following situations, provided that precautions satisfactory to the AHJ are taken to prevent ignition of any combustible material or injury to occupants:

(a)* For ceremonial or religious purposes

(b) On stages and platforms where part of a performance

(c) Where candles on tables are securely supported on substantial noncombustible bases and candle flame is protected

(4) The requirement of 20.1.5.3 shall not apply to heat producing equipment complying with 11.2.2 of this Code.

(5) The requirement of 20.1.5.3 shall not apply to food service operations in accordance with 20.1.5.2 of this Code.

(6) Gas lights shall be permitted to be used, provided that precautions are taken, subject to the approval of the AHJ, to prevent ignition of any combustible materials.

(Add) **20.1.5.4.5 Stage Standpipe System.** When the AHJ determines that material, such as scenery, props and temporary fixtures, are present on a stage equipped with hose connections that create an extraordinary fire load, a fire watch equipped with fire hoses attached to the hose outlets on the stage for first aid firefighting shall be provided whenever an audience is present.

(Amd) **20.1.5.5.4.12.2** At least one battery cable shall be removed from the batteries used to start the vehicle engine, and the disconnected battery cable shall then be taped, except where the

manufacturer's instructions indicate that this may cause damage to the vehicles operating systems.

(Amd) **20.1.5.6.1.** Where facilities or events involve a gathering of more than 500 people, crowd managers shall be provided in accordance with Sections 20.1.5.6.2 through 20.1.5.6.4 of this Code.

(Amd) **20.1.5.6.2* Number of crowd managers.** Not fewer than two trained crowd managers, and not fewer than one trained crowd manager for each 250 persons or portion thereof, shall be provided for the gathering.

Exceptions:

- (1) Outdoor events with fewer than 1,000 persons in attendance shall not require crowd managers.
- (2) Assembly occupancies used exclusively for religious worship with an occupant load not exceeding 1,000 shall not require crowd managers.
- (3) The number of crowd managers shall be reduced where, in the opinion of the AHJ, the fire protection provided by the facility and the nature of the event warrant a reduction.

(Amd) **20.1.5.6.3** Duties and responsibilities for the crowd manager and crowd manager supervisor shall be documented within a written emergency plan.

(Add) **20.1.5.6.6** The duties of crowd managers shall include, but not be limited to:

- (1) Conducting an inspection of the area of responsibility ^{and} identify and address any egress barriers.
- (2) Conducting an inspection of the area of responsibility ^{to} identify and mitigate any fire hazards.
- (3) Verifying compliance with all permit conditions, including those governing pyrotechnics and other special effects.
- (4) Directing and assist the event attendees in evacuation during an emergency.
- (5) Assisting emergency response personnel where requested.
- (6) Other duties required by the fire code official.
- (7) Other duties as specified in the fire safety plan.

This term appears to be underlined. See section 104.1 in CSFSC for comparison. Should this be AHJ, like 13.1.9.1 on pg. 33?

(Amd) **20.1.5.8.3*** In the following assembly occupancies, an audible announcement shall be made, or a projected image shall be shown, prior to the start of each program that notifies occupants of the location of the exits to be used in case of a fire or other emergency:

- (1) Theaters.
- (2) Motion picture theaters.
- (3) Auditoriums.
- (4) Other similar assembly occupancies with occupant loads exceeding 100 where there are non-continuous programs.

(Amd) **20.1.5.9.1** The requirements of this section shall apply where smoking is prohibited by the provisions of the Connecticut General Statutes.

(Amd) **20.1.5.13 Fire Alarm Impairments During Performances.** Automatic fire alarm system initiating devices except water flow initiating devices, may be disabled during the performance

remove underline

subject to the approval of the AHJ where the nature and production of a performance requires such action to prevent false activation of the fire alarm system. Such approval shall be limited to the actual performance duration and a written emergency plan approved by the AHJ shall be in place.

(Del) **20.1.5.13 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Amd) **20.2 Educational Occupancies Including Education Group E.**

(Amd) **20.2.1 Application.** Educational Occupancies Including Education Group E shall comply with the CSFSC and this section.

(Add) **20.2.1.1 Permits.** Permits, if required, shall comply with [↗]section 1.12.8 of this Code.

(Del) **20.2.3 Interior Finish.** Delete section in its entirety.

(Add) **20.2.3. Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Add) **20.2.4.2.1.1 Fire Drills. Crisis Response Drills.** Each local and regional board of education shall provide for a fire drill and a crisis response drill to be held in the schools of such board in accordance with section 10-231 of the Connecticut General Statutes.

(Add) **20.2.4.4.4 Security covers.** Only approved security covers shall be permitted to be applied over the vision panels on classroom doors. Approved security covers shall not interfere with the proper operation of the door and its latching mechanism.

(Del) **20.2.4.6. Integrated Fire Protection and Life Safety Systems.** Delete section.

(Add) **20.2.5 Room Locations.**

(Add) **20.2.5.1** Rooms normally occupied by preschool, kindergarten or first-grade students shall be located on a level of exit discharge, unless otherwise permitted by Section 20.2.5.3 of this code.

(Add) **20.2.5.2** Rooms normally occupied by second-grade students shall not be located more than one story above a level of exit discharge, unless otherwise permitted by Section 20.2.5.3 of this code.

(Add) **20.2.5.3** Rooms or areas located on floor levels other than as specified in Sections 20.2.5.1 and 20.2.5.2 of this code may be used provided such rooms or areas have independent means of egress dedicated for use by the preschool, kindergarten, first-grade or second-grade students.

(Amd) **20.3 Day-Care Occupancies Including Those Considered Institutional Group I-4.**

(Amd) **20.3.1 Application.** Day-Care Occupancies Including Those Considered Institutional Group I-4 shall comply with the CSFSC and this section.

(Add) **20.3.1.4.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.3.3.4 Interior Finish.** Delete section in its entirety.

(Add) **20.3.3.4 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.3.4.1.2*** In existing day-care homes, the requirements of the CSFSC, Part IV, section 17.6 shall apply to existing day care homes in which more than 3, but not more than 12, clients receive care, maintenance, and supervision by other than a relative or legal guardian for less than 24 hours per day, generally within a dwelling unit. An existing day-care home shall have the option to meet the requirements of the CSBC in lieu of this code. Any existing day-care home that meets the requirements of the CSBC shall be deemed to have met the requirements of this chapter.

(Del) **20.3.4.1.3** Delete section.

(Del) **20.3.4.2.3.7 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Amd) **20.4 Health Care Occupancies Including Institutional Group I-2.**

(Amd) **20.4.1 Application.** Health Care Occupancies Including Institutional Group I-2 shall comply with the CSFSC and this section.

(Add) **20.4.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Amd) **20.4.2.1.4** The provisions of Sections 10.5, 10.8 and 20.4.2.1.2 to 20.4.2.2.3, inclusive, of this code shall apply.

(Del) **20.4.2.7 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.4.3. Interior Finish.** Delete section in its entirety.

(Add) **20.4.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.5 Residential Board and Care Occupancies Including Residential Group R-4, Institutional Group I-1 and Small I-2 Homes as described in the CSFSC.**

(Amd) **20.5.1 Application.** Residential Board and Care Occupancies Including Residential Group R-4, Institutional Group I-1 and Small I-2 Homes as described in the CSFSC shall comply with the CSFSC and this section.

(Add) **20.5.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this code.

(Amd) **20.5.2.3.6** If a board and care facility has an evacuation capability classification of impractical, those residents who cannot meaningfully assist in their own evacuation or who have special health problems shall not be required to actively participate in the drill.

(Del) **20.5.2.3 Interior Finish.** Delete section in its entirety.

(Add) **20.5.2.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.6 Ambulatory Health Care Centers Including Business Group B Medical Occupancies.**

(Amd) **20.6.1 Application.** Ambulatory Health Care Centers Including Business Group B Medical Occupancies shall comply with the CSFSC and this section.

(Add) **20.6.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.6.2.7 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.6.3 Interior Finish.** Delete section in its entirety.

(Add) **20.6.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.7 Detention and Correctional Occupancies Including Institutional Group I-3.**

(Amd) **20.7.1 Application.** Detention and Correctional Occupancies Including Institutional Group I-3 shall comply with the CSFSC and this section.

(Del) **20.7.2.8 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.7.3 Interior Finish.** Delete section in its entirety.

(Add) **20.7.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.8 Hotels Including Residential Group R-1.**

(Amd) **20.8.1 Application.** Hotels Including Residential Group R-1 shall comply with the CSFSC and this section.

(Add) **20.8.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.8.2.3 Drills in Dormitories.** Delete section.

(Amd) **20.8.2.4.1*** A floor diagram reflecting the actual floor arrangement, exit and escape locations and room identification shall be posted in a location and manner acceptable to the AHJ on, or immediately adjacent to, every guest room door in hotels.

(Del) **20.8.2.7 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.8.3 Interior Finish.** Delete section in its entirety.

(Add) **20.8.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.8.2.4.1*** A floor diagram reflecting the actual floor arrangement, exit and escape locations and room identification shall be posted in a location and manner acceptable to the AHJ on, or immediately adjacent to, every guest room door in hotels.

(Amd) **20.9 Apartment Buildings and Dormitories Including Residential Group R-2.**

(Amd) **20.9.1 Application.** Apartment Buildings and Dormitories Including Residential Group R-2 shall comply with the CSFSC and this section.

(Add) **20.9.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this code.

(Add) **20.9.2.1.1 Drills in Dormitories.** Emergency egress and relocation drills shall be regularly conducted in accordance with the CSFSC and Section 10.5 of this code.

(Add) **20.9.2.1.2* Floor Diagram** A floor diagram reflecting the actual floor arrangement, exit and escape locations and room identification shall be posted in a location and manner acceptable to the AHJ on, or immediately adjacent to, every door in every resident room in dormitories.

(Add) **20.9.2.1.3 Emergency Action Plans** Dormitories shall have an emergency action plan in accordance with Section 10.8 of this Code.

(Del) **20.9.2.4 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.9.3 Interior Finish.** Delete section in its entirety.

(Add) **20.9.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.10 Lodging or Rooming Houses and Bed and Breakfast R-1.**

(Amd) **20.10.1 Application.** Lodging or Rooming Houses and Bed and Breakfast Group R-1 shall comply with the CSFSC and this section.

(Add) **20.10.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this code.

(Del) **20.10.3 Interior Finish.** Delete section in its entirety.

(Add) **20.10.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Add) **20.10.5 Emergency Instructions for Residents or Guests.** A floor diagram reflecting the actual floor arrangement, exit and escape locations, and room identification shall be posted in a location and manner acceptable to the AHJ on, or immediately adjacent to, every resident room door.

(Del) **20.11 One- and Two-Family Dwellings and Manufacturing Housing.** Delete section in its entirety.

(Amd) **20.12 Mercantile Occupancies Including Mercantile Group M.**

(Amd) **20.12.1 Application.** Apartment Buildings and Dormitories Including Residential Group R-2 shall comply with the CSFSC and this section.

(Add) **20.12.1.1 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.12.2.6 Integrated Fire Protection and Life Safety Systems.** Delete section.

remove underline

(Del) **20.12.3 Interior Finish.** Delete section in its entirety.

(Add) **20.12.3 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Add) **20.12.4 Covered Mall Buildings.** Covered mall buildings shall comply with the provisions of Sections 20.12.4.1 to 20.12.4.5, inclusive, of this code.

(Add) **20.12.4.1 Lease Plan.** A lease plan shall be prepared for each covered mall building and shall include the following information:

- (1) Each occupancy, including tenant identification.
- (2) Exits from each tenant space.
- (3) Fire protection features, including the following:
 - (A) Fire department connections.
 - (B) Fire command center.
 - (C) Smoke management system controls.
 - (D) Elevators and elevator controls.
 - (E) Hose valves outlets.
 - (F) Sprinkler and standpipe control valves.
 - (G) Automatic fire-extinguishing system areas.
 - (H) Automatic fire detector zones.
 - (I) Fire barriers.

(Add) **20.12.4.2 Approval.** The lease plan shall be submitted to the AHJ for approval and shall be maintained on site for immediate reference by responding fire service personnel.

(Add) **20.12.4.3 Revisions.** The lease plan shall be revised annually or as often as necessary to keep it current.

(Add) **20.12.4.4 Tenant Identification.** Each occupied tenant space, except anchor stores, provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and contrast with their background.

(Add) **20.12.4.5 Maintenance.** Vacant tenant spaces shall be:

- (1) Kept free from the storage of any materials.
- (2) Separated from the remainder of the building by partitions of at least 0.5 inch (12.7 mm) gypsum board or an approved equivalent to the underside of the ceiling of the adjoining tenant spaces.
- (3) Without doors or other access openings other than one door that shall be kept key locked in the closed position except during that time when opened for inspection.
- (4) Kept free from combustible waste and be broom-swept clean.

(Add) **20.12.5 Storage and Display of Fireworks, Sparklers and Fountains.** The display and storage of consumer fireworks at retail establishments shall be in accordance with the provisions of the 2006 edition of NFPA 1124, except as modified in Sections 20.12.5.1 to 20.12.5.3, inclusive, of this code.

(Add) **20.12.5.1** Fireworks, sparklers and fountains shall be under the visual supervision of a store employee or other responsible party while the store is open to the public.

(Add) **20.12.5.2** Fireworks, sparklers and fountains shall not be displayed or stored within 5 feet (1.5 m) of any entrance or exit of any enclosed building or structure.

(Add) **20.12.5.3** The provisions of NFPA 1124, 2006 edition, are amended for use in Connecticut as follows:

(Amd) NFPA 1124, **7.3.7 Storage Rooms**. Storage rooms containing consumer fireworks, sparklers, or fountains regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, or separated from the retail sales area by a fire barrier having a fire resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, separated by a minimum of 4 ft. (1.3 m) of clear space.

(Amd) NFPA 1124, **7.5.3 Storage Rooms**. Storage rooms containing consumer *fireworks*, regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13; or separated from the retail sales area by a *fire barrier* having a *fire-resistance* rating of not less than 1 hour. The quantity of *fireworks* permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, separated by a minimum of 4 ft. (1.3 m) of clear space.

(Amd) **20.13 Business Occupancies Including Business Group B.**

(Amd) **20.13.1 Application**. Business Occupancies Including Business Group B shall comply with the CSFSC and this section.

(Add) **20.13.1.1 Permits**. Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.13.2.5 Integrated Fire Protection and Life Safety Systems**. Delete section.

(Del) **20.13.3 Interior Finish**. Delete section in its entirety.

(Add) **20.13.3 Interior Finish**. Interior finish shall be in accordance with the CSFSC.

(Amd) **20.14 Industrial Occupancies Including Factory Industrial Groups F-1 and F-2.**

(Amd) **20.14.1 Application**. Industrial Occupancies Including Factory Industrial Groups F-1 and F-2 shall comply with the CSFSC and this section.

(Add) **20.14.2 Permits**. Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.14.3.5 Integrated Fire Protection and Life Safety Systems**. Delete section.

(Del) **20.14.4 Interior Finish**. Delete section in its entirety.

(Add) **20.14.4 Interior Finish**. Interior finish shall be in accordance with the CSFSC.

(Add) **20.14.5 Group H-5 Occupancies**. Group H-5 occupancies shall comply with the requirements of Sections 20.14.5.1 to 20.14.5.4, inclusive, of this code and the CSFSC.

(Add) **20.14.5.1 Plans and Diagrams**. Plans and diagrams shall be maintained in approved locations indicating the approximate plan for each area, the amount and type of hazardous

production materials (HPM) stored, handled and used, locations of shutoff valves for HPM supply piping, emergency telephone locations and locations of exits.

(Add) **20.14.5.2 Plan Updating.** The plans and diagrams required by section 20.14.5.1 of this code shall be maintained up-to-date, the AHJ and fire department shall be informed of all major changes.

(Add) **20.14.5.3 Emergency Response Team.** Responsible persons shall be designated as the on-site emergency response team and trained to be liaison personnel for the fire department. These persons shall aid the fire department in preplanning emergency responses, identifying locations where HPM is stored, handled and used, and be familiar with the chemical nature of such material. As determined by the AHJ, an adequate number of personnel for each work shift shall be designated.

(Add) **20.14.5.4 Emergency Drills.** Each on-site emergency response team shall conduct emergency drills on a regular basis, but not less than once every three months, and maintain records of drills conducted.

(Amd) **20.15 Storage Occupancies Including Storage Groups S-1 and S-2.**

(Amd) **20.15.1 Application.** Storage Occupancies Including Storage Groups S-1 and S-2 shall comply with the CSFSC and this section.

(Add) **20.15.2 Permits.** Permits, if required, shall comply with Section 1.12.8 of this Code.

(Del) **20.15.3.2 Integrated Fire Protection and Life Safety Systems.** Delete section.

(Del) **20.15.4 Interior Finish.** Delete section in its entirety.

(Add) **20.15.4 Interior Finish.** Interior finish shall be in accordance with the CSFSC.

(Amd) **20.16.1 Application.** Special structures and high rise buildings shall comply with the CSFSC and this section.

(Del) **20.17 Historical Buildings and Cultural Resources.** Delete section in its entirety.

Chapter 21

Airports and Heliports

(Amd) **21.2.4.1** Airport terminal buildings shall be constructed in accordance with the CSBC and the CSFSC in effect at the time of application for a building permit.

remove underline

Chapter 22

Automobile Wrecking Yards

(Amd) **22.8 Burning Operations.** Burning operations shall be in accordance with Regulations of Connecticut State Agencies adopted by the Department of Energy and Environmental Protection

pursuant to Title 22a of the Connecticut General Statutes.

Chapter 25

(Amd) **Grandstands and Bleachers, Folding and Telescopic Seating, and Membrane Structures**

(Amd) **25.1.1** The location, protection, and maintenance of grandstands and bleachers, folding and telescopic seating, and membrane structures shall meet the requirements of the CSFSC and this chapter. Seating facilities located in the open air or within enclosed or semi-enclosed structures, such as tents, membrane structures and stadium complexes, shall comply with the CSFSC and this chapter.

(Del) **25.1.3 Means of Egress.** Delete section in its entirety.

(Add) **25.1.3 Means of Egress.** Means of egress shall be in accordance with the CSFSC.

(Del) **25.1.6 Extinguishing Requirements.** Delete section in its entirety.

(Add) **25.1.6 Extinguishing Requirements.** Means of egress shall be in accordance with the CSFSC.

(Amd) **25.1.7 Detection, Alarm, and Communication Systems.** Detection, Alarm, and Communication Systems shall comply with the CSFSC.

(Del) **25.2 Tents.** Delete section in its entirety.

(Amd) **25.5.1.1 Use of Membrane Roofs.** Membrane roofs shall be used in accordance with the following:

- (1) Membrane materials shall not be used where fire resistance ratings are required for walls or roofs.
- (2) Where every part of the roof, including the roof membrane, is not less than 240 inches (6100 mm) above any floor, balcony, or gallery, a noncombustible membrane shall be permitted to be used as the roof in any type of construction as permitted by the CSBC.
- (3) With approval of the AHJ, membrane materials shall be permitted to be used where every part of the roof membrane is sufficiently above every significant fire potential such that the imposed temperature cannot exceed the capability of the membrane, including seams, to maintain its structural integrity.

(Add) **25.5.3.1.1** The requirements of Section 25.5.3 of this code do not apply to air-supported and air-inflated structures as defined in the Connecticut Mechanical Amusement Ride and Device Regulations, adopted pursuant to section 29-136 of the Connecticut General Statutes.

(Del) **25.6.4.3** Delete section.

(Del) **25.6.4.4** Delete section.

(Del) Chapter 27

Manufactured Home and Recreational Vehicle Sites.

(Del) **Chapter 27** Delete Chapter in its entirety.

Chapter 28 Marinas, Boatyards, Marine Terminals,

(Amd) **28.1.1 Scope.** The operation of marinas, boatyards, yacht clubs, boat condominiums, docking facilities associated with residential condominiums, multiple-docking facilities at multiple-family residences, and all associated piers, docks and floats shall comply with NFPA 303, and Section 28.1 of this code.

delete

Chapter 32

Motion Picture and Television Production Studio Soundstages and Approved Production Facilities

(Amd) **32.1 General.** The design, construction, operation, and maintenance of soundstages and approved production facilities used in motion picture and television productions shall comply with the CSFSC, CSBC, NFPA 140 and this chapter.

(Del) **32.5 Smoking.** Delete section.

(Amd) **32.6 Pyrotechnic Special Effects, Open Flames, and Smoking.**

(Amd) **32.6.1** The use of pyrotechnic special effects, open flames, or smoking shall be subject to the approval of the provisions of Chapter 65 of this code.

(Amd) **32.6.2** The use of flame effect materials, devices or components governed by NFPA 140 or NFPA 160; the device(s), their arrangement, location(s), and fuel(s) shall be approved by the State Fire Marshal.

(Del) **32.6.3** Delete section.

(Amd) **32.9.3.1** Means of egress shall be in accordance with the CSFSC unless otherwise modified by 32.9.3.2 through 32.9.3.6.

Chapter 34 General Storage

(Del) **34.6.6 Security Service.** Delete section.

(Del) **34.9 Protection of Rubber Tires.** Delete section in its entirety.

(Del) **34.10 Protection of Roll Paper.** Delete section in its entirety.

(Del) **Chapter 35**
Animal Housing Facilities

(Del) **Chapter 35** Delete Chapter in its entirety.

Chapter 40
Dust Explosion and Fire Prevention

(Del) **40.14* Incident Investigation.** Delete section in its entirety.

Chapter 42
Refueling

(Amd) **42.5.3.4** Dispensing devices shall be mounted on a concrete island and shall be protected against collision damage with guard posts in accordance with the following:

- 1) They shall be constructed of steel not less than 4 inches in diameter and shall be filled with concrete.
- 2) They shall be set not less than 3 feet deep in a concrete footing of not less than 15 inches in diameter.
- 3) Guard posts shall be installed at each end of the island.

(Add) **42.10.1.2 Permits.** Permits, where required, shall comply with Section 1.12 of this Code.

(Del) **42.12 On-Demand Mobil Fueling.** Delete section in its entirety.

(Add) **42.12 On-Demand Mobil Fueling.** On-Demand Mobil Fueling is prohibited.

Chapter 45
Combustible Fibers

(Del) **45.2.2** Delete section.

(Del) **45.7 Storage of Hay, Straw, and Other Similar Agricultural Products.** Delete section in its entirety.

Chapter 50 Commercial Cooking Equipment

(Amd) **50.1.1*** The operation, inspection and maintenance of all public and private commercial cooking equipment and mobile and temporary cooking operations shall comply with this chapter and NFPA 96. This chapter shall not apply to Type II kitchen exhaust hoods as defined by the 2018 *International Mechanical Code*[®] portion of the Connecticut State Building Code.

(Add) **50.1.6 Isolated cooking Operations.** The requirements for the hood, grease removal devices, duct and fixed fire extinguishing system may be waived by the authority having jurisdiction for cooking operations in free standing tents, mobile units or other small buildings located greater than 30 feet (9.2 m) from grandstands or other public buildings and occupied by employees only, when the clearance to combustibles, safety controls, portable fire extinguishers, staff training, fuel use, storage, and shut off of fuel, and electrical shut off for equipment are in compliance with this code.

(Amd) **50.6.1.6.1** Where the fire-extinguishing system or exhaust system is nonoperational or impaired, the systems shall be tagged as non-compliant, and the system owner or owners' representative shall be notified in writing of the impairment; additionally, the AHJ shall be notified either by hard copy or electronically by the person tagging the system.

(Amd) **50.6.2.8.1** Records including certificates of inspection and maintenance shall be forwarded to the AHJ either by hard copy or electronically by the person performing the inspection or maintenance.

(Amd) **50.6.6.15** Certificates of inspection and cleaning and reports of areas not cleaned shall be submitted to the AHJ either by hard copy or electronically by the person performing the inspection or cleaning.

(Amd) **50.8.1.2 Permits.** Permits, if required, shall comply with Section 1.12 of this code for the location and operation of mobile and temporary cooking operations.

(Amd) **50.8.2.1 Separation.** Mobile or temporary cooking operations shall be separated from buildings or structures, combustible materials, vehicles, and other cooking operations by a minimum of 10 feet or as approved by the AHJ.

(Del) **50.8.2.2** Delete section.

(Amd) **50.8.3.1** Tents shall comply with the CSFSC and the CSBC.

Chapter 52 Energy Storage Systems

(Del) **52.9** Delete Section.

Chapter 55 Cleaning and Purging of Flammable Gas Piping Systems

(Add) **55.1.1** Coverage of fuel gas piping systems shall extend from the point of delivery or source valve to the gas-consuming equipment isolation valve.

**(Del) Chapter 56
Reserved**

Delete Chapter

**(Add) Chapter 56
Fire Protection for Electric Generating Plants and High Voltage Direct Current
Converter Stations**

(Add) **56.1** Application.

(Add) **56.1.1** The construction, fire prevention and fire protection for electric generating plants and high voltage direct current converter stations shall comply with NFPA 850.

**(Del) Chapter 57
Reserved**

Delete Chapter

**(Add) Chapter 57
Gas Equipment and Piping**

(Add) **57.1** General Provisions.

(Add) **57.1.1** Application.

(Add) **57.1.1.1** The installation of fuel gas piping systems, fuel gas utilization equipment, and related accessories shall comply with the requirements of this chapter, the CSFSC, CSBC and NFPA 54.

(Add) **57.1.1.2** Fuel gases include natural gas, manufactured gas, liquefied petroleum gas in the vapor phase only, liquefied petroleum gas-air mixtures, and mixtures of these gases, plus gas-air mixtures within the flammable range with the fuel gas or the flammable component of a mixture being commercially distributed product.

**Chapter 60
Hazardous Materials**

(Amd) **60.1.1 Applicability.** Occupancies containing high hazard contents shall comply with this chapter in addition to other applicable requirements of this code and applicable requirements of NFPA 400.

(Add) **60.1.7 Manufacturing Establishments.** Manufacturing facilities, as defined in section 29-307a of the Connecticut General Statutes, shall comply with the reporting requirements,

(Amd) Chapter 65
Explosives, Fireworks, Model Rocketry; including
Sparklers, Fountains and Flame Effects Before a Proximate Audience

(Amd) **65.1.1** The storage, use, and handling of explosives, fireworks, and model rockets shall be in accordance with the requirements of this chapter and the applicable provisions of sections 29-343 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

(Del) **65.1.2** Delete section.

(Amd) **65.2.1** The construction, handling, and use of fireworks intended solely for the outdoor display as well as the general conduct and operation of the display shall comply with the requirements of the applicable provisions of sections 29-356 to 29-366, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

(Amd) **65.2.2** All storage of display fireworks shall comply with the applicable provisions of sections 29-356 to 29-366, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

(Del) **65.2.3 Permits.** Delete Section.

(Amd) **65.3.1** The use of pyrotechnic special effects in the performing arts in conjunction with theatrical, musical, or any similar productions before a proximate audience, performers, or support personnel shall comply with the applicable provisions of sections 29-356 to 29-366, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

(Amd) **65.3.2** Where any of the following conditions exist, they shall comply with the applicable provisions of sections 29-343 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

- (1) Any indoor display of pyrotechnic special effects.
- (2) Any outdoor use of pyrotechnic special effects at distances less than those required for outdoor effects as prescribed by the applicable provisions of Connecticut General Statutes, and the applicable codes adopted pursuant thereto.
- (3) The use of pyrotechnics special effects during any videotaping, audiotaping, digital recording, or filming of any television, radio, or movie production, if such production is before a proximate audience.

(4) The rehearsal of any production in which pyrotechnic special effects are used.

(Del) **65.3.3 Permits.** Delete section.

(Amd) **65.4.1** The use of flame effects or devices used in conjunction with theatrical performances, athletic or sporting events or flame effects before an audience shall comply with NFPA 140, NFPA 160 and the applicable provisions of sections 29-343 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable codes adopted pursuant thereto.

remove underline

(Del) **65.4.2 Permits.** Delete section.

(Add) **65.4.3** The use of flame effect materials, devices or components governed by NFPA 140 or NFPA 160; the device(s), their arrangement, location(s), and fuel(s) shall be approved by the State Fire Marshal.

(Add) **65.4.4** When LP-Gas is used as the fuel source for flame effects before a proximate audience, and where a separation distance of 20 feet (6.1 meters) is not practical, reduction of distances shall be permitted with the approval of the State Fire Marshal.

(Add) **65.4.5** Each flame effect device fired during a performance shall be separated from the audience by a minimum of 15 feet, except:

- 1) Where specified at a greater distance by the manufacturer.
- 2) As approved by the State Fire Marshal.

(Del) **65.5 Fireworks Manufacturing.** Delete section in its entirety.

(Amd) **65.6 Model Rocketry.** The design, construction, limitations of propellant mass and power, and reliability of model rocket motors and model rocket model reloading kits and their components produced commercially for sale to or use by the public for purposes of education, recreation, and sporting competitions shall comply with the applicable provisions of sections 29-367 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable codes and regulations adopted pursuant thereto.

remove underline

(Amd) **65.7.1** The manufacture of model rocket motors designed, sold, and used for the purpose of propelling recoverable aero models shall comply with the applicable provisions of sections 29-367 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable code and regulations adopted pursuant thereto.

(Amd) **65.8.1** The design, construction, limitations of propellant mass and power, and reliability of all high-power rocket motors and motor components produced commercially for sale to or use by certified users for education, recreation, and sporting competitions shall comply with the applicable provisions of sections 29-367 to 29-370, inclusive, of the Connecticut General Statutes, and the applicable codes and regulations adopted pursuant thereto.

(Amd) **65.9.1** The manufacture, transportation, storage, sale and use of explosive material shall comply with the requirements of the applicable provisions of sections 29-343 to 29-355a, inclusive, of the Connecticut General Statutes, and the applicable codes and regulations adopted pursuant thereto.

(Del) **65.9.2 Permits.** Delete section in its entirety.

(Add) **65.10 Sale, Handling, and Storage of Sparklers and Fountains.**

(Add) **65.10.1 General Requirements.** Retail sales of sparklers and fountains shall comply with the requirements of this chapter and the requirements for consumer fireworks in NFPA 1124, 2006 edition, as amended by Sections 20.12.5.1 to 20.12.5.3, inclusive, of this code.

(Add) **65.10.1.1** The provisions of NFPA 1124, 2006 edition, are amended for use in Connecticut as follows:

(Amd) NFPA 1124, **7.3.7 Storage Rooms.** Storage rooms containing consumer fireworks, sparklers, or fountains regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, or separated from the retail sales area by a fire barrier having a fire resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, separated by a minimum of 4 feet (1.3 m) of clear space.

(Amd) NFPA 1124, **7.5.3 Storage Rooms.** Storage rooms containing consumer fireworks, sparklers or fountains regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, or separated from the retail sales area by a fire barrier having a fire-resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, separated by a minimum of 4 feet (1.3 m) of clear space.

(Add) **65.10.1.2 Permits.** Permits, if required, shall comply with Section 1.12.6 of this code.

(Add) **65.10.1.3** Retail sales of sparklers and fountains shall be limited to mercantile occupancies as defined in Section 3.3.192.19 of this code.

(Add) **65.10.2 Storage and Display of Sparklers and Fountains.**

(Add) **65.10.2.1** Sparklers and fountains shall be under the visual supervision of a store employee or other responsible party while the store is open to the public.

(Add) **65.10.2.2** Sparklers and fountains shall not be displayed or stored within 5 feet (1.5 m) of any entrance or exit of any enclosed building or structure.

(Add) **65.10.2.3** The total quantity of sparklers and fountains on hand either displayed or in storage shall not exceed 227.2 lb. (gross) [103 kg (gross)], including packaging, or 1,000 lb. (gross) [454 kg (gross)] in a building protected throughout with an approved automatic sprinkler system installed in accordance with NFPA 13. A quantity in excess of these amounts is subject to approval by the State Fire Marshal.

(Add) **65.10.2.3.1** Where the actual weight of the pyrotechnic composition of sparklers and

fountains is not known, 25 percent of the gross weight of the product, including packaging, shall be permitted to be used to determine the weight of the pyrotechnic composition.

(Add) **65.10.3 Consumer Fireworks.** The retail sale of consumer fireworks except those meeting the definition of sparklers and fountains is prohibited.

(Add) **65.10.3.1 Noncomplying Fireworks.** The retail sales of fireworks that do not comply with the regulations of the U.S. Consumer Product Safety Commission as set forth in 16 CFR Parts 1500 and 1507, the regulations of the U.S. Department of Transportation as set forth in 49 CFR Parts 100 to 178, inclusive, and section 29-357 of the Connecticut General Statutes, including their related storage and display for sale, shall be prohibited.

Chapter 69 Liquefied Petroleum Gas and Liquefied Natural Gases

(Add) **69.1.3 Written Emergency Plan.** A written emergency response plan is required for industrial plants, bulk plants, and dispensing stations. The facility emergency response plan, when required, shall be in writing and amended as required but at least every two years. Written documentation of the current emergency response plan shall be maintained at the facility and shall be provided upon written request to the local fire marshal and emergency response agencies. The fire safety analysis and special fire protection provisions referred to in section 6.29 of NFPA 58, shall be incorporated into the emergency plan as appropriate. *remove underline*

(Add) **69.2.1.4.1.3 LP-Gas** fuel suppliers shall affix and maintain in a legible condition, their firm name(s) and emergency telephone number(s) in a readily visible location on or near LP-Gas supplier-owned Department of Transportation (DOT) and American Society of Mechanical Engineers (ASME) containers installed on a consumer's premises.

(Add) **69.2.1.4.1.3.1** The firm name(s) and emergency telephone number(s) on the containers shall be at least one half (1/2) inch high and of contrasting color to the container.

(Add) **69.2.1.4.1.3.2** The emergency telephone number(s) shall be staffed 24 hours a day to ensure that the LP-Gas supplier is available in the event of an emergency at the consumer's premises.

(Add) **69.4.1.3** Cylinders, tanks or containers shall be filled, evacuated or transported only by the owner of the cylinder, tank or container or upon the owner's authorization.

Chapter 74 Ammonium Nitrate

(Amd) **74.1.2** The storage of ammonium nitrate in the form of crystals, flakes, grains, or prills including fertilizer grade, dynamite grade, nitrous oxide grade, technical grade and other mixtures containing 60 percent or more by weight of ammonium nitrate shall comply with the Connecticut Explosives Code adopted pursuant to section 29-349 of the Connecticut General Statutes and

NFPA 400.

**Annex A
Explanatory Material**

This Annex is recognized as explanatory material for the body of the Code as applicable.

**Annex B
Sample Ordinance Adopting the NFPA 1, Fire Code**

This Annex is not adopted by the state of Connecticut.

**Annex C
Fire Fighter Building Marking Systems**

This Annex is adopted by the state of Connecticut.

**Annex D
Fire Fighter Breathing-Air Replenishment Systems**

This Annex is not adopted by the state of Connecticut.

**Annex E
Fire Sprinkler Disclosure Statement for One- and Two-Family Dwellings**

This Annex is not adopted by the state of Connecticut.

**Annex F
Informational References**

This Annex is adopted by the state of Connecticut.