

2022 Connecticut State Fire Safety Code

Summary of changes in response to the August 30, 2022, Legislative Commissioners' Office memorandum.

Substantive Concerns:

Concerns 1 to 3 have been addressed.

Concern #4—No changes were made.

This code, the Connecticut State Fire Safety Code, regulates processes and activities that are a part of the building or structure. The language in the code that points the user to the Connecticut State Fire Prevention Code refers to processes and activities that do not support the structure. In other words, the Fire Prevention Code regulates peoples' activities within the building (that could move to another building), while the Fire Safety Code regulates the building itself.

Additional Comments:

Technical Corrections and Seek Clarification Changes were made as indicated except in the following instances (or clarifications are provided):

On page 15, Section 104.6, "and Replace with ..." was not inserted, because we are deleting all subsections of 104.6 and just adding one section back.

On page 22, the definition for "APPROVED AGENCY" is from the International Building Code and is intended to stay consistent with that code for continuity between this code and the Connecticut State Building Code. Connecticut amends the definition to include Connecticut-specific statutory requirements. As background, here is the model code definition and the model code commentary:

[A] APPROVED AGENCY. An established and recognized agency that is regularly engaged in conducting tests, furnishing inspection services or furnishing product certification where such agency has been *approved* by the *building official*.

❖ Third-party testing or inspections may be needed for elements within the built environment. The basis for the building official's approval of any agency for a particular activity may include, but is not limited to, the capacity and capability of the agency to perform the work in accordance with Section 1705 and other applicable sections. This is typically done through a review of the résumés and references of the agency and its personnel. This definition also recognizes that agencies are generally approved through a nationally recognized accreditation body for testing, inspections or product certification. For this code, the building official is identified as the person responsible for approval.

On page 33, Section 403.9.3.1.1, this fire safety plan is different from the approved fire safety and evacuation plan in Section 404 in that this is part of the overall fire safety and evacuation plan for a

particular occupancy group. This requirement is the same for at least one other occupancy group, as well.

On page 35, Section 503.1.1, the language “or moved into or within the jurisdiction” is model code language that also appears elsewhere in the underlying model code (example Section 507). The Connecticut amendment adds the requirement to comply with Appendix D.

On page 54, Section 1005.3.2, “(mm)” was not deleted as that was from the model code (see Section 1005.3.1 for similar language).

On page 56, in #7, “exception concerning” was not inserted as this is not in the model code language.

On page 57, Section 1013.2, R-1 bed and breakfast establishments do not need to comply with this section specific to low-level exit signs.

On page 70, the language was changed to Chapters 13 through 19 as the underlying model code reserves chapters 13 through 19, which Connecticut maintains in its amendment.

2022

CONNECTICUT STATE FIRE SAFETY CODE.

CONNECTICUT STATE FIRE SAFETY CODE

Part I—Administrative

Sec. 100 Title and applicability.

Sec. 100.1 The Connecticut State Fire Safety Code and the adopted standards, as amended, shall be known as the Connecticut State Fire Safety Code, hereinafter referred to as “the code” or “this code”.

Sec. 100.2 If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

Sec. 100.3 In the event any part or provision of this code is held to be illegal or void, this shall not have the effect of making void or illegal any of the other parts or provisions of this code that are determined to be legal, and it shall be presumed that this code would have been adopted without such illegal or void parts or provisions.

Sec. 100.4 Nothing in this code shall be construed to prohibit a better type of building construction, an additional means of egress, or an otherwise safer condition than that specified by the minimum requirements of this code.

Sec. 100.5 The provisions of the code shall only apply to detached private dwellings occupied by one or two families and townhouses with respect to smoke alarms and carbon monoxide detectors as specified in the Connecticut State Building Code and subject to the specific inspection criteria for smoke detection and warning equipment of section 29-305 of the Connecticut General Statutes.

Sec. 100.6 Buildings designed, constructed and occupied in accordance with the provisions of the 2015 International Residential Code portion of the Connecticut State Building Code, including tents and membrane structures, shall be deemed single-family dwellings for the application of this code and section 29-305 of the Connecticut General Statutes.

Sec. 100.7 The Connecticut State Fire Safety Code shall not apply to portable grandstands or bleachers providing seating for fewer than 100 persons located outside of a building.

Sec. 100.8 The Connecticut State Fire Safety Code shall not apply to any federal agency performing construction or operating on federally owned land or on leased land totally under the control of the federal government.

Sec. 100.9 Public service companies. This code shall not apply to the installation, alteration or repair of generation, transmission, distribution, metering or other related equipment that is under the ownership or control of a public service company as defined in section 16-1 of the Connecticut

General Statutes.

Sec. 100.10 The Connecticut State Fire Safety Code shall be administered as provided in chapter 541 of the Connecticut General Statutes.

Sec. 102 Adopted standard.

Sec. 102.1 Part III – New construction, renovation, or change of use and new buildings. For those for which a permit was issued on or after January 1, 2006. The following standard is hereby adopted as amended in this code as Part III of the Connecticut State Fire Safety Code:

International Fire Code[®] of the International Code Council, Inc., 2021 edition, except as amended, altered or deleted and by the addition of certain provisions as indicated in this code.

The *International Fire Code*[®] is available from the International Code Council, Inc., 4051 W. Flossmoor Road, Country Club Hills, IL 60478-5795; 1-888-422-7233; www.iccsafe.org.

Sec. 102.2 Existing buildings/occupancies for which a permit was issued before January 1, 2006. The following standard is hereby adopted as amended herein as Part IV of the Connecticut State Fire Safety Code, except as amended, altered or deleted and by the addition of certain provisions as indicated in this code:

NFPA 101, *Life Safety Code*[®], 2021 edition, with annexes promulgated by the National Fire Protection Association.

NFPA standards are available from the National Fire Protection Association, One Batterymarch Park, Quincy, MA 02269-9101; 1-800-344-3555; www.nfpa.org.

Sec. 102.3 Connecticut amendment conventions. The model codes adopted in Sections 102.1 and 102.2 are amended to meet the needs of the state of Connecticut as identified by the following conventions:

- (a) A section or subsection in the Connecticut Amendments preceded by “Amd” indicates the substitution of the provision.
- (b) A section or subsection in the Connecticut Amendments preceded by “Del” indicates the deletion of the provision.
- (c) A section or subsection in the Connecticut Amendments preceded by “Add” indicates the addition of the provision.

Sec. 103 Authority having jurisdiction.

- (a) For the purposes of the standards adopted by reference by this code, the authority having jurisdiction (AHJ) shall mean the State Fire Marshal regarding the proper administration, application, interpretation and modification of the requirements contained within the Connecticut State Fire Safety Code.

- (b) The local fire marshal shall make the initial determination concerning compliance with the Connecticut State Fire Safety Code, except as expressly provided in the wording of a section or in subsection (c) of this section. A decision of a local fire marshal may be appealed to the Codes and Standards Committee as provided in subsection (d) of this section.
- (c) The State Fire Marshal shall make the determination concerning compliance with the Connecticut State Fire Safety Code on state-owned property.
- (d) A decision of the local fire marshal or State Fire Marshal may be appealed to the Codes and Standards Committee in accordance with section 29-309 of the Connecticut General Statutes.

Sec. 104 Plan submittal and review.

Detailed plans and specifications for new structures and additions, renovations or alterations to existing structures shall be submitted by the applicant to the local fire marshal having jurisdiction to demonstrate compliance with section 29-263 of the Connecticut General Statutes and this code.

Sec. 105 Building permit approval.

The local fire marshal shall provide to the local building official certification in writing prior to the issuance of a building permit that the construction documents for any building, structure or use subject to the requirements of this code are in substantial compliance with the requirements of this code. Because of the 30-day time limit imposed by section 29-263 of the Connecticut General Statutes, the fire marshal shall notify the building official whether there is substantial compliance within that time period.

Sec. 106 Variations or exemptions.

In accordance with section 29-296 of the Connecticut General Statutes, the State Fire Marshal may modify the requirements of the Connecticut State Fire Safety Code where the State Fire Marshal deems that strict compliance would entail practical difficulty or unnecessary hardship, or is otherwise adjudged unwarranted, provided any such variation or exemption or approved equivalent or alternative compliance shall, in the opinion of the State Fire Marshal, secure the public safety.

Sec. 107 Inspections.

- (a) Each local fire marshal, the State Fire Marshal and their respective designees shall conduct inspections as prescribed in section 29-305 of the Connecticut General Statutes of buildings and facilities regulated by the Connecticut State Fire Safety Code within their jurisdictions.
- (b) Each local fire marshal, the State Fire Marshal and their respective designees may conduct inspections as often as may be necessary during the construction of new buildings, structures or additions, and during the course of renovations, alterations or modernizations for the purpose of satisfying themselves that all work is in accordance with the approved plans, specifications and this code.
- (c) The minimum requirements for the frequency of inspections as prescribed in section 29-305 of the Connecticut General Statutes shall be as follows: (Note: the definitions for the classification of the occupancies is found in Part III, Section 202 of this code.)

1. Annual inspections for the occupancy classifications all R Residential, A-1, A-2, E, H-1, I-1, M selling consumer fireworks (1.4G), H-3 containing consumer fireworks (1.4G).
2. Inspections every two years for the occupancy classifications A-3, H-2, I-2, I-3, I-4, B-Medical, B-College.
3. Inspections every three years for the occupancy classifications B, H-3, M, S-1, A-4, A-5.
4. Inspections every four years for the occupancy classifications F-1, F-2, H-4, H-5, S-2, U.

Sec. 108 Acceptance of building official reports.

The State Fire Marshal or local fire marshal may accept the reports of the building official concerning a code compliance review or inspection in lieu of conducting the review or inspection himself or herself.

Sec. 109 Certificate of occupancy approval.

The local fire marshal shall provide to the local building official certification in writing that prior to the occupancy of any building, structure or use subject to the requirements of this code, such building, structure or use is in substantial compliance with the requirements of this code.

Sec. 110 Application.

- (a) Part I of this code shall apply to all occupancies and uses located within a building or structure.
- (b) For building permit applications made on or after the effective date of this code, Part III of this code shall apply to:
 - (1) The design and construction of new buildings, structures or portions thereof,
 - (2) Buildings, structures or portions thereof undergoing repairs, alterations and additions,
 - (3) Buildings, structures or portions thereof undergoing a change of occupancy or use as specified in "Changes of Occupancy or Use" in Part I of this code, and
 - (4) For existing occupancies subject to an abatement order for violations of Part IV of this code, only new fire protection systems, and electrical and mechanical system work.
- (c) Part III of this code shall be applicable to buildings, structures or portions thereof for which application for a building permit was made on or after January 1, 2006. For those buildings, structures, or portions thereof which are under the purview of an edition of the Connecticut State Fire Safety Code promulgated on or after January 1, 2006, which contains requirements that are different than those of this code, the requirements of the previous edition of the code shall prevail unless one of the provisions – of this section applies.
- (d) Part IV of this code shall only apply to occupancies and uses located within buildings and structures or portions thereof that existed prior to January 1, 2006.

Sec. 111 Changes of occupancy or use.

In any building, structure or portion thereof, whether or not a physical alteration is needed, a change made in the use or occupancy that would place the building or structure in a different

division of the same group or occupancy or in a different group of occupancies shall not be permitted unless the structure, building or portion thereof conforms with the requirements of this code that apply to new construction for the proposed new use. A change of tenants or ownership shall not be construed to be a change of occupancy classification where the nature of use and assigned occupancy classification remain the same.

Sec. 112 Abatement of hazards; penalty.

(a) The local fire marshal for the fire marshal’s respective jurisdiction or the State Fire Marshal shall order conditions contrary to the provisions of this code to be remedied in accordance with Section 29-291c of the Connecticut General Statutes. An order to vacate all or part of a building may be issued by a local fire marshal or local police officer in accordance with section 29-306 of the Connecticut General Statutes when there exists in a building a risk of death or injury from (1) blocked, insufficient or impeded egress, (2) failure to maintain or the shutting off of any fire protection or fire warning system required by the Fire Safety Code or State Fire Prevention Code, (3) the storage of any flammable or explosive material without a permit or in quantities in excess of any allowable limits pursuant to a permit, (4) the use of any firework or pyrotechnic device without a permit, or (5) exceeding the occupancy limit established by the State Fire Marshal or a local fire marshal. The penalty for the failure to remedy or abate such hazards shall be as prescribed in section 29-291c of the Connecticut General Statutes.

(b) Pursuant to section 29-291c of the Connecticut General Statutes, Section 113 of this code lists those sections of this code for which a citation may be issued.

Sec. 113 Enforcement by Citation

(Add) 113.1 Enforcement by citation. The following chapters or sections of this code may be enforced through the use of the citation process pursuant to section 29-291c of the Connecticut General Statutes.	
Chapter/Section	Subject Matter
Part III - Section 105 Part IV - see CSFPC, Section 1.12	Operating without a permit required by local ordinance
Part III - Section 806.1 Part IV - Section 10.3.9.2.1	Provisions for cut Christmas trees
Part III - Section 901.6 Part IV - Sections 9.6 and 9.11	Failure to maintain or the shutting off of any fire protection or fire warning system required by the Connecticut State Fire Safety Code
Part III - Section 1003.6 Part IV - Section 7.1.10	Blocked, insufficient or impeded egress
Part III - Section 3301 Part IV - Section 4.6.10	Safeguards during building construction, alteration, and demolition operations
Part III - Section 1004.9 Part IV - Section 13.7.9.3	Exceeding the established occupancy limit- assembly occupancies

Part III - Section 5609.1 Part IV - Section 37.4.5.3.1	Storage and display of sparklers and fountains
Part III - Chapter 35 Part IV - see CSFPC, Chapter 41	Hot work operations
Part III - Section 607.3 Part IV - Section 9.2.3	Procedures for use and maintenance of commercial cooking equipment
Part III - Section 308.2, see also CSFPC Sections 20.1.5.3 and 65.4 Part IV - Section 13.7.3, see also CSFPC Sections 20.1.5.3 and 65.4	Flame effects before an audience
Part III - Chapter 56 Part IV - Section 37.4.5.3.1	Sale, handling, and storage of fireworks, sparklers, and fountains
Part III - N/A Part IV - see CSFPC, Section 69.3.13.1	Patio heaters
Part III - Section 6106 Part IV - see CSFPC, Section 69.4.1.3	Filling a liquified petroleum (LP) container without the permission of the owner

Part II—Reserved

PART III CONNECTICUT STATE FIRE SAFETY CODE

Amendments to the 2021 International Fire Code

PART 1 GENERAL PROVISIONS

CHAPTER 1 SCOPE & ADMINISTRATION

SECTION 101 SCOPE & GENERAL REQUIREMENTS

(Amd) **101.1 Title.** Part III of the Connecticut State Fire Safety Code and the adopted standards, as amended, shall be known as Part III of the Connecticut State Fire Safety Code, hereinafter referred to as “the code” or “this code”.

(Add) **101.1.1 Adopted standard.** The following standard, including selected appendices, is hereby adopted as amended herein as Part III of the Connecticut State Fire Safety Code:

International Fire Code® of the International Code Council, Inc., 2021 edition except as amended, altered or deleted and by the addition of certain provisions as indicated in this code.

The following appendices are adopted as part of this code: Appendices D, H, I, and N, as amended.

The following appendices are permitted to be used as guidance: Appendices B, E, F, G, and J, as amended.

International Fire Code® is available from the International Code Council, Inc., 4051 W. Flossmoor Road, Country Club Hills, IL 60478-5795; 1-888-422-7233; www.iccsafe.org.

(Add) **101.1.1.1 Classification of occupancy and use.** Both the fire code official and the building code official shall jointly determine the classification of occupancy and use. The provisions for the classification of occupancy and use are found in Chapter 13, *Occupancy Classification and Use*.

(Add) **101.1.2 Connecticut amendment conventions.** The model codes adopted in 102.1 and 102.2 are amended to meet the needs of the state of Connecticut as identified by the following conventions:

- (a) A section or subsection in the Connecticut Amendments preceded by “Amd” indicates the substitution of the provision.
- (b) A section or subsection in the Connecticut Amendments preceded by “Del” indicates the deletion of the provision.
- (c) A section or subsection in the Connecticut Amendments preceded by “Add” indicates the addition of the provision.

(Add) **101.1.3** Nothing in this code shall be construed to prohibit a better type of building construction, an additional means of egress, or an otherwise safer condition than that specified by the minimum requirements of this code.

(Del) **101.2 Scope.** Delete section in its entirety.

(Del) **101.3 Purpose.** Delete section in its entirety.

(Del) **101.4 Severability.** Delete section in its entirety.

(Del) **101.5 Validity.** Delete section in its entirety.

SECTION 102 APPLICABILITY

(Amd) **102.1 Application.** This part of the code shall apply to all buildings, structures, or portions thereof, facilities or processes, for which application for an initial building permit was made on or after January 1, 2006, as outlined below, except as specifically provided for in the wording of a section.

- (a) For initial building permit applications made on or after the effective date of this code, this code shall apply to:
 - (1) The design and construction of new buildings, structures, facilities or portions thereof.
 - (2) Buildings, structures, or portions thereof; or conditions undergoing repairs, alterations, and additions.
 - (3) Buildings, structures, or portions thereof; undergoing a change of occupancy or use as specified in “Change of occupancy or use” in 102.3 of this code.
 - (4) Except as expressly provided for in the wording of a section, it shall also be applicable to facilities or conditions for which application for the initial building permit was made on or after January 1, 2006.
 - (5) For existing occupancies subject to an abatement order for violations of Part

IV of this code or the Connecticut State Fire Prevention Code, only new fire protection systems, and electrical and mechanical system work.

- (e) For those buildings, structures, facilities, or portions thereof, that are under the purview of an edition of the Connecticut State Fire Safety Code promulgated on or after December 31, 2005 but before the adoption of this code subject to requirements that are different than those of this code, the requirements of the previous edition of the code shall prevail.

Notes:

Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems

Part IV of this code shall apply to buildings, structures, facilities, or portions thereof, or conditions that existed prior to January 1, 2006.

(Add) **102.1.1 Alternative compliance.** Any existing building or portion thereof, structure, evaluated and determined by the fire marshal in conjunction with the building official to be in compliance with the 2021 *International Existing Building Code* portion of the Connecticut State Building Code, shall be deemed to be in compliance with this code. For buildings or structures constructed under an original application of permit prior to January 1, 2006, those portions of an existing building or structure not affected by alteration, addition, or change of occupancy shall comply with Part IV of this code. For buildings or structures constructed under an application of permit on or after to January 1, 2006, those portions of the building or structure not affected by alteration, addition, or change of occupancy shall comply with the applicable requirements of the Connecticut State Fire Safety Code under which it was constructed. Regardless of any wording in the 2021 *International Existing Building Code* portion of the Connecticut State Building Code, the means of egress in existing buildings shall meet the requirements of the Part IV of this code for the proposed occupancy.

(Add) **102.1.1.1 Emergency responder communication coverage in existing buildings.** Regardless of any wording in the 2021 *International Existing Building Code* portion of the *Connecticut* State Building Code, emergency responder communication coverage in existing buildings shall meet the requirements of this section. Existing buildings other than Group R-3, that do not have *approved* in-building, two-way emergency response communication coverage for emergency responders in the building based on existing coverage levels of the public safety communication systems, shall be equipped with such coverage according to one of the following:

1. Where an existing wired communication system cannot be repaired or is being replaced, or where not *approved* in accordance with Section 510.1, Exception 1.
2. Within a time frame established by the authority having jurisdiction.

Exception: Where it is determined by the *fire code official* that the in-building, two-way emergency responder communication coverage system is not needed.

(Add) **102.1.2 Grandstands and bleachers.** The Connecticut State Fire Safety Code shall not apply to portable grandstands or bleachers providing seating for fewer than 100 persons located outside of a building.

(Add) **102.1.3 Federal agency.** The Connecticut State Fire Safety Code shall not apply to any federal agency performing construction or operating on federally owned land or on leased land totally under the control of the federal government.

(Amd) **102.1.4 Public service companies.** This code shall not apply to the installation, alteration or repair of generation, transmission, distribution, metering or other related equipment that is under the ownership or control of a public service company as defined in section 16-1 of the Connecticut General Statutes.

(Add) **102.2 Administrative, operational and maintenance provisions.** The administrative, operational and maintenance provisions of this code shall be administered as provided in chapter 541 of the Connecticut General Statutes and shall apply to buildings, structures, facilities, or portions thereof and conditions arising after January 1, 2006.

(Amd) **102.3 Change of use or occupancy.** A change of occupancy shall not be made unless the use or occupancy is made to comply with the requirements of this code and the *2021 International Building Code* portion of the Connecticut State Building Code. A change of tenants or ownership shall not be construed to be a change of occupancy classification where the nature of the use and assigned occupancy classification remain the same.

(Amd) **102.5 Application of residential code.** Where structures are designed, constructed, and occupied in accordance with the *2021 International Residential Code* portion of the Connecticut State Building Code the provisions of this code shall only apply to detached private dwellings occupied by one or two families and townhouses with respect to smoke alarms and carbon monoxide detectors as specified in the Connecticut State Building Code and subject to the specific inspection criteria for smoke detection and warning equipment of section 29-305 of the Connecticut General Statutes. Tents and membrane structures erected on such sites shall not be regulated by the Connecticut State Fire Safety Code.

(Del) **102.6 Historic buildings.** Delete section.

(Del) **102.8 Subjects not regulated by this code.** Delete section.

(Amd) **102.9 Matters not provided for.** See section 29-306 of the Connecticut General Statutes.

(Add) **102.13 Building Code.** Any references within the body of this code to the *International Building Code* shall be considered references to the 2021 edition of the *International Building Code* portion of the Connecticut State Building Code.

(Add) **102.14 Gas.** The *International Fuel Gas Code* is not adopted by this code. Any references to the *International Fuel Gas Code* within the body of this code shall be considered references to requirements of NFPA 54, National Fuel Gas Code; NFPA 2, Hydrogen Technologies Code; and NFPA 58, Liquefied Petroleum Gas Code.

(Add) **102.15 Electrical.** Any references within the body of this code to the *National Electrical Code* shall be considered references to the 2020 edition of NFPA 70, *National Electrical Code* portion of the Connecticut State Building Code.

(Add) **102.16 Mechanical Code.** Any references within the body of this code to the *International Mechanical Code* shall be considered references to the 2021 edition of the *International Mechanical Code* portion of the Connecticut State Building Code.

PART 2 ADMINISTRATION and ENFORCEMENT

(Del) SECTION 103 CODE COMPLIANCE AGENCY

Delete section in its entirety

SECTION 104 DUTIES AND POWERS OF THE FIRE CODE OFFICIAL (FIRE MARSHAL)

(Amd) **104.1 Authority having jurisdiction.**

(a) For the purposes of this code and the standards adopted by reference in this code, the authority having jurisdiction shall mean the State Fire Marshal regarding the proper administration, application, interpretation and modification of the requirements contained within this code.

(b) The local fire marshal shall make the initial determination concerning compliance with this code, except as expressly provided in the wording of a section or in subsection (c) of this section. A decision of a local fire marshal may be appealed to the State Fire Marshal as provided in subsection (d) of this section.

(c) The State Fire Marshal shall make determinations concerning compliance with this code on state-owned property.

(d) A decision of the local fire marshal or State Fire Marshal may be appealed to the Codes and Standards Committee in accordance with section 29-309 of the Connecticut General Statutes.

Note: The terms “fire code official” and “fire marshal” shall have the same meaning.

(Amd) **104.2 Applications and permits.** The *fire code official* is authorized to receive applications, review *construction documents* and issue permits for operations regulated by this code, inspect premises for which such *construction documents* were prepared for, and enforce compliance with the provisions of this code.

(Add) **104.2.1 Plan submittal and review.** Detailed plans and specifications for new buildings, structures and additions, renovations or alterations to existing structures, equipment, and systems regulated by this code shall be submitted by the applicant to the local fire marshal having jurisdiction or the State Fire Marshal as applicable to demonstrate compliance with section 29-263 of the Connecticut General Statutes and this code. Pursuant to the requirements of section 29-263 of the Connecticut General Statutes, such documents shall be accompanied by evidence of licensure.

(Add) **104.2.1.1 Information on construction documents.** *Construction documents* shall be drawn to scale on suitable material. Electronic media documents may be submitted where *approved* by the *fire code official*. *Construction documents* shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that such work will conform to the provisions of this code and relevant laws, ordinances, rules, and regulations as determined by the *fire code official*.

(Add) **104.2.1.2 Amended construction documents.** Work shall be completed in accordance with the *approved construction documents*, and any changes made during construction that are not in compliance with the *approved construction documents* shall be resubmitted for approval as an amended set of *construction documents*.

(Add) **104.2.1.3 Means of egress.** The *construction documents* shall show in sufficient detail the location, construction, size, and character of all portions of the means of egress including the path of the exit discharge to the public way in compliance with the provisions of this code. In other than occupancies in Groups R-2, R-3, and I-1, the *construction documents* shall designate the number of occupants to be accommodated on every floor, and in all rooms and spaces. For those occupancies utilizing the Small I-2 provisions, the *construction documents* shall designate the locations of the client areas and beds.

(Add) **104.2.1.4 Fire protection system shop drawings.** Shop drawings for the fire protection system(s) shall be submitted to indicate compliance with this code, and applicable referenced standards and the *construction documents*, and shall be *approved* prior to the start of installation. Shop drawings shall contain all information as required by the referenced installation standards in Chapter 80.

(Add) **104.2.1.5 Fire sprinkler system shop drawings.** Shop drawings for fire sprinkler system(s) shall be submitted to indicate conformance with this code and the *construction documents* and shall be approved prior to the start of system installation. Shop drawings shall contain all information as required by the referenced installation standards in Chapter 80. Pursuant to section 29-263a of the Connecticut General Statutes, such documents shall be accompanied by evidence of licensure as a fire sprinkler system layout technician in accordance with section 20-304a of the Connecticut General Statutes, or a professional engineer licensed in accordance with chapter 391 of the Connecticut General Statutes.

(Add) **104.2.1.6 Fire alarm system shop drawings.** Shop drawings for fire alarm system(s) shall be submitted to indicate conformance with this code and the *construction documents* and shall be approved prior to the start of system installation. Shop drawings shall contain all information as required by the referenced installation standards in Chapter 80. Pursuant to section 29-263a of the Connecticut General Statutes, such documents shall be accompanied by evidence of licensure, if applicable, in accordance with section 20-304a of the Connecticut General Statutes, as a professional engineer licensed in accordance with chapter 391 of the Connecticut General Statutes.

(Add) **104.2.1.7 Examination of documents.** The *fire code official* shall examine or cause to be examined the accompanying *construction documents* and shall ascertain by such examination whether the work indicated and described is in accordance with the requirements of this code.

(Add) **104.2.1.8 Approved documents.** *Construction documents approved by the fire code official* are approved with the intent that such *construction documents* comply in all respects with this code. Review and approval by the *fire code official* shall not relieve the applicant of the responsibility of compliance with this code.

(Add) **104.2.1.9 Building permit approval.** The local fire marshal shall provide to the local building official certification in writing prior to the issuance of a building permit that the construction documents for any building, structure or use subject to the requirements of this code are in substantial compliance with the requirements of this code. Because of the 30-day time limit imposed by section 29-263 of the Connecticut General Statutes, the local fire marshal shall notify the building official whether there is substantial compliance within that time period.

(Add) **104.2.2 Changes of occupancy or use.** In any building, structure, or portion thereof, whether or not a physical alteration is needed, a change made in the use or occupancy that would place the building or structure in a different division of the same group or occupancy or in a different group of occupancies shall not be permitted unless the structure, building or portion thereof conforms with the requirements of this code that apply to new construction for the proposed new use. A change of tenants or ownership shall not be construed to be a change of occupancy classification where the nature of use and assigned occupancy classification remain the same.

(Amd) **104.3 Inspections and right of entry.** See section 29-305 of the Connecticut General Statutes.

(Del) **104.3.1 Warrant.** Delete section.

(Del) **104.6 Official records.** Delete section in its entirety.

(Add) **104.6 Official records.** See section 29-305 of the Connecticut General Statutes.

(Del) **104.7 Liability.** Delete section in its entirety.

(Amd) **104.9 Modifications, variations, or exemptions.** In accordance with section 29-296 of the Connecticut General Statutes, the State Fire Marshal may modify the requirements of the Connecticut State Fire Safety Code where the State Fire Marshal deems strict compliance would entail practical difficulty or unnecessary hardship, or is otherwise adjudged unwarranted, provided any such variation or exemption or approved equivalent or alternative compliance shall, in the opinion of the State Fire Marshal, secure the public safety.

(Del) **104.11 Fire investigations.** Delete section in its entirety.

(Del) **104.11 Authority at fires and other emergencies.** Delete section in its entirety.

SECTION 105 PERMITS

(Amd) **105.1 General.** A municipality or fire district, by ordinance, may establish requirements and a fee schedule for construction document review, permits, certificates, notices, approvals, and orders pertaining to fire control and fire hazards pursuant to Section 105 of this code. The local fire marshal shall issue such permits, certificates, notices, approvals and orders. Permits shall be issued in accordance with Sections 105.1.1 to 105.7.25 inclusive.

(Amd) **105.1.1 Permits required.** A property owner or the owner's authorized agent who intends to conduct an operation or business regulated by this code, shall first make application to the local fire marshal and obtain the required permit.

(Amd) **105.1.2 Types of permits.** The permits prescribed in Section 105.1.1 shall be operational permits. An operational permit allows the applicant to have an occupancy or conduct an operation or business for which a permit is required by Section 105.6 for either:

- a) A prescribed period as specified by the local fire marshal, or

- b) Until such permit is renewed or revoked.
- (Del) **105.1.4 Emergency repairs.** Delete section.
- (Del) **105.1.5 Repairs.** Delete section.
- (Del) **105.1.6 Annual permit.** Delete section in its entirety.
- (Del) **105.2.3 Time limitation of application.** Delete section.
- (Del) **105.2.4 Action on application.** Delete section.
- (Del) **105.3 Conditions of a permit.** Delete section in its entirety.
- (Amd) **105.5 Required operational permits.** The *fire code official* is authorized to issue operational permits for the operations set forth in Sections 105.5.2 to 105.5.52, inclusive, where specified by ordinance.
- (Amd) **105.5.16 Explosives.** See sections 29-343 to 29-355a, inclusive, of the Connecticut General Statutes.
- (Amd) **105.5.34 Open burning.** See section 23-48 of the Connecticut General Statutes.
- (Amd) **105.5.42 Pyrotechnic special effects material.** See sections 29-356 to 29-366, inclusive, of the Connecticut General Statutes.
- (Add) **105.5.53 Additional operational permits.** In addition to the requirements of Sections 105.5.2 to 105.5.52, inclusive, permits to operate an occupancy for a use for a building shall be required.
- (Del) **105.6 Required construction permits.** Delete section in its entirety.
- (Del) **107.3 Permit valuation.** Delete section.
- (Del) **107.4 Work commencing before permit issuance.** Delete section.
- (Del) **107.5 Related fees.** Delete section.
- (Amd) **108.1 Inspection authority.** Each local fire marshal, the State Fire Marshal, or their respective designees, shall conduct inspections as prescribed in section 29-305 of the Connecticut General Statutes, of buildings and facilities regulated by this code within their jurisdictions. Each local fire marshal, the State Fire Marshal, or their respective designees, may conduct inspections as often as may be necessary during the construction of new buildings, structures or additions, or processes, and during the course of renovations, alterations or modernizations for the purpose of satisfying themselves that all work is in accordance with the *approved* plans, specifications and this code.

(Amd) **108.2 Inspections.**

- (a) Each local fire marshal, the State Fire Marshal, or their respective designees, shall conduct inspections as prescribed in section 29-305 of the Connecticut General Statutes, of buildings and facilities regulated by the Connecticut State Fire Safety Code within their jurisdictions.
- (b) Each local fire marshal, the State Fire Marshal, or their respective designees, may conduct inspections as often as may be necessary during the construction of new buildings, structures or additions, and during the course of renovations, alterations or modernizations for the purpose of satisfying themselves that all work is in accordance with the *approved* plans, specifications and this code.
- (c) The minimum requirements for the frequency of inspections as prescribed in section 29-305 of the Connecticut General Statutes shall be as follows:
 - (1) Annual inspections for the occupancy classifications all R Residential, A-1, A-2, E, H-1, I-1, I-2 including small I-2, M selling consumer fireworks [sparklers and fountains] (1.4G), H-3 containing consumer fireworks [sparklers and fountains] (1.4G).
 - (2) Inspections every two years for the occupancy classifications A-3, H-2, I-3, I-4, B-Medical, B-College, Ambulatory Health Care.
 - (3) Inspections every three years for occupancy classifications B, H-3, M, S-1, A-4, A-5.
 - (4) Inspections every four years for the occupancy classifications F-1, F-2, H-4, H-5, S-2, U.

(Amd) **108.3 Concealed work.** It shall be the duty of the permit applicant, or the applicant's authorized agent, to cause the work to remain visible and able to be accessed for inspection purposes. Where any installation subject to inspection prior to use is covered or concealed without having first been inspected, the *fire code official* shall have the authority to require that such work be made visible and able to be accessed for inspection. Neither the *fire code official* nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.

(Add) **108.5 Acceptance of building official reports.** The State Fire Marshal or local fire marshal may accept the reports of the building official concerning a code compliance review or inspection in lieu of conducting the review or inspection himself or herself.

(Add) **108.6 Certificate of occupancy approval.** The local fire marshal shall provide to the local building official certification in writing that prior to the occupancy of any building, structure or use subject to the requirements of this code, such building, structure or use is in substantial compliance with the requirements of this code.

(Add) **108.6.1 Notification of inspection results.** Notification as to the passage or failure, in whole or in part, of any required inspection shall be made in writing by the *fire code official* or his/her duly authorized representative and shall be left at the job site, electronically sent, or delivered to the building permit holder or their authorized agent. It

shall be the duty of the building permit holder to ascertain the results of the required inspection.

SECTION 109 MAINTENANCE

(Add) **109.5.1 Order to vacate.** An order to vacate all or part of a building may be issued by a local fire marshal or local police officer in accordance with section 29-306 of the Connecticut General Statutes, when there exists in a building a risk of death or injury from (1) blocked, insufficient or impeded egress, (2) failure to maintain or the shutting off of any fire protection or fire warning system required by the Fire Safety Code or State Fire Prevention Code, (3) the storage of any flammable or explosive material without a permit or in quantities in excess of any allowable limits pursuant to a permit, (4) the use of any firework or pyrotechnic device without a permit, or (5) exceeding the occupancy limit established by the State Fire Marshal or a local fire marshal. The penalty for the failure to remedy or abate such hazards shall be as described in section and 29-291c of the Connecticut General Statutes as appropriate.

(Add) **109.6.1 Order to vacate.** An order to vacate all or part of a building may be issued by a local fire marshal or local police officer in accordance with section 29-306 of the Connecticut General Statutes, when there exists in a building a risk of death or injury from (1) blocked, insufficient or impeded egress, (2) failure to maintain or the shutting off of any fire protection or fire warning system required by the Fire Safety Code or State Fire Prevention Code, (3) the storage of any flammable or explosive material without a permit or in quantities in excess of any allowable limits pursuant to a permit, (4) the use of any firework or pyrotechnic device without a permit, or (5) exceeding the occupancy limit established by the State Fire Marshal or a local fire marshal. The penalty for the failure to remedy or abate such hazards shall be as described in section 29-291c of the Connecticut General Statutes as appropriate.

(Del) SECTION 110 SERVICE UTILITIES

(Del) **110.1 Authority to disconnect service utilities.** Delete section.

SECTION 111

(Amd) APPEAL OF THE DECISION OF THE LOCAL OR STATE FIRE MARSHAL

(Amd) **111.1 Appeal of the decision of the local or state fire marshal.** A decision of the local fire marshal or State Fire Marshal may be appealed to the Codes and Standards Committee in accordance with section 29-309 of the Connecticut General Statutes.

(Del) **111.2 Limitations on authority.** Delete section.

(Del) **111.3 Qualifications.** Delete section.

(Del) **111.4 Administration.** Delete section.

**SECTION 112
(Amd) ABATEMENT OF FIRE HAZARDS**

(Amd) **112.1 Abatement of fire hazards.** The local fire marshal for a jurisdiction or the State Fire Marshal shall order conditions contrary to the provisions of this code to be remedied in accordance with section 29-306 of the Connecticut General Statutes.

(Add) **112.1.1 Unauthorized tampering.** Signs, tags or seals posted or affixed by the *fire code official* shall not be mutilated, destroyed or tampered with, or removed, without authorization from the *fire code official*.

(Del) **112.2 Owner/occupant responsibility.** Delete section.

(Del) **112.3 Notice of violation.** Delete section in its entirety.

(Del) **112.4 Violation penalties.** Delete section in its entirety.

**(Del) SECTION 113
STOP WORK ORDER**

(Del) **113.1 Authority.** Delete section.

(Del) **113.2 Issuance.** Delete section.

(Del) **113.3 Emergencies.** Delete section.

**SECTION 114
UNSAFE STRUCTURES OR EQUIPMENT**

(Amd) **114.1 General.** See sections 7-313e and 29-306 of the Connecticut General Statutes.

(Del) **114.1.1 Unsafe conditions.** Delete section.

(Del) **114.1.2 Structural hazards.** Delete section.

(Del) **114.2 Evacuation.** Delete section.

(Del) **114.3 Record.** Delete section.

(Del) **114.4 Notice.** Delete section.

(Del) **114.5 Method of service.** Delete section in its entirety.

(Del) **114.6 Restoration or abatement.** Delete section in its entirety.

(Del) **114.7 Summary abatement.** Delete section in its entirety.

**(Add) SECTION 115
OCCUPANCY CLASSIFICATION AND USE**

(Add) **115.1 Occupancy classification and use.** The requirements of Chapter 3 of the 2021 *International Building Code* portion of the 2022 Connecticut State Building Code shall also be considered requirements of this code and known as the 2021 *International Building Code*, Chapter 3 portion of the 2022 Connecticut State Fire Safety Code.

**(Add) SECTION 116
SPECIAL DETAILED REQUIREMENTS BASED UPON OCCUPANCY AND USE**

(Add) **116.1 Special detailed requirements based upon occupancy and use.** The requirements of Chapter 4 of the 2021 *International Building Code* portion of the 2022 Connecticut State Building Code shall also be considered requirements of this code and known as the 2021 *International Building Code*, Chapter 4 portion of the 2022 Connecticut State Fire Safety Code.

**(Add) SECTION 117
GROUP R-1 BED AND BREAKFAST ESTABLISHMENTS**

(Add) **117.1 Kitchens in Group R-1 bed and breakfast establishments.** Kitchens in Group R-1 bed and breakfast establishments shall be separated by ½-hour rated fire separation assemblies.

Exceptions:

1. If the kitchen is protected by a limited area sprinkler system.
2. If the kitchen is equipped with a listed residential range top extinguisher unit or an approved commercial kitchen hood with a listed, approved automatic fire suppression system.
3. The structural members supporting the rated assemblies shall not be required to be fire-resistance rated.

(Add) **117.2 Group R-1 bed and breakfast establishments.** The height limitation for existing unsprinklered *buildings* of Type VB construction undergoing a *change of occupancy* from detached *one- and two-family dwellings* to *Group R-1 bed and breakfast establishments* shall be increased by 5 feet (1524 mm) from the value in Table 504.3 of the 2021 *International Building Code* portion of the Connecticut State Building Code and one *story* from the value in Table 504.4 of the 2021 *International Building Code* portion of the Connecticut State Building Code where 1-hour fire-resistance rated assemblies are constructed between the second and third floors. The structural members supporting the rated assemblies shall not be required to be fire-resistance rated.

(Add) SECTION 118 INCIDENTAL USES

(Add) **118.1 Incidental uses.** The requirements of Section 509 of the 2021 *International Building Code* portion of the 2022 Connecticut State Building Code shall also be considered requirements of this code and known as the 2021 *International Building Code*, Section 509 portion of the 2022 Connecticut State Fire Safety Code.

Exception: Incidental uses within and serving a dwelling unit are not required to comply with this section.

(Add) SECTION 119 MIXED USE AND OCCUPANCY

(Add) **119.1 Mixed Used and Occupancy.** The requirements of Section 508 of the 2021 *International Building Code* portion of the 2022 Connecticut State Building Code, except as noted below, shall also be considered requirements of this code and known as the 2021 *International Building Code*, Section 508 portion of the 2022 Connecticut State Fire Safety Code.

Exceptions:

1. Sections 508.5.9 and 508.5.11 addressing Accessibility and Plumbing Facilities respectively, are not adopted as part of the 2022 Connecticut State Fire Safety Code.
2. Any references to allowable building height, allowable building area, or the number of stories allowed in a building in Section 508 are not adopted as part of the 2022 Connecticut State Fire Safety Code, and shall be determined by the building official.

CHAPTER 2 DEFINITIONS

(Add) **APPROVED AGENCY.** An established and recognized agency regularly engaged in conducting tests or furnishing inspection services or furnishing product certification, where such agency has been approved by the *fire code official*. Building officials licensed in accordance with the provisions of section 29-262 of the Connecticut General Statutes and employed by the jurisdiction in which the building or structure is being constructed, shall be considered an approved agency for the portions of this code also regulated by the Connecticut State Building Code. Pursuant to subsection (e)(1) of section 29-276b of the Connecticut General Statutes, approved agencies conducting tests or furnishings inspection services of soils or concrete must maintain accreditation by the National Voluntary Laboratory Accreditation Program of the National Institute of Standards and Technology.

(Amd) **BUILDING.** Any structure used or intended for supporting or sheltering any use or occupancy. For application of this code, each portion of a building that is completely separated from other portions by fire walls designed and constructed in accordance with the Connecticut State Building Code and has been approved by the building official shall be considered a separate building.

(Add) **BULK MERCHANDISING RETAIL BUILDING.** A retail building exceeding 12,000 square feet (1,115 m²) in area in which the sales area includes the storage of combustible materials on pallets, in solid piles, or in racks in excess of 12 feet (3,658 mm) in storage height.

(Amd) **EXISTING.** Buildings, facilities or conditions that were already in existence, constructed or officially authorized prior to the adoption of this code. For the purposes of Chapter 11 of this code, existing shall be defined as a building, structure or condition for which a building permit was applied for on or after January 1, 2006, and prior to the adoption of this code, and which has not undergone any alterations, renovations, or changes of use.

(Amd) **FIRE CODE OFFICIAL.** The local fire marshal or State Fire Marshal charged with the enforcement of this code, or his or her duly authorized representative.

(Amd) **FIREWORKS.** Fireworks has the same meaning as provided in section 29-356 of the Connecticut General Statutes and includes any device that meets the definition of 1.3G fireworks and 1.4G fireworks, but excludes sparklers and fountains, as defined in section 29-356 of the Connecticut General Statutes.

Fireworks, 1.3G. Large fireworks devices, which are *explosive materials*, intended for use in fireworks displays and designed to produce audible or visible effects by combustion, *deflagration* or *detonation*. Such 1.3G fireworks include, but are not limited to, firecrackers containing more than 130 milligrams (2 grains) of explosive composition, aerial shells containing more than 40 grams of pyrotechnic composition and other display pieces which exceed the limits for classification as 1.4G fireworks. Such 1.3G fireworks are also identified as Fireworks, UN0335 pursuant to 49.CFR 172.101.

Fireworks, 1.4G. Small fireworks devices containing restricted amounts of pyrotechnic composition designed primarily to produce visible or audible effects by combustion or *deflagration* which comply with the construction, chemical composition and labeling requirements for Fireworks, UN0336 pursuant to CFR 172.101 and those set forth in 16 CFR Parts 1500 and 1507.

Sparklers and Fountains. See definition under Sparklers and Fountains.

OCCUPANCY CLASSIFICATIONS:

(Amd) **FOSTER CARE FACILITIES.** Facilities that provide foster care to more than three children, 3 years of age or younger.

(Add) **NIGHT CLUB/DISCOTHEQUE/DANCE HALL.** A place that is open at night, has music, dancing, or a show, and may serve alcoholic drinks and food.

(Add) **GROUP B COLLEGE OCCUPANCIES.** A building, structure, or portion thereof that is of a Group B Business occupancy classification and associated with a facility of higher education above the twelfth grade. This definition does not include training or skill development facilities.

(Add) **GROUP B MEDICAL AND DENTAL OCCUPANCIES.** Shall apply to Group B medical and dental occupancies that provide services or treatment for four or more patients who may simultaneously be rendered incapable of taking action for self-preservation under emergency conditions. The occupancy shall include, but not be limited to, the following:

- Outpatient clinics with general anesthesia or life-support equipment;
- Dental centers providing treatment under general anesthesia;
- One-day surgical centers; and
- Physicians' offices providing treatment under general anesthesia.

Facilities such as the above that do not provide general anesthesia or life support

equipment simultaneously to four or more patients shall be classified as Group B Business occupancies.

(Add) **IN-HOME GROUP B OCCUPANCY. (Live-Work Unit)** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit shall be classified as a single-family dwelling.

(Add) **IN-HOME INDUSTRIAL OCCUPANCIES, OTHER THAN HIGH HAZARD INDUSTRIAL OCCUPANCIES. (Live-Work Unit)** Customary in-home industrial occupancies located within a single-family dwelling unit, in which processing, assembling, mixing, packaging, finishing, decorating, or repair operations are conducted, that employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit, shall be classified as a single-family residential occupancies.

(Amd) **Group E, day care facilities, more than six children.** This group includes buildings, structures, or portions thereof occupied by more than six children 3 years of age or older who receive educational, supervision or personal care services for fewer than 24 hours per day.

(Del) **Five or fewer children.** Delete.

(Del) **Five or fewer children in a dwelling unit.** Delete.

(Add) **Group E, day care facilities, six or fewer children.** A building, structure, or portion thereof having six or fewer children who receive educational, supervision or personal care services shall be classified as part of the primary occupancy.

(Add) **Group E, day care facilities, six or fewer children in a dwelling unit.** As described in subdivision (3) of subsection (a) of section 19a-77 of the Connecticut General Statutes, a family child care home shall be classified as Group R-3 or shall comply with the 2015 *International Residential Code* portion of the Connecticut State Building Code in accordance with Section 101.2.

Note: Residential Group R-4, Four to sixteen persons receiving care; and Residential Group R-3, Three or fewer persons receiving care are located under the **Institutional Group I-1** heading.

(Add) **Group R-1 BED and BREAKFAST or BED and BREAKFAST ESTABLISHMENT.** A building:

- (1) That provides sleeping accommodations to the public for a fee for no more than sixteen persons with guest rooms limited to the first and second floor of the structure, and

- (2) Where the owner occupies the building or an adjacent property as his or her primary place of residence, and
- (3) Where cooking or food warming of any type is not allowed in guest rooms, and
- (4) That is a maximum of three stories in height and does not contain a mixed occupancy.

(Add) **ONE-FAMILY DWELLING.** A building containing one dwelling unit with not more than six lodgers or boarders. Also known as a single-family dwelling.

(Add) **TWO-FAMILY DWELLING.** A building containing two dwelling units with not more than six lodgers or boarders per dwelling unit.

(Amd) **Residential Group R-4, Four to sixteen persons receiving care.** A facility housing not fewer than four and not more than sixteen persons receiving custodial care shall be classified as R-4.

(Amd) **Residential Group R-3 Three or fewer persons receiving care.** A facility with three or fewer persons receiving custodial care shall be classified as Group R-3 or shall comply with the 2018 *International Residential Code* portion of the Connecticut State Building Code.

(Amd) **Institutional Group I-2.** Institutional Group I-2 occupancy shall include buildings and structures used for medical care on a 24-hour basis for more than three persons who are incapable of self-preservation. This group shall include, but not be limited to, the following:

- Foster care facilities
- Detoxification facilities
- Hospitals
- Nursing homes
- Psychiatric hospitals

(Del) **Five or fewer persons receiving medical care.** Delete.

(Add) **Institutional Group I-2, Three or fewer persons receiving care.** A facility with three or fewer persons simultaneously receiving medical care shall be classified as Group R-3 or shall comply with the 2018 *International Residential Code* portion of the State Building Code.

(Add) **Small I-2 Home, Alternative compliance for small I-2 homes.** See Section 1407.14 for alternative compliance provisions for Group I-2 homes serving four to six persons who are incapable of self-preservation.

(Amd) **Institutional Group I-3.** Institutional Group I-3 occupancy shall include buildings that are inhabited by more than three persons who are under restraint or security. A Group

I-3 facility is occupied by persons who are generally incapable of self-preservation due to security measures not under such persons' control. This group shall include, but not be limited to, the following:

- Correctional centers
- Detention centers
- Jails
- Prerelease centers
- Prisons
- Reformatories

Buildings of Group I-3 shall be classified as one of the five following occupancy conditions:

Condition 1. This occupancy condition shall include buildings in which free movement is allowed from sleeping areas, and other spaces where access or occupancy is permitted, to the exterior via *means of egress* without restraint. A Condition 1 facility is permitted to be constructed as Group R.

Condition 2. This occupancy condition shall include buildings in which free movement is allowed from sleeping areas and any other occupied *smoke compartment* to one or more other *smoke compartments*. Egress to the exterior is impeded by locked *exits*.

Condition 3. This occupancy condition shall include buildings in which free movement is allowed within individual *smoke compartments*, such as within a residential unit comprised of individual *sleeping units* and group activity spaces, where egress is impeded by remote-controlled release of *means of egress* from such a *smoke compartment* to another *smoke compartment*.

Condition 4. This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Remote-controlled release is provided to permit movement from *sleeping units*, activity spaces and other occupied areas within the *smoke compartment* to other *smoke compartments*.

Condition 5. This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Staff-controlled manual release is provided to permit movement from *sleeping units*, activity spaces and other occupied areas within the *smoke compartment* to other *smoke compartments*.

(Amd) Institutional Group I-4, day care facilities. Institutional Group I-4 occupancy shall include buildings and structures occupied by more than six persons of any age who receive custodial care for fewer than 24 hours per day by persons other than parents or

guardians or relatives by blood, marriage or adoption, and in a place other than the home of the person cared for. This group shall include, but not be limited to, the following:

Adult day care

Child day care

(Amd) **Institutional Group I-4, Classification as Group E.** A child day care facility that provides care for more than six but not more than one hundred children 3 years or less of age, where the rooms in which the children are cared for are located on the level of exit discharge serving such rooms and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.

(Del) **Five of fewer occupants receiving care.** Delete.

(Del) **Five of fewer occupants receiving care in a dwelling unit.** Delete.

(Add) **Institutional Group I-4 day care facilities, six or fewer persons receiving care.** A facility having six or fewer persons receiving custodial care shall be classified as part of the primary occupancy.

(Add) **Institutional Group I-4 child care.** As described in subdivision (3) of subsection (a) of section 19a-77 of the Connecticut General Statutes, a family child care home shall be classified as Group R-3 or shall comply with the 2015 *International Residential Code* portion of the Connecticut State Building Code.

(Amd) **Residential Group R-1.** Residential occupancies containing sleeping units in which the occupants are primarily transient in nature, including:

Bed and breakfast establishments

Boarding houses with more than six occupants

Congregate living facilities with more than six occupants

Hotels

Motels

(Amd) **Residential Group R-2.** Residential Group R-2 occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

Apartment houses

Boarding houses with more than six occupants

Congregate living facilities with more than six occupants

Convents

Dormitories

Fraternities and sororities

Hotels
Live/work units
Monasteries
Motels
Vacation timeshare properties

(Amd) **Residential Group R-3.** Residential Group R-3 occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-4 or I, including:

Buildings that do not contain more than two dwelling units, with not more than six lodgers or boarders per dwelling unit.

Care facilities that provide accommodations for five or fewer persons receiving care.

Congregate living facilities (nontransient) with six or fewer occupants where personal care services are not provided.

Boarding houses (nontransient)

Convents

Dormitories

Fraternities and Sororities

Monasteries

Congregate living facilities (transient) with six or fewer occupants where personal care services are not provided.

Boarding houses (transient) with six or fewer occupants where personal care services are not provided.

(Amd) **Residential Group R-4.** Residential Group R-4 occupancy shall include buildings, structures or portions thereof for more than 3 but not more than 16 occupants, excluding staff, who reside on a 24-hour basis in a supervised residential environment and receive custodial care. Buildings of Group R-4 shall be classified as one of the occupancy conditions specified in Section 310.6.1 or 310.6.2 of the 2018 *International Building Code* portion of the Connecticut State Building Code. The persons receiving care are capable of self-preservation. This group shall include, but not be limited to, the following:

Alcohol and drug centers

Assisted living facilities

Congregate care facilities

Group homes

Halfway houses

Residential board and care custodial care facilities

Social rehabilitation facilities

Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3, except as otherwise provided for in the Connecticut State Building Code.

(Add) **PLANS AND SPECIFICATIONS.** See Construction Documents.

(Add) **PLATFORM.** A raised area within a building used for worship, the presentation of music, plays or other entertainment; a head table for special guests; a raised area for lecturers or speakers; a boxing or wrestling ring; a theatre-in-the round stage; or an area used for similar purposes wherein, other than horizontal sliding curtains, there are no overhead hanging curtains, drops, scenery or stage effects other than lighting and sound. A temporary platform is one installed for not more than 30 days.

Exception: Curtains suspended from overhead that open and close in a horizontal manner shall be permitted at platforms.

(Add) **SPARKLERS AND FOUNTAINS.** “Sparklers” and “fountains” have the same meanings as provided in section 29-356 of the Connecticut General Statutes.

(Amd) **SPECIAL AMUSEMENT BUILDING.** A special amusement building is any temporary or permanent building or portion thereof that is occupied for amusement, entertainment or education purposes and that contains a device or system that conveys passengers or provides a walkway along, around or over a course in any direction so arranged that the means of egress path is not readily apparent due to visual or audio distractions or is intentionally confounded or is not readily available because of the nature of the attraction or mode of conveyance through the building or structure.

Exception: Children’s play structures that do not exceed 10 feet (0.93m) in height and do not have an aggregate horizontal projection in excess of 300 square feet (27.9m).

CHAPTER 3 GENERAL REQUIREMENTS

(Amd) **301.2 Permits.** Permits shall be required as set forth in Section 105.5 for the activities or uses regulated by Sections 303, 306, 307, 308 and 315.

(Del) SECTION 307 OPEN BURNING, RECREATIONAL FIRES AND PORTABLE OUTDOOR FIREPLACES

Delete section in its entirety. See section 23-48 of the Connecticut General Statutes.

(Amd) **308.1 General.** Open flame, fire and burning shall be in accordance with Sections 308.1.1 to 308.4.1, inclusive, and with other applicable sections of this code.

(Amd) **308.1.6.3 Sky lanterns.** A person shall not release or cause to be released an untethered sky lantern.

(Amd) **308.2 Permits required.** Permits shall be obtained from the *fire code official* in accordance with Section 105.5 prior to engaging in the following activities involving open flame, fire and burning:

1. Use of a torch or flame-producing device to remove paint from a structure.
2. Except for theatrical performance open flame devices as specified in Section 308.3.2, the use of open flame, fire or burning in connection with Group A or E occupancies.
3. Use or operation of torches and other devices, machines or processes liable to start or cause fire in or on wildfire risk areas.

Note: See section 29-357a of the Connecticut General Statutes for permit requirements for displays of special effects produced by pyrotechnics or flame producing devices.

(Amd) **308.3.2 Theatrical performances, flame effects before an audience.** Where *approved* by the State Fire Marshal, open flame devices or effects used in conjunction with theatrical performances or flame effects before an audience shall be in conformance with and governed by the requirements of the Connecticut State Fire Prevention Code.

(Add) **308.3.2.1 Approval.** The use of flame effect materials, devices or components governed by NFPA 140 and NFPA 160; the device, its arrangement, and location(s) shall be *approved* by the State Fire Marshal and shall be in conformance with the requirements of the Connecticut State Fire Prevention Code.

**(Del) SECTION 310
SMOKING**

Delete section in its entirety.

**(Del) SECTION 319
MOBILE FOOD PREPRATION VEHICLES**

Delete section in its entirety.

CHAPTER 4
EMERGENCY PLANNING AND PREPAREDNESS.

(Amd) **401.1 Scope.** Reporting of emergencies, coordination with emergency response forces, emergency plans and procedures for managing or responding to emergencies shall comply with the provisions of this section.

(Amd) **403.2.2 Announcements.** As required by subsection (b) of section 29-381 of the Connecticut General Statutes, before any performance or event at any theater, concert or music hall or assembly hall or at any building, auditorium or room used for public gatherings of more than one hundred persons, the owner, proprietor, manager or agent of such theater, hall, building, auditorium or room shall make a public announcement that describes the location of emergency exits.

(Amd) **403.4.1 Fire drills. Crisis response drills.** (a) Each local and regional board of education shall provide for a fire drill to be held in the schools of such board not later than thirty days after the first day of each school year and at least once each month thereafter, except as provided in subsection (b) of this section.

(b) Each such board shall substitute a crisis response drill for a fire drill once every three months and shall develop the format of such crisis response drill in consultation with the appropriate local law enforcement agency. A representative of such agency may supervise and participate in any such crisis response drill.

(Amd) **403.7.2 Group I-2 occupancies.** Group I-2 occupancies shall comply with Sections 401, 403.7.2.1 to 403.7.2.4.1, inclusive, and 404 to 406, inclusive.

(Amd) **403.7.2.4 Emergency evacuation drills not including small I-2 homes.** Emergency evacuation drills shall comply with Section 405.

Exceptions:

1. The movement of patients to safe areas or to the exterior of the building is not required.
2. Where emergency evacuation drills are conducted after visiting hours or where patients or residents are expected to be asleep, a coded announcement shall be an acceptable alternative to audible alarms.

(Add) **403.7.2.4.1 Emergency evacuation drills for small I-2 homes.** Emergency evacuation drills shall involve the actual evacuation of all residents to an assembly point, as specified in the emergency action plan required by the CSFPC, and shall provide residents with experience in egressing through all exits and means of escape required by the code.

(Amd) **403.9.2.1 College and university buildings. Residential boarding and high school buildings.** An *approved* fire safety and evacuation plan in accordance with Section 404 shall be prepared and maintained for Group R-2 college and university buildings, and R-2 Residential boarding and high school buildings. Group R-2 college and university buildings, and R-2 Residential boarding and high school buildings shall comply with Sections 403.9.2.1.1 and 403.9.2.1.2.

(Amd) **403.9.2.1.1 First emergency evacuation drill.** The first emergency evacuation drill of each school year shall be conducted within 30 days of the beginning of classes.

(Amd) **403.9.2.2.1 Guide contents.** A fire emergency guide shall describe the location, function and use of fire protection equipment and appliances available for use by residents, including fire alarm systems, smoke alarms and portable fire extinguishers. Guides shall include an emergency evacuation plan for each sleeping unit or *dwelling unit*.

(Amd) **403.9.3.1.1 Fire safety plan.** A copy of the fire safety plan shall be maintained at the facility at all times. The plan shall include the following in addition to the requirements of Section 404.2.2:

1. Location and number of resident sleeping rooms.
2. Location of special locking or egress control arrangements.
3. Location of all points of safety.

(Add) **403.10.6 Road tunnels.** Newly-constructed road tunnels shall comply with Chapter 7 of NFPA 502. Renovations to existing road tunnels are not required to comply with Chapter 7 of NFPA 502.

(Amd) **403.11.3 Crowd managers.** Where facilities or events involve a gathering of more than 250 people, crowd managers shall be provided in accordance with Sections 403.11.3.1 to 403.11.3.3, inclusive.

(Amd) **403.11.3.1 Number of crowd managers.** Not fewer than one trained crowd manager for each 250 persons or portion thereof, shall be provided for the gathering.

Exceptions:

1. Outdoor events with fewer than 1,000 persons in attendance shall not require crowd managers.
2. Assembly occupancies used exclusively for religious worship with an *occupant load* not exceeding 500 shall not require crowd managers.

3. The number of crowd managers shall be reduced where, in the opinion of the *fire code official*, the fire protection provided by the facility and the nature of the event warrant a reduction.

(Amd) **404.2.3.2 Drills.** Lockdown plan drills shall be conducted in accordance with the approved plan. Except as provided for in Section 403.4.1, such drills shall not be substituted for fire and evacuation drills required by Section 405.2.

(Amd) **Table 405.3**

FIRE AND EVACUATION DRILL FREQUENCY AND PARTICIPATION

Group or Occupancy	Frequency	Participation
Group A	Quarterly	Staff
Group B ^b	Annually	All occupants
Group B ^c (Ambulatory care facilities)	Quarterly on each shift ^a	Staff
Group B ^b (Clinic, outpatient)	Annually	Staff
Group E	Monthly ^{a,e}	All occupants
Group F	Annually	Staff
Group I-1	Semiannually on each shift ^b	All occupants
Group I-2	Quarterly on each shift ^a	Staff
Small I-2 Group Homes	Quarterly on each shift	All occupants, See Section 403.7.2.4
Group I-3	Quarterly on each shift ^a	Staff
Group I-4	Monthly on each shift ^a	All occupants
Group R-1	Quarterly on each shift	Staff
Group R-2 ^d	Four annually	All occupants
Group R-4	Semiannually on each shift ^{a,f}	All occupants ^f

a. In severe weather conditions, the *fire code official* shall have the authority to modify the emergency evacuation drill frequency.

b. Emergency evacuation drills are required in Group B buildings having an occupant load of 500 or more persons or more than 100 persons above or below the lowest level of exit discharge.

c. Emergency evacuation drills are required in ambulatory care facilities in accordance with Section 403.3.

d. Emergency evacuation drills in Group R-2 college and university buildings shall be in accordance with Section 403.9.2.1. Other Group R2 occupancies shall be in accordance with Section 403.9.2.2.

e. See Section 403.4.1 for crisis response drills.

f. See Section 403.9.3.4.

CHAPTER 5 FIRE SERVICE FEATURES

(Amd) **501.1 Scope** The fire chief in conjunction with the *fire code official* shall assure fire service features for buildings, structures, operations, and premises shall comply with this chapter.

(Amd) **501.2 Permits.** A permit shall be required as set forth in Section 105.5.

(Amd) **503.1 Where required.** Fire apparatus access roads shall be provided and maintained in accordance with Section 503.1.

(Amd) **503.1.1 Buildings and facilities.** *Approved* fire apparatus access roads shall be provided for every facility, building, or portion hereafter constructed or moved into or within the jurisdiction. Each fire apparatus access road shall comply with the requirements of Appendix D.

(Amd) **503.1.2 Additional access.** The *fire code official* in conjunction with the *fire chief* is authorized to require more than one fire apparatus access road based on the potential for impairment of a single road by vehicle congestion, condition of terrain, climate conditions or other factors that could limit access.

(Del) **503.2 Specifications.** Delete section in its entirety.

(Del) **503.4 Obstruction to fire department access roads.** Delete section in its entirety.

(Del) **503.5 Required gates or barriers.** Delete section in its entirety.

(Del) **503.6 Security gates.** Delete section.

(Del) **507.1 Required water supply.** Delete section in its entirety.

(Del) **507.2 Type of water supply.** Delete section in its entirety.

(Del) **507.3 Fire flow.** Delete section in its entirety.

(Del) **507.4 Water supply test.** Delete section in its entirety.

(Amd) **507.1 Required water supply.** Fire hydrant systems shall comply with Sections 507.1.1 to 507.5.6, inclusive.

(Del) **507.5.1 Where required.** Delete section.

(Amd) **510.2 Emergency responder radio coverage in existing buildings.** Existing buildings other than Group R-3, undergoing an addition, alteration, renovation, or change of use either by the requirements of this code or the *International Existing Building Code* portion of the Connecticut State Building Code, that do not have *approved* in-building, two-way emergency response communication coverage for emergency responders in the building based on existing coverage levels of the public safety communication systems, shall be equipped with such coverage according to one of the following:

1. Where an existing wired communication system cannot be repaired or is being replaced, or where not *approved* in accordance with Section 510.1, Exception 1.
2. Within a time frame established by the authority having jurisdiction.

Exception: Where it is determined by the *fire code official* that the in-building, two-way emergency responder communication coverage system is not needed.

CHAPTER 6 BUILDING SERVICES AND SYSTEMS

(Add) **601.3 Gas.** The *International Fuel Gas Code* is not adopted by the state of Connecticut. Any references to the *International Fuel Gas Code* within the body of this code shall be considered references to the requirements of NFPA 54, *National Fuel Gas Code*; NFPA 2, *Hydrogen Technologies Code*; and NFPA 58, *Liquefied Petroleum Gas Code*. These requirements apply to gas piping systems extending from the point of delivery to the inlet connections of appliances, the installation and operation of residential and commercial gas appliances and related accessories as covered by this code.

(Amd) **603.10 Abandoned wiring.** Abandoned cables that are able to be accessed without causing damage, or requiring demolition to the building, shall be tagged for future use or removed.

(Amd) **604.1 State Elevator Code.** All elevators, dumbwaiters, material lifts, vertical and inclined platform lifts, inclined stairway chairlifts, limited-use/limited application elevators and escalators, including existing systems, shall comply with the regulations of the Department of Administrative Services adopted pursuant to chapter 538 of the Connecticut General Statutes as enforced by the State Elevator Inspector and the requirements of this section.

(Del) **604.2 Emergency operations.** Delete section in its entirety.

(Del) **604.3 Standby power.** Delete section in its entirety.

(Del) **604.5 Maintenance of elevators.** Delete section in its entirety.

(Del) **604.6 Elevator keys.** Delete section in its entirety.

(Amd) **605.4 Fuel oil storage systems.** Fuel oil storage systems for building heating systems shall be installed and maintained in accordance with the requirements of NFPA 31 and this Code. Tanks and fuel-oil piping systems shall be installed in accordance with NFPA 31 and Chapter 13 of the *International Mechanical Code*.

(Amd) **605.5 Portable unvented heaters.** Portable unvented heaters shall conform to the requirements of sections 29-318 to 29-318c, inclusive, of the Connecticut General Statutes. Portable unvented fuel fired heating equipment shall be prohibited in occupancies in Groups A, E, I, R-1, R-2, R-3 and R-4 and ambulatory care facilities.

Exception:

Portable outdoor gas-fired heating appliances in accordance with Section 605.5.2.

(Amd) **606.1 General.** Commercial kitchen exhaust hoods shall comply with the requirements of the *2021 International Mechanical Code* portion of the Connecticut State Building Code.

CHAPTER 7 (AMD) INSPECTION AND MAINTENANCE OF FIRE AND SMOKE PROTECTION FEATURES

(Amd) **701.1 Scope.** The provisions of this Chapter shall govern the inspection and maintenance of the materials, systems and assemblies used for structural *fire resistance*, *fire-resistance-rated* construction separation of adjacent space and construction installed to resist the passage of smoke to safeguard against the spread of fire and smoke within a building and the spread of fire to or from buildings. New buildings shall comply with the *2021 International Building Code* portion of the Connecticut State Building Code and Section 701.1.1.

(Add) **701.1.1 Additional requirements.** In addition to the requirements of this Chapter, the requirements of Chapter 7 of the *2021 International Building Code* portion of the 2022 Connecticut State Building Code shall also be considered requirements of this Code and known as the *2021 International Building Code*, Chapter 7 portion of the 2022 Connecticut State Fire Safety Code.

(Amd) **701.6 Owner's responsibility.** The *owner* shall maintain an inventory of all required *fire-resistance-rated* construction, construction installed to resist the passage of smoke and the construction included in Sections 703 to 707, inclusive, and Sections

602.4.1 and 602.4.2 of the 2021 *International Building Code* portion of the Connecticut State Building Code. Such construction shall be visually inspected by the *owner* annually and properly repaired, restored or replaced when damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the *owner* unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

CHAPTER 8

INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS

(Amd) **801.1 Scope.** The provisions of this Chapter shall govern interior finish, interior trim, furniture, furnishings, decorative materials and decorative vegetation in buildings. Buildings shall comply with Sections 801 to 808 inclusive.

(Add) **801.1.1 Additional requirements.** In addition to the requirements of this chapter, the requirements of Chapter 8 of the 2021 *International Building Code* portion of the 2022 Connecticut State Building Code shall also be considered requirements of this code and known as the 2021 *International Building Code*, Chapter 8 portion of the 2022 Connecticut State Fire Safety Code.

(Amd) SECTION 803

WALL AND CEILING FINISHES

(Amd) SECTION 804

INTERIOR WALL AND CEILING TRIM AND INTERIOR FINISH IN BUILDINGS

(Amd) 804.1 **804.1 Interior trim.** Combustible trim in buildings, excluding *handrails* and guards, shall not exceed 10 percent of the specific wall or ceiling areas to which it is attached. Other than foam plastic, material used as interior trim shall comply with Section 804.1.1 or 804.1.2. Foam plastic used as interior trim shall comply with Section 804.2.

(Amd) SECTION 805

UPHOLSTERED FURNITURE AND MATTRESSES IN BUILDINGS

(Amd) SECTION 806

NATURAL DECORATIVE VEGETATION IN BUILDINGS

(Add) **806.1.1** Where permitted by the *fire code official*, Christmas trees shall be permitted in accordance with Table 806.1.1.

Table 806.1.1 Provisions for Christmas Trees by Occupancy

Occupancy	No Trees Permitted	Cut Tree Permitted With Automatic Sprinkler System	Cut Tree Permitted Without Automatic Sprinkler System	Balled Tree Permitted
Ambulatory health care				X
Apartment buildings		Within unit	Within unit	X
Assembly				X
Board and care				X
Business		X		X
Day-care		X		X
Detention and correctional	X			
Dormitories			X**	X
Educational				X
Health care				X
Hotels				X
Industrial		X	X	X
Lodging and rooming		X		X
Mercantile		X		X
Storage		X	X	X

** Cut trees in dwelling units that are associated with supervisory personnel in dormitory occupancies are permitted subject to the approval of the AHJ.

(Amd) SECTION 807
DECORATIVE MATERIALS AND TRIM AND ARTIFICIAL DECORATIVE
VEGETATION IN BUILDINGS

(Amd) SECTION 808
FURNISHINGS AND OTHER UPHOLSTERED FURNITURE AND MATTRESSES OR
DECORATIVE MATERIALS IN BUILDINGS

C H A P T E R 9
FIRE PROTECTION AND LIFE SAFETY SYSTEMS

(Amd) **901.3 Permits.** A permit shall be required as set forth in Section 105.5.

(Amd) **901.5 Installation acceptance testing.** Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other *fire protection systems* and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as *approved* by the *fire code official*. The *fire code official* shall be notified before any required acceptance testing. Testing shall be conducted in the presence of the *fire code official* or his or her representative at the expense of the owner or owner's representative.

(Amd) **901.6 Inspection, testing and maintenance.** Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Non-required *fire protection systems* and equipment shall be inspected, tested and maintained or removed. The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency(cies) shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Add) **901.6.1.1 Maintenance of NFPA 13D systems.**

(Add) **901.6.1.1.1 Monthly maintenance.** A minimum monthly maintenance program shall include:

- (1) Visually inspecting all sprinklers to ensure against obstruction of spray.

- (2) Inspecting all valves to ensure they are open.
- (3) Checking the pressure of air used with dry systems.
- (4) Checking the water level in storage tanks.

(Add) **901.6.1.1.2 Quarterly maintenance.** A minimum quarterly maintenance program shall include:

- (1) Testing of all water flow alarms.
- (2) Testing of the alarm system.

(Add) **901.6.1.1.3 Sprinkler Replacement.** Operated or damaged sprinklers shall be replaced with sprinklers having the same performance characteristics as the original equipment.

(Add) **901.6.1.1.4 Painted Sprinklers.** Any sprinklers that have been painted outside the factory shall be replaced with a new listed sprinkler.

(Amd) **901.7 Systems out of service.** Where a required *fire protection system* is out of service for more than 4 hours in a 24-hour period, the fire department and the *fire code official* shall be notified immediately and, where required by the *fire code official*, the building shall be either evacuated or an *approved* fire watch shall be provided for all occupants left unprotected by the shut down until the *fire protection system* has been returned to service. Where utilized, fire watches shall be provided with not less than one *approved* means for notification of the fire department. The only duty of the fire watch shall be to perform constant patrols of the building and keep watch for fires.

Exception: Facilities with an *approved* notification and impairment management program. The notification and impairment program for water-based *fire protection systems* shall comply with NFPA 25.

(Add) **901.11 Ceiling tiles and ceiling assemblies.** Where automatic sprinklers or automatic fire detection devices are installed, ceiling tiles and ceiling assemblies necessary for the proper actuation of the fire protection devices shall be maintained.

(Amd) **903.1.1 Alternative protection.** In any occupancy where the character of fuel for fire is such that extinguishment or control of fire is accomplished by a type of alternative automatic extinguishing system complying with Section 904, such alternative system shall be permitted in lieu of an automatic sprinkler system and shall be installed in accordance with the applicable standard and *approved* by the *fire code official*.

(Amd) **903.2.1.2 Group A-2.** An *automatic sprinkler system* shall be provided for *fire areas* containing Group A-2 occupancies and throughout all stories from the Group A-2 occupancy to and including the levels of exit discharge serving that occupancy where one of the following conditions exists:

1. The *fire area* exceeds 5,000 square feet (464.5 m²).

Exception: Existing restaurants in existing non-sprinklered buildings that were designated Use Group A-3 under a previous edition of the

Connecticut State Building Code that undergo addition, alteration or change of occupancy that results in an increase in the restaurant's fire area provided the proposed fire area does not exceed 12,000 square feet (1,115 m²).

2. The *fire area* has an *occupant load* of 300 or more or where the occupant load exceeds 100 or more in the following assembly occupancies:
 - a. *Dance halls*
 - b. *Discotheques*
 - c. *Night clubs*
 - d. Assembly occupancies with festival seating.
3. The *fire area* is located on a floor other than a *level of exit discharge* serving such occupancies.

(Add) **903.2.3.1. Statutory requirements.** An *automatic sprinkler system* shall be provided in Group E occupancies pursuant to section 29-315 of the Connecticut General Statutes.

(Amd) **903.2.7 Group M.** An *automatic sprinkler system* shall be provided throughout buildings containing a Group M occupancy where one or more of the following conditions exists:

1. A Group M *fire area* exceeds 12,000 square feet (1,115 m²).
2. A Group M *fire area* is located more than three stories above grade plane.
3. The combined area of all Group M *fire areas* on all floors, including any mezzanines, exceeds 24,000 square feet (2,230 m²).
4. Throughout stories below the *level of exit discharge* where such stories have an area exceeding 2,500 square feet (232 m²) and are used for the sale, storage or handling of combustible goods or merchandise.
5. In Group M occupancies storage rooms containing consumer fireworks, regardless of size, in a new or existing permanent store shall be protected with an *automatic sprinkler system* installed in accordance with NFPA 13 or separated from the retail sales area by a fire barrier having a fire resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic feet, including packaging. Such storage shall be segregated into areas of 1,200 cubic feet or less, and separated by a minimum of 4 feet of clear space.
6. In Group M occupancies, the total quantity of sparklers and fountains on hand either displayed or in storage shall not exceed 227.2 lb. (gross) [103 kg (gross)], including packaging or 1,000 lb. (gross) [454 kg (gross)] in a building protected throughout with an approved *automatic sprinkler system* installed in accordance with NFPA 13. A quantity in excess of these amounts is subject to approval by the State Fire Marshal.

(Amd) **903.2.8 Group R.** An *automatic sprinkler system* installed in accordance with Section 903.3 shall be provided throughout all newly constructed buildings with a Group

R *fire area* or in existing buildings that have a Group R *fire area* newly introduced by change of occupancy, occupancy group designation or by an addition.

Exceptions:

1. Group R-1 bed and breakfast establishments.
2. In existing buildings four stories or less in height containing not more than four dwelling units where dwelling units are added to an existing Group R use that does not involve a physical increase in the height or area of the building and where each dwelling unit has either:
 - 2.1 An *exit* door directly to the exterior at a *level of exit discharge*,
 - 2.2 Direct access to an exterior *stair* serving a maximum of two *dwelling units* on the same *story*, or
 - 2.3 Direct access to an interior *stair* serving only that *dwelling unit* and separated from all other portions of the *building* with 1-hour fire-resistance-rated *fire barriers*.
3. Existing buildings converted prior to June 15, 1994, from a one- or two-family building or Group R-3 to Group R-2 containing not more than four *dwelling units*.
4. Horizontal additions containing newly introduced Group R occupancies that are added to existing buildings shall have an *automatic sprinkler system* installed in the addition only if the addition is completely separated from the existing building by fire barriers with a minimum 1-hour fire-resistance rating.
5. In a building with a maximum of two *dwelling units* where:
 - 5.1 Each *dwelling unit* has a direct independent exit to grade.
 - 5.2 Each exit and *dwelling unit* is separated from any non-residential occupancy by a minimum 1-hour fire-resistance-rated separation.
 - 5.3 The non-residential occupancy is protected by an automatic fire detection and alarm system with notification in each *dwelling unit*.

The use of any exceptions in this section shall not negate the requirements of Chapter 10.

(Amd) **903.2.8.4 Care facilities.** An *automatic sprinkler system* installed in accordance with Section 903.3.1.3 shall be permitted in Group R-4 care facilities with sixteen or fewer residents when all of the following conditions are met:

1. The facility is not in a building containing mixed occupancies,
2. The building in which the facility is located is limited to two stories above grade plane and 40 feet (12.2 m) in height,
3. The *automatic sprinkler system* has a minimum 30-minute water supply,
4. All habitable, enclosed, usable areas and closets shall be sprinklered,
5. Facilities with more than eight residents shall be treated as two-family dwellings with regard to water supply, and

6. The *automatic sprinkler system* is provided with valve supervision by one of the following methods:

6.1. A single listed control valve that shuts off both domestic and *automatic sprinkler system* water supply and a separate valve that shuts off the domestic system only.

6.2. Electrical supervision connected to the facility's fire alarm system.

6.3. Valve closure that causes the sounding of an audible alarm audible throughout the premises.

(Amd) **903.2.11 Specific building areas and hazards.** In all occupancies other than Group U, an *automatic sprinkler system* shall be installed for building design or hazards in the locations set forth in Sections 903.2.11.1 to 903.2.11.7, inclusive.

(Add) **903.2.11.7 Additional statutory requirements.** Pursuant to section 29-315 of the Connecticut General Statutes, automatic fire extinguishing systems shall be installed on each floor of any building or structure to be built more than four stories tall and to be used for human occupancy and in other occupancies as required by the State Fire Marshal in the interest of safety because of special occupancy hazards.

(Amd) **903.3.1.1.1 Exempt locations.** Automatic sprinklers shall not be required in the following rooms or areas where such rooms or areas are protected with an *approved* automatic fire detection system in accordance with Section 907.2 that will respond to visible or invisible particles of combustion. Sprinklers shall not be omitted from any room merely because it is damp, of *fire-resistance-rated construction* or contains electrical equipment.

1. Generator and transformer rooms separated from the remainder of the building by walls and floor/ceiling or roof/ceiling assemblies having a *fire-resistance-rating* of not less than 2 hours.
2. Fire service access elevator machine rooms and machinery spaces.
3. Machine rooms, machinery spaces, control rooms and control spaces associated with occupant evacuation elevators designed in accordance with Section 3008 of the 2021 *International Building Code* portion of the Connecticut State Building Code.

(Add) **903.3.1.1.3 Vertical openings.** Closely spaced sprinklers and draft stops are not required around floor openings permitted to be unenclosed by this code unless the closely spaced sprinklers and draft stops are being utilized in lieu of an enclosure as specified by Section 712.1.3.1 of the 2021 *International Building Code* portion of the Connecticut State Building Code.

(Add) **903.3.5.3 Water authority approval.** Unless served by a private well of sufficient capacity or other approved source, domestic service shall be permitted to provide the

water supply for the automatic sprinkler system only upon written approval of the water authority supplying such domestic service.

(Amd) **904.1 General.** Automatic fire-extinguishing systems, other than *automatic sprinkler systems*, shall be designed, installed, inspected, tested and maintained in accordance with the provisions of this section and the applicable referenced standards listed in Chapter 80. Where other fire protection systems are required to be installed by the provisions of this code or are installed with the approval of the AHJ as an alternative or equivalency or by a condition of a modification, the design and installation of the system shall comply with the appropriate standards listed in Chapter 80. The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of a system and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiency shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Add) **905.2.1 Piping design.** The riser piping, supply piping and the water service piping shall be sized to maintain a residual pressure of at least 100 pounds per square inch (psi) (690 kPa) at the topmost outlet of each riser while flowing the minimum quantities of water specified based upon a pressure of 150 psi (1035 kPa) available at the fire department connection.

Exception: In buildings equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or Section 903.3.1.2 and where the highest floor level is not more than 75 feet above the lowest level of fire department vehicle access, Class I standpipes shall have an automatic or manual-wet supply.

SECTION 906 PORTABLE FIRE EXTINGUISHERS

(Amd) **906.1 Where required.** Portable fire extinguishers shall be installed and maintained in accordance with NFPA 10 in all of the following locations:

1. In Group A, B, E, F, H, I, M, R-1, R-1 Bed and Breakfast (in the kitchen), R-2, R-4, and S occupancies.

Exceptions:

1. In Group R-2 occupancies that are classified as apartment or dormitory occupancy.
2. In storage areas of Group S occupancies where forklift, powered industrial truck or powered cart operators are the primary occupants, fixed extinguishers, as specified in NFPA 10, shall not be required if all of the following requirements are satisfied:

2.1. Use of vehicle-mounted extinguishers shall be *approved* by the *fire code official*.

2.2. Each vehicle shall be equipped with a 10-pound, 40A:80B:C extinguisher affixed to the vehicle using a mounting bracket *approved* by the extinguisher manufacturer or the *fire code official* for vehicular use.

2.3. Not less than two spare extinguishers of equal or greater rating shall be available on-site to replace a discharged extinguisher.

2.4. Vehicle operators shall be trained in the proper operation, use and inspection of extinguishers.

2.5. Inspections of vehicle-mounted extinguishers shall be performed daily.

2. Within 30 feet (9,144 mm) distance of travel from commercial cooking equipment and from domestic cooking equipment in Group I-1 and Group I-2, Condition 1.

3. In areas where *flammable* or *combustible liquids* are stored, used or dispensed.

4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 3316.1.

5. Where required by the sections indicated in Table 906.1.

6. Special-hazard areas, including, but not limited to, laboratories, computer rooms and generator rooms, where required by the *fire code official*.

7. In all occupancies, outside and immediately adjacent to the entrance to all special hazardous areas except general storage areas. If the only entrance to a special hazardous area is from the exterior of the building, the fire extinguisher may be located just inside the entrance door.

8. New and existing mercantile occupancies selling sparklers and fountains shall have a minimum of two dedicated 2-A water fire extinguishers at the location of the sparklers and fountains.

Exception: Portable fire extinguishers are not required at normally unmanned Group U occupancy buildings or structures where a portable fire extinguisher suitable to the hazard of the location is provided on the vehicle of visiting personnel.

(Del) **906.2.1 Certification of service personnel for portable fire extinguishers.**
Delete section.

(Amd) **907.2.7.1 Occupant notification.** During times that the building is occupied, the initiation of a signal from a manual fire alarm box shall not be required to activate the alarm notification appliances when an alarm signal is activated at a constantly attended location from which evacuation instructions shall be initiated over an emergency voice/alarm communication system installed in accordance with Section 907.5.2.2.

(Add) **907.2.7.2 Staged evacuation/selective occupant notification.** Where *approved* by the authority having jurisdiction and where total evacuation of occupants is impractical due to building configuration, only occupants in the affected zones shall be initially notified, and provisions shall be made to selectively notify occupants in other zones to afford orderly evacuation of the entire building. When selective occupant notification is utilized, the portion of the building that does not receive the initial notification of alarm shall be separated from areas of immediate emergency and initial evacuation by construction having a fire resistance rating of at least 1 hour or other features approved by the authority having jurisdiction.

(Amd) **907.2.8.2 Automatic smoke detection system.** An automatic smoke detection system that activates the occupant notification system in accordance with Section 907.5 shall be installed throughout all interior *corridors* serving *sleeping units*.

Exceptions:

1. In buildings that do not have interior *corridors* serving *sleeping units* and where each *sleeping unit* has a means of egress door opening directly to an exit or to an exterior exit access that leads directly to an exit.
2. In Group R-1 bed and breakfast establishments. (See Section 907.2.11.1.1.)

(Amd) **907.2.9.1 Manual fire alarm system.** A manual fire alarm system that activates the occupant notification system in accordance with Section 907.5 shall be installed in Group R-2 occupancies where:

1. Any *dwelling unit* or *sleeping unit* is located three or more stories above the lowest *level of exit discharge*;
2. Any *dwelling unit* or *sleeping unit* is located more than one story below the *highest level of exit discharge* of exits serving the *dwelling unit* or *sleeping unit*, or
3. The building contains more than 11 *dwelling units* or *sleeping units*.

Exceptions:

1. In buildings not over two stories in height where all *dwelling units* or *sleeping units* and contiguous attic and crawl spaces are separated from each other and public or common areas by at least 1-hour fire partitions and each *dwelling unit* or *sleeping unit* has an exit directly to a *public way*, egress court or yard.
2. In buildings equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2 where the occupant notification appliances will automatically activate throughout the notification zones upon a sprinkler water flow.
3. In buildings that do not have interior *corridors* serving *dwelling units* or *sleeping units* and are protected by an *approved automatic sprinkler system* installed in accordance with Section 903.3.1.1 or 903.3.1.2, provided dwelling units or sleeping units either have a means of egress door opening directly to an exterior *exit access* that leads directly to the *exits* or are served by open-ended *corridors* designed in accordance with Section 1027.6, Exception 3.

(Amd) **907.2.9.3 Group R-2 college and university buildings and primary or secondary school buildings.** An automatic smoke detection system that activates the occupant notification system in accordance with Section 907.5 shall be installed in Group R-2 occupancies operated by a college or university, or primary or secondary schools for student or staff housing in all of the following locations:

1. Common spaces outside of dwelling units and sleeping units.
2. Laundry rooms, mechanical equipment rooms and storage rooms.
3. All interior *corridors* serving *sleeping units* or *dwelling units*.

Exception: An automatic smoke detection system is not required in buildings that do not have interior *corridors* serving *sleeping units* or *dwelling units* and where each *sleeping unit* or *dwelling unit* either has a *means of egress* door opening directly to an exterior *exit access* that leads directly to an *exit* or a *means of egress* door opening directly to an *exit*. Required smoke alarms in *dwelling units* and *sleeping units* in Group R-2 occupancies operated by a college or university for student or staff housing shall be interconnected with the fire alarm system in accordance with NFPA 72.

(Add) **907.2.11.1.1 Group R-1 bed and breakfast establishments.** An *approved* household fire warning system in accordance with the requirements of NFPA 72, consisting of a control unit with smoke detectors, a manual fire alarm box on each floor and occupant notification shall be installed in all Group R-1 bed and breakfast establishments. A heat detector shall be installed in the kitchen.

(Add) **907.2.11.2.1 Group R-4.** In Group R-4 occupancies, single or multiple-station smoke alarms shall be installed in living rooms, dens, day rooms and similar spaces in addition to the locations required by Section 907.2.11.2.

(Add) **907.2.11.2.2 Alterations and additions.** When alterations or additions requiring a permit occur in Group R-2, R-3 and R-4 occupancies, or when one or more sleeping rooms are added or created in existing *dwelling units*, the entire *dwelling unit* shall be provided with smoke detectors located as required for new *dwelling units*. Such smoke detectors within existing spaces may be battery operated and are not required to be dual-powered or interconnected unless other remodeling considerations require removal of wall and ceiling coverings which would facilitate concealed interconnected wiring.

(Add) **907.2.11.2.2.1 During construction.** Pursuant to section 29-315b of the Connecticut General Statutes, whenever a single-family or two-family dwelling is occupied during interior alterations or additions requiring a building permit, the temporary installation of battery-operated smoke alarms shall be required in the vicinity of such alterations or additions for the duration of construction activities. A combined smoke and carbon monoxide alarm may be installed to comply with Section 915.8 and this section.

(Add) **907.2.11.2.3 Group I-4 and Group E day care facilities.** Single- or multiple-station smoke detectors shall be installed and maintained in all day care facilities in the following locations:

1. In each story in front of doors to the stairways;
2. In the *corridors* of all floors occupied by the day care occupancy; and
3. In lounges, recreation areas and sleeping rooms in the day care occupancy.

Exception: Day care facilities housed in one room.

(Add) **907.4.3.2 Ceiling tiles and ceiling assemblies.** Where automatic fire detectors are installed, ceiling tiles and ceiling assemblies necessary for the proper actuation of the fire protection device in accordance with NFPA 72 shall be maintained.

(Add) **907.6.6.1.1 Automatic telephone-dialing devices.** Automatic telephone-dialing devices used to transmit an emergency alarm shall comply with the requirements of subsection (c) of section 28-25b of the Connecticut General Statutes.

(Del) **907.9 Where required in existing buildings and structures.** Delete section.

(Amd) **912.2 Location.** With respect to hydrants, driveways, buildings and landscaping, fire department connections shall be so located that fire apparatus and hoses connected to supply the system will not obstruct access to the buildings for other fire apparatus. The location of fire department connections shall be *approved* by the *fire code official* in conjunction with the fire chief.

(Amd) **912.2.1 Visible location.** Fire department connections shall be located on the street side of buildings or facing *approved* fire apparatus access roads, fully visible and recognizable from the street, fire apparatus access road or nearest point of fire department vehicle access or as otherwise *approved* by the *fire code official* in conjunction with the fire chief.

(Amd) **912.2.2 Location signage.** On buildings, wherever the fire department connection is not visible to approaching fire apparatus, the fire department connection shall be indicated by an *approved* sign mounted on the street front or on the side of the building. Such sign shall have the letters "FDC" not less than 6 inches (152 mm) high and words in letters not less than 2 inches (51 mm) high or an arrow to indicate the location. Such signs shall be subject to the approval of the *fire code official* in conjunction with the fire chief.

(Add) **913.2.3 Electric fire pumps.** Buildings provided with standby electrical power for the purpose of continuing operations or occupancy shall provide standby power in accordance with Article 701 of the 2020 NFPA 70, *National Electrical Code*, portion of the Connecticut State Building Code for any electric fire pump installed to provide an

adequate water supply or minimum operating pressure to a required automatic sprinkler system. Such system shall be in accordance with Section 1203.

(Amd) **915.1 General.** Carbon monoxide detection and warning equipment shall be installed in new buildings and occupancies in accordance with Sections 915.1 to 915.6, inclusive. When alterations or additions requiring a permit occur in existing buildings, carbon monoxide detection and warning equipment shall be provided in accordance with Section 915.7.

(Amd) **915.1.1 Where required.** Carbon monoxide detection shall be provided in the following locations:

1. Group E occupancies in accordance with Section 915.2.3
2. Group I-1, I-2, I-4 and R occupancies where any of the conditions in Sections 915.1.2 through 915.1.6 exist.

(Amd) **915.1.2 Fuel-burning appliances and fuel-burning fireplaces.** Carbon monoxide detection and warning equipment shall be provided in *dwelling units* and *sleeping units* that contain a fuel-burning appliance or fuel-burning fireplace.

(Amd) **915.1.3 Fuel-burning forced-air furnaces.** Carbon monoxide detection and warning equipment shall be provided in *dwelling units* and *sleeping units* served by a fuel-burning, forced-air furnace.

Exception: Carbon monoxide detection and warning equipment shall not be required in *dwelling units* and *sleeping units* where carbon monoxide detection is provided in the first room or area served by each main duct leaving the furnace, and the carbon monoxide alarm signals are automatically transmitted to an *approved* location.

(Amd) **915.1.4 Fuel-burning appliances outside of dwelling units and sleeping units.** Carbon monoxide detection and warning equipment shall be provided in *dwelling units* and *sleeping units* located in buildings that contain fuel-burning appliances or fuel-burning fireplaces.

Exceptions:

1. Carbon monoxide detection and warning equipment shall not be required in *dwelling units* and *sleeping units* without communicating openings between the fuel-burning appliance or fuel-burning fireplace and the *dwelling unit* or *sleeping unit*.
2. Carbon monoxide detection and warning equipment shall not be required in *dwelling units* and *sleeping units* where a carbon monoxide detection and warning equipment is provided in one of the following locations:
 - 2.1. In an *approved* location between the fuel-burning appliance or fuel-burning fireplace and the *dwelling unit* or *sleeping unit*.

2.2. On the ceiling of the room containing the fuel-burning appliance or fuel-burning fireplace.

(Amd) **915.1.5 Private garages.** Carbon monoxide detection and warning equipment shall be provided in *dwelling units* and *sleeping units* in buildings with attached private garages.

Exceptions:

1. Where there are no communicating openings between the private garage and the *dwelling unit* or *sleeping unit*.
2. In *dwelling units* and *sleeping units* located more than one story above or below a private garage.
3. Where the private garage connects to the building through an *open-ended corridor*.
4. Where carbon monoxide detection and warning equipment is provided in an *approved* location between openings to a private garage and *dwelling units* or *sleeping units*.

(Amd) **915.2.3 Group E occupancies.** Carbon monoxide detection and warning equipment shall be provided in the locations specified in Sections 915.2.3.1 and 915.2.3.2.

Exception: Group E rooms with cooking appliances, laboratories and maintenance spaces.

(Add) **915.2.3.1. Locations.** Carbon monoxide detectors shall be located as follows:

1. On the ceilings of rooms containing permanently installed fuel-burning heating equipment.
2. Centrally located within the first room or area served by the first air supply register by each main duct leaving a fuel-burning, forced-air furnace.

(Add) **915.2.3.2 Signage.** A sign shall be provided at all entrances to such rooms indicating that carbon monoxide detectors are located within the space.

(Add) **915.4.5 Interconnection of alarms.** Carbon monoxide alarms shall be interconnected in accordance with Section 29.7.2 of NFPA 72.

(Add) **915.5.4 Group E alarm notification.** Carbon monoxide detectors shall be connected to the building fire alarm signaling system as a separate zone or zones. Such alarms shall activate a supervisory signal at the main control unit and any remote annunciators. Such alarms shall not activate the building evacuation alarm.

(Amd) **915.6 Maintenance.** Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable, begin producing end-of-life signals or have reached the manufacturer's replacement date shall be replaced.

(Add) **915.7 Alterations and additions.** When *alterations* or *additions* requiring a *permit* occur to *buildings* with Group R-3 and R-4 occupancies and to Group R-1 bed and breakfast establishments, or when one or more sleeping rooms are added or created in such occupancies, the entire occupancy shall be provided with carbon monoxide detectors located as required for new construction. The carbon monoxide detectors shall have a power source in accordance with Section 915.4.1.

When *alterations* or *additions* requiring a *permit* occur to *buildings* with Group I-1, I-2, I-4, R-1 other than bed and breakfast establishments, R-2 and E occupancies, or when one or more sleeping rooms are added or created in such occupancies, only the work area shall be provided with carbon monoxide detectors located as required for new construction. The carbon monoxide detectors shall have a power source in accordance with Section 915.4.1. For the purpose of this section, “work area” is defined as that portion or portions of a *building* consisting of all reconfigured spaces as indicated on the *construction documents*. “Work area” excludes other portions of the *building* where incidental work entailed by the intended work must be performed and portions of the *building* where work not initially intended by the *owner* is specifically required by this code.

Exceptions:

1. The carbon monoxide detectors may be battery operated or plug-in and are not required to be interconnected when other remodeling considerations do not require the removal of the appropriate wall or ceiling coverings to facilitate concealed interconnected wiring.
2. Alterations to the exterior surfaces of existing buildings including, but not limited to, reroofing, re-siding, window replacement and the construction of decks without roofs, are exempt from the requirements of this section.
3. Carbon monoxide detectors shall not be required in buildings not containing a fuel-burning appliance, fireplace or attached garage.

(Add) **915.8 During construction.** Pursuant to section 29-315b of the Connecticut General Statutes, whenever a single-family or two-family dwelling is occupied during interior alterations or additions requiring a building permit where a fuel-burning appliance, fireplace or attached garage exists, the temporary installation of battery-operated carbon monoxide alarms shall be required in the vicinity of such alterations or additions for the duration of construction activities. Combined smoke and carbon monoxide alarms may be installed to comply with Section 907.2.11.2.2.1 and this section.

C H A P T E R 1 0

M E A N S O F E G R E S S

(Amd) **1001.1 General.** Buildings or portions thereof shall be provided with a *means of egress* system as required by this chapter. The provisions of this chapter shall control the design, construction and arrangement of *means of egress* components required to provide an approved *means of egress* from structures and portions thereof.

Exception: Pursuant to section 29-292 of the Connecticut General Statutes, detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories above grade plane in height with a separate means of egress and their accessory structures shall comply with the *International Residential Code*.

(Add) **1003.8 Security device.** Any security device or system that emits any medium that could obscure a means of egress in any building, structure or premises shall be prohibited.

(Amd) **1004.5 Areas without fixed seating.** The number of occupants shall be computed at the rate of one occupant per unit of area as prescribed in Table 1004.5. For areas without *fixed seating*, the *occupant load* shall not be less than the number determined by dividing the floor area under consideration by the *occupant load* factor assigned to the function of the space as set forth in Table 1004.5. Where an intended function is not listed in Table 1004.5, the *fire code official* shall establish a function based on a listed function that most nearly resembles the intended function.

(Amd) **1005.3.1 Stairways.** The capacity, in inches (mm), of *means of egress stairways* shall be calculated by multiplying the *occupant load* served by such *stairway* by a *means of egress* capacity factor of 0.3 inch (7.6 mm) per occupant. Where *stairways* serve more than one story, only the *occupant load* of each story considered individually shall be used in calculating the required capacity of the *stairways* serving that story.

Exceptions:

1. Facilities with *smoke-protected assembly seating* shall be permitted to use the capacity factors in Table 1030.6.2 indicated for stepped *aisles* for *exit access* or *exit stairways* where the entire path for *means of egress* from the seating to the *exit discharge* is provided with a smoke control system complying with Section 909.
2. Facilities with *open-air assembly seating* shall be permitted to the capacity factors in Section 1030.6.3 indicated for stepped *aisles* for *exit access* or *exit stairways* where the entire path for *means of egress* from the seating to the *exit discharge* is open to the outdoors.

(Amd) **1005.3.2 Other egress components.** The capacity, in inches (mm), of *means of egress* components other than *stairways* shall be calculated by multiplying the *occupant load* served by such component by a *means of egress* capacity factor of 0.2 inch (5.1 mm) per occupant.

Exceptions:

1. Facilities with *smoke-protected assembly seating* shall be permitted to use the capacity factors in Table 1030.6.2 indicated for level or ramped *aisles* for *means of egress* components other than *stairways* where the entire path for *means of*

egress from the seating to the *exit discharge* is provided with a smoke control system complying with Section 909.

2. Facilities with *open-air assembly seating* shall be permitted to the capacity factors in Section 1030.6.3 indicated for level or ramped aisles for *means of egress* components other than stairways where the entire path for *means of egress* from the seating to the *exit discharge* is open to the outdoors.

(Amd) **1006.1 General.** The number of *exits* or *exit access doorways* required within the *means of egress* system shall comply with the provisions of Section 1006.2 for spaces, including *mezzanines*, and Section 1006.3 for stories or occupied roofs.

Exception: Buildings of Group R-1 bed and breakfast establishments shall only be required to have one exit.

(Add) **1006.2.2.7 Group I-4 Day care means of egress.** Group I-4 facilities, rooms or spaces where care is provided for more than 10 children who are 3 years of age or younger shall have access to not less than two *exits* or *exit access doorways*.

(Amd) **1008.2 Illumination required.** The *means of egress from a room or space*, including the exit discharge, shall be illuminated at all times the building space served by the means of egress is occupied.

Exceptions:

1. Occupancies in Group U.
2. *Aisle accessways* in Group A.
3. Within *dwelling units* and *sleeping units* in Groups R-1, R-2 and R-3.
4. Within *sleeping units* of Group I occupancies.
5. In Group R-1 bed and breakfast establishments when illumination of the *means of egress* is initiated upon initiation of a fire alarm.

(Add) **1008.2.4 Arrangement of illumination.** Required illumination shall be arranged so that the failure of any single lamp does not result in an illumination level of less than 0.2 foot-candle (2.15 lux) at the floor level.

(Amd) **1008.3.3 Rooms and spaces.** In the event of power supply failure, an emergency electrical system shall automatically illuminate all of the following areas:

1. Electrical equipment rooms.
2. Fire command centers.
3. Fire pump rooms.
4. Generator rooms.
5. Public restrooms with an area greater than 300 square feet (27.87 m²).

6. Means of egress components, other than those within sleeping rooms, of Group R-1 Bed and breakfast establishments.

(Add) **1008.3.6 Activation.** The emergency *means of egress* illumination system shall be arranged to provide the required illumination automatically in the event of any interruption of normal lighting due to any of the following:

1. Failure of a public utility or other outside electrical power supply.
2. Opening of a circuit breaker or fuse.
3. Manual acts including accidental opening of a switch controlling normal lighting facilities.

(Add) **1010.1.1.2 Bed and breakfast establishments.** Doors within and accessing Group R-1 bed and breakfast establishments shall have a minimum clear width of 28 inches (711 mm). Doors within and accessing bathrooms shall have a minimum clear width of 24 inches (610 mm).

(Amd) **1010.1.2.1 Direction of swing.** Side-hinged swinging doors, pivoted doors, or balanced doors shall swing in the direction of egress travel where serving a room or area containing an occupant load of 50 or more persons, an exit enclosure (unless the door serves an individual living/dwelling unit that opens directly into an exit enclosure) or a Group H occupancy.

(Add) **1010.2.1.1 Bathroom doors.** In Group R-4 occupancies, Group I-2 child care facilities, and Group I-4 day care facilities, bathroom doors that latch in the closed position shall be capable of being unlocked from the ingress side.

(Amd) **1011.5.2 Riser height and tread depth.** *Stair* riser heights shall be 7 inches (178 mm) maximum and 4 inches (102 mm) minimum. The *stair* riser height shall be measured vertically between the *nosings* of adjacent treads or between the *stairway* landing and the adjacent tread. Rectangular tread depth shall be 11 inches (279 mm) minimum measured horizontally between the vertical planes of the foremost projection of adjacent treads and at right angle to the tread's *nosing*. *Winder* treads shall have a minimum tread depth of 11 inches (279 mm) between the vertical planes of the foremost projection of adjacent treads at the intersections with the walkline and a minimum tread depth of 10 inches (254 mm) within the clear width of the *stair*.

Exceptions:

1. *Alternating tread devices* in accordance with Section 1011.14.
2. Ships ladders in accordance with Section 1011.15.
3. *Spiral stairways* in accordance with Section 1011.10.
4. Aisle stairs in assembly seating areas where the *stair* pitch or slope is set, for sightline reasons, by the slope of the adjacent seating area in accordance with Section 1030.14.

5. In Group R-1 bed and breakfast occupancies; Group R-3 occupancies; within *dwelling units* in Group R-2 occupancies; and in Group U occupancies that are accessory to Group R-3 occupancies, or accessory to individual *dwelling units* in Group R-2 occupancies; the maximum riser height shall be 8 inches (203.2 mm) and the minimum tread depth shall be 9 inches (229 mm); the minimum *winder* tread depth at the walkline shall be 10 inches (254 mm); and the minimum *winder* tread depth shall be 6 inches (152 mm). A *nosing* not less than 3/4 inch (19.1 mm) but not more than 1-1/4 inches (32 mm) shall be provided on *stairways* with solid risers where the tread depth is less than 11 inches (279 mm).
6. The riser height and tread depth of existing *stairways* in buildings undergoing addition, alteration, repair, relocation or change of occupancy that involve the existing *stairways* shall be permitted to remain, provided the greatest riser height within any flight of *stairs* shall not exceed the smallest by 3/8 inch (9.5 mm) and the greatest tread depth within any flight of stairs shall not exceed the smallest by 3/8 inch (9.5mm) and the greatest tread depth within any flight of *stairs* shall not exceed the smallest by 3/8 inch (9.5 mm).
7. See Section 503.1 of the *International Existing Building Code* for the replacement of existing *stairways*.
8. In Group I-3 facilities, *stairways* providing access to guard towers, observation stations and control rooms, not more than 250 square feet (23 m²) in area, shall be permitted to have a maximum riser height of 8 inches (203 mm) and a minimum tread depth of 9 inches (229 mm).

(Amd) **1011.5.3 Winder treads.** *Winder* treads are not permitted in *means of egress stairways* except within a *dwelling unit* and within existing detached one- and two-family dwellings undergoing a change of occupancy to Group R-1 bed and breakfast establishments.

Exceptions:

1. Curved *stairways* in accordance with Section 1011.9.
2. *Spiral stairways* in accordance with Section 1011.10.

(Amd) **1011.7.2 Outdoor conditions.** Outdoor *stairways* and outdoor approaches to *stairways* shall be designed so that water will not accumulate on walking surfaces. In other than occupancies in Group R-3, and occupancies in Group U that are accessory to an occupancy in Group R-3, treads, platforms and landings that are part of exterior *stairways* shall be protected to prevent the accumulation of snow and ice.

(Amd) **1011.11 Handrails.** *Flights of stairways* shall have *handrails* on each side and shall comply with Section 1014. Where glass is used to provide the *handrail*, the *handrail* shall also comply with Section 2407 of the 2021 *International Building Code* portion of the Connecticut State Building Code.

Exceptions:

1. *Flights of stairways* within *dwelling units* and Group R-1 bed and breakfast establishments and *spiral stairways* are permitted to have a *handrail* on one side only.
2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change in elevation is greater than what is required for a landing do not require *handrails*.
3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require *handrails*.
4. Changes in room elevations of three or fewer risers within *dwelling units* and *sleeping units* in Group R-1 bed and breakfast establishments and Groups R-2 and R-3 occupancies do not require *handrails*.
5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a *stairway*, *handrails* shall not be required on the *stairway*, provided that all of the following criteria are met:
 - 5.1. The *stairway* contains not more than two risers.
 - 5.2. A handhold, positioned horizontally or vertically, is located on one side of the *stairway* adjacent to the top landing.
 - 5.3. The handhold is located not less than 34 inches (864 mm) and not more than 42 inches (1067 mm) above the bottom landing of the *stairway*.
 - 5.4. The handhold gripping surface complies with Section 1014.3 and is not less than 4.5 inches (114 mm) in length.

(Add) **1013.1.1 Accessible exits.** Where *exit* signs are required by Section 1013.1 of this code, *accessible exit* doors at the *level of exit discharge* that lead directly to *accessible* paths of *exit discharge* shall additionally be marked by the International Symbol of Accessibility. Such symbol shall be not less than 6 inches (152 mm) high and shall be incorporated into the required *exit* sign or shall be located directly adjacent to it. Such symbol shall meet the requirements of Section 1013.

(Amd) **1013.2 Low-level exit signs.** Where *exit* signs are required from a room or space in Group R-1 occupancies, Group I-2 occupancies, and Group R-2 occupancies by Section 1013.1, additional low-level *exit* signs shall be provided at doors within *exit access corridors* serving *guest rooms* in Group R-1 occupancies, patient and client sleeping areas of Group I-2 occupancies and sleeping areas and *dwelling units* in Group R-2 occupancies and shall comply with Section 1013.5.

The bottom of the sign shall be not less than 10 inches (254 mm) nor more than 12 inches (305 mm) above the floor level. The sign shall be flush mounted to the door or wall on the same plane as the door. Where mounted on the wall, the edge of the sign shall be within 4 inches (102 mm) of the door frame on the latch side.

Exception: Group R-1 bed and breakfast establishments.

(Amd) **1014.9 Intermediate handrails.** *Stairways* shall have intermediate *handrails* located in such a manner that all portions of the *stairway* width exceeding 75 inches (1,905 mm) required for *egress* capacity are within 30 inches (762 mm) of a *handrail*. On monumental *stairs*, *handrails* shall be located along the most direct path of *egress* travel.

(Amd) **1015.3 Height.** Required *guards* shall not be less than 42 inches (1,067 mm) high, measured vertically as follows:

1. From the adjacent walking surfaces including adjacent fixed seating.
2. On *stairways*, and stepped *aisles*, from the line connecting the leading edges of the tread *nosings*.
3. On *ramps* and ramped *aisles*, from the *ramp* surface at the *guard*.

Exceptions:

1. For occupancies in Group R-3 not more than three stories above grade in height, and within individual *dwelling units* in occupancies in Group R-2 not more than three stories above grade in height with separate *means of egress*, required *guards* shall not be less than 36 inches (914 mm) in height measured vertically above the adjacent walking surfaces.
2. For occupancies in Group R-3, and within individual *dwelling units* in occupancies in Group R-2, *guards* on the open sides of *stairs* shall have a height not less than 34 inches (864 mm) measured vertically from a line connecting the leading edges of the treads.
3. For occupancies in Group R-1 bed and breakfast establishments, Group R-3, and within individual *dwelling units* in occupancies in Group R-2, where the top of the *guard* also serves as a *handrail* on the open sides of *stairs*, the top of the *guard* shall not be less than 34 inches (864 mm) and not more than 38 inches (965 mm) measured vertically from a line connecting the leading edges of the treads.
4. For occupancies in Group R-1 bed and breakfast establishments, level *guards* shall be not less than 36 inches (914 mm) high, measured vertically above the adjacent walking surface.
5. The *guard* height in assembly seating areas shall be in accordance with Section 1030.17 as applicable.
6. Along *alternating tread devices* and ship ladders, *guards* whose top rail also serves as a *handrail* shall have a height not less than 30 inches (762 mm) and not more than 34 inches (864 mm) measured vertically from the leading edge of the device tread *nosing*.
7. In group F occupancies where *exit access stairways* serve fewer than three stories and such stairways are not open to the public, and where the top of the *guard* also serves as a *handrail*, the top of the *guard* shall be not less than 34 inches (864 mm) and not more than 38 inches (965 mm) measured vertically from a line connecting the leading edges of the treads.

(Amd) **1015.4 Opening limitations.** Required *guards* shall not have openings which allow passage of a sphere 4 inches (102 mm) in diameter from the walking surface to the required *guard* height.

Exceptions:

1. From a height of 36 inches (914 mm) to 42 inches (1067 mm), *guards* shall not have openings which allow passage of a sphere 4³/₈ inches (111 mm) in diameter.
2. The triangular openings at the open side of a *stair*, formed by the riser, tread and bottom rail shall not allow passage of a sphere 6 inches (152 mm) in diameter.
3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, *guards* shall not have openings which allow passage of a sphere 21 inches (533 mm) in diameter.
4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for *alternating tread devices* and ship ladders, *guards* shall not have openings which allow passage of a sphere 21 inches (533 mm) in diameter.
5. In assembly seating areas, *guards* required at the end of aisles in accordance with Section 1030.17.4 shall not have openings which allow passage of a sphere 4 inches (102 mm) in diameter up to a height of 26 inches (660 mm) above adjacent walking surfaces. From a height of 26 inches (660 mm) to 42 inches (1067 mm) above the adjacent walking surfaces, *guards* shall not have openings which allow passage of a sphere 8 inches (203 mm) in diameter.
6. Within individual *dwelling units* and *sleeping units* in Group R-2 and R-3 occupancies, *guards* on the open sides of *stairs* shall not have openings which allow passage of a sphere 4³/₈ inches (111 mm) in diameter.
7. In Group R-1 bed and breakfast establishments, *guards* shall have balusters or ornamental patterns such that a sphere 6 inches (152mm) in diameter cannot pass through any opening.

(Add) **1015.9 Retaining walls.** Retaining walls where the difference in height between the finished grade at the top of the wall and the finished grade at the bottom of the wall is greater than 4 feet (1219 mm) shall be provided with *guards* complying with Sections 1015.3, 1015.4 and 1607.9 when a walking surface, parking lot or driveway is located closer than 2 feet (610 mm) from the edge of the top of the retaining wall. For the purpose of this section, grass, planting beds or landscaped areas shall not be considered a walking surface.

(Amd) **1019.3 Occupancies other than Groups I-2 and I-3.** In other than Group I-2 and I-3 occupancies, floor openings containing *exit access stairways* or *ramps* that do not comply with one of the exceptions listed in this section shall be enclosed with a shaft enclosure constructed in accordance with Section 713 of the 2021 *International Fire Code* portion of the Connecticut State Building Code.

Exceptions:

1. In buildings equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1 with other than Group H or I occupancies, *exit*

access stairways and ramps serving an occupant load of less than 10 not more than one story above the level of exit discharge.

2. In Group R-1, R-2 and R-3 occupancies, *exit access stairways and ramps* connecting four stories or less serving and contained within a single residential *dwelling unit or sleeping unit or live/work unit.*
3. *Exit access stairways* serving and contained within a Group R-3 congregate residence or a Group R-4 facility are not required to be enclosed.
4. *Exit access stairways* connecting the first and second floors of Group R-1 bed and breakfast establishments. *Stairways* connecting the second and third floors in such occupancies shall be enclosed with fire separation assemblies having a fire-resistance rating of not less than 1 hour. *Stairways* connecting the basement and the first floor occupancies shall be enclosed with fire partitions having a fire-resistance rating of not less than 1/2 hour with 20-minute fire-resistance rated door assemblies. Fire-resistance assemblies at *stairways* in Group R-1 bed and breakfast establishments shall not be required to be supported by fire-resistance rated construction.
5. *Exit access stairways and ramps* within an atrium complying with the provisions of Section 404 of the 2021 *International Fire Code* Portion of the Connecticut State Building Code.
6. *Exit access stairways and ramps* in open parking garages that serve only the open parking garage.
7. *Exit access stairways and ramps* serving smoke-protected or open-air assembly seating complying with the *exit access* travel distance requirements of Section 1029.7.
8. *Exit access stairways and ramps* between the balcony, gallery or press box and the main assembly floor in occupancies such as theaters, *places of religious worship*, auditoriums and sport facilities.
9. *Stairways* serving outdoor facilities where all portions of the *means of egress* are significantly open to the outside.
10. *Exit access stairways* serving mezzanines complying with the provisions of Section 505 of the 2021 *International Fire Code* portion of the Connecticut State Building Code.
11. Exterior *exit access stairways or ramps* between occupied roofs.

(Add) **1020.1.2 Group R-1 bed and breakfast establishments.** A fire-resistance rating is not required for *corridors* in Group R-1 bed and breakfast establishments. Doors leading from guest rooms into *corridors* or hallways in Group R-1 bed and breakfast establishments shall be equipped with self-closing devices.

(Amd) **1020.2 Construction.** *Corridors* shall be *fire-resistance rated* in accordance with Table 1020.2. The *corridor* walls required to be *fire-resistance rated* shall comply with Section 708 of the *International Building Code* for *fire partitions*.

Exceptions:

1. A *fire-resistance rating* is not required for *corridors* in an occupancy in Group E where each room that is used for instruction has not less than one door opening directly to the exterior and rooms for assembly purposes have not less than one-half of the required *means of egress* doors opening directly to the exterior. Exterior doors specified in this exception are required to be at ground level.
2. A *fire-resistance rating* is not required for *corridors* contained within a *dwelling unit* or *sleeping unit* in an occupancy in Groups I-1 and R.
3. A *fire-resistance rating* is not required for *corridors* in open parking garages.
4. A *fire-resistance rating* is not required for *corridors* in an occupancy in Group B that is a space requiring only a single *means of egress* complying with Section 1006.2.
5. *Corridors* adjacent to the *exterior walls* of buildings shall be permitted to have unprotected openings on unrated *exterior walls* where unrated walls are permitted by Table 705.5 of the 2021 *International Fire Code* portion of the Connecticut State Building Code and unprotected openings are permitted by Table 705.8 of the 2021 *International Fire Code* portion of the Connecticut State Building Code.

(Amd) **TABLE 1020.2**
CORRIDOR FIRE-RESISTANCE RATING

OCCUPANCY	OCCUPANT LOAD SERVED BY CORRIDOR	REQUIRED FIRE-RESISTANCE RATING (hours)	
		WITHOUT SPRINKLER SYSTEM	WITH SPRINKLER SYSTEM ^c
H-1, H-2, H-3	All	Not Permitted	1
H-4, H-5	Greater than 30	Not Permitted	1
A, B, E, F, M, S, U	Greater than 30	1	0
R	Greater than 10	Not Permitted	0.5 ^c / 1 ^d
I-2 ^d	All	Not Permitted	0
I-1, I-3	All	Not Permitted	1 ^{b, c}
I-4	All	1 ^e	0

- a. For requirements for occupancies in Group I-2, see Sections 1407.2 and 1407.3.
- b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 1408.8.
- c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed.
- d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.

e. For Group I-4 day care facilities that satisfy Section 903.2.6, Exception 2, a corridor fire-resistance rating of zero (0) shall be permitted.

(Add) **1022.3 Group M occupancies.** In mercantile occupancies other than bulk merchandising retail buildings, if the only means of customer entrance is through one exterior wall of a building, one-half of the required egress width from the street floor shall be located in such wall. For the purpose of this section, bulk merchandising retail *building* is defined as a *building* exceeding 12,000 square feet (1115 m²) in area in which the sales area includes the storage of combustible materials on pallets, in solid piles, or in racks in excess of 12 feet (3658 mm) in storage height.

(Add) **1025.6.1 Size and location.** Luminous egress path marking systems or devices shall be sized and located in exit access corridors as prescribed by Section 1025.2.4. In exit access corridors exceeding 120 inches (3,048 mm) in width, the marking shall be provided on both sides of the corridor.

(Add) **1025.6.2 Device or system requirements.** Luminous egress path marking systems or devices shall be listed and labeled and installed in accordance with the manufacturer's installation requirements. Self-luminous and photoluminescent egress path markings shall comply with Sections 1025.4 and 1025.5. Such systems shall not incorporate arrows, chevrons, signs or alternating lighting patterns designed or intended to lead an occupant to any one specific exit in preference over another exit.

Exception: Systems incorporating arrows, chevrons, signs or alternating lighting patterns designed or intended to lead an occupant in any one specific direction shall be permitted in common paths of travel and dead end *corridors*.

(Add) **1025.6.3 Illumination.** Luminous egress path marking systems or devices shall be continuously illuminated or shall illuminate within 10 seconds of a power failure. Illumination shall be maintained for a period of not less than 90 minutes following loss of power to the corridor within which the system or device is located.

(Add) **1028.4.1 Remoteness.** Where two or more doors leading to *exit discharge* are required, a minimum of two such doors shall be placed a distance apart equal to not less than one-third of the length of the maximum overall diagonal dimension of the building served, measured in a straight line between doors. Additional doors leading to *exit discharge* shall be arranged a reasonable distance apart so that if one becomes blocked, the others will be available.

(Amd) **1030.2 Assembly main exit.** Pursuant to section 29-381a of the Connecticut General Statutes, in a building, room or space used for assembly purposes and provided with a single main entrance/*exit*, the main *exit* shall be of sufficient width to accommodate not less than two-thirds of the occupant load, but such width shall not be less than the total required width of all means of egress leading to the *exit*. This applies to Group A

occupancies that are newly constructed, have an increase in the number of occupants by addition or alteration or are created by change of occupancy. Where the building is classified as a Group A occupancy, the main *exit* shall front on at least one street or an unoccupied space of not less than 10 feet (3,048 mm) in width that adjoins a street or public way. In a building, room or space used for assembly purposes where there is no well-defined main entrance/exit or where multiple main entrances/exits are provided, exits shall be permitted to be distributed around the perimeter of the building provided the total width of egress is not less than 100 percent of the required width.

(Amd) **1031.2 Where required.** In addition to the *means of egress* required by this chapter, *emergency escape and rescue openings* shall be provided in the following occupancies:

1. Group R-2 occupancies located in stories with only one *exit* or access to only one *exit* as permitted by Tables 1006.3.4(1) and 1006.3.4(2) or utilizing an exception to 903.2.8.
2. Group R-3 and R-4 occupancies.

Basements and sleeping rooms below the fourth *story above grade plane* shall have not fewer than one *emergency escape and rescue opening* in accordance with this section.

Where *basements* contain one or more sleeping rooms, an *emergency escape and rescue opening* shall be required in each sleeping room, but shall not be required in adjoining areas of the *basement*. Such openings shall open directly into a *public way* or to a *yard* or *court* that opens to a *public way*.

Exceptions:

1. *Basements* with a ceiling height of less than 80 inches (2032 mm) shall not be required to have *emergency escape and rescue openings*.
2. *Emergency escape and rescue openings* are not required from *basements* or sleeping rooms that have an *exit* door or *exit access* door that opens directly into a *public way* or to a *yard*, *court* or exterior egress balcony that opens to a *public way*.
3. *Basements* without *habitable spaces* and having not more than 200 square feet (18.6 m²) in floor area shall not be required to have *emergency escape and rescue openings*.
4. *Storm shelters* are not required to comply with this section where the shelter is constructed in accordance with ICC 500.
5. Within individual *dwelling* and *sleeping units* in Groups R-2 and R-3, where the building is equipped throughout with an *automatic sprinkler system* installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, sleeping rooms in *basements* shall not be required to have *emergency escape and rescue openings* if the *basement* has one of the following:

5.1. One *means of egress* and one *emergency escape and rescue opening*.

5.2. Two *means of egress*.

(Add) 3. Group E occupancies. In Group E occupancies, *emergency escape and rescue openings* shall be provided in every room or space greater than 250 square feet (23.3 m²) used for classroom or educational purposes or normally subject to student occupancy.

Exceptions:

1. Buildings protected throughout by an approved automatic sprinkler system in accordance with Section 903.3.1.1.
2. Rooms or spaces that have a door leading directly to the outside of the building.

(Add) 4. Group I-4 occupancies. In Group I-4 occupancies, *emergency escape and rescue openings* shall be provided in every room or space greater than 250 square feet (23.3 m²) normally subject to client occupancy.

Exceptions:

1. Buildings protected throughout by an approved *automatic sprinkler system* in accordance with Section 903.3.1.1.
2. Rooms or spaces that have a door leading directly to the outside of the building.

(Amd) **1031.3.2 Minimum dimensions.** The minimum net clear opening height dimension shall be 24 inches (610 mm). The minimum net clear opening width dimension shall be 20 inches (508 mm). The net clear opening dimensions shall be the result of normal operation of the opening.

Exception: In existing buildings undergoing a change of occupancy to Group R-1 bed and breakfast establishments, the net clear opening dimensions may be obtained by removal of the sash without the use of a key or tool provided the instructions for the removal of the sash are clearly posted on the inside of the guest room door.

(Amd) **1031.3.3 Maximum height from floor.** *Emergency escape and rescue openings* shall have the bottom of the clear opening not greater than 44 inches (1,118 mm) measured from the floor.

Exception: In an existing building undergoing a change of use, the 44-inch (1,118 mm) maximum height may be measured vertically above a fixed, permanent platform, step or steps whose minimum width shall equal or exceed the operable width of the opening and shall be centered on such opening. Any stairs or steps shall comply with Section 1011.5.

(Add) **1032.2.3 Inspection of door openings.** Door openings shall be inspection in accordance with the requirements of NFPA 80.

CHAPTER 11
(Amd) CODE REQUIREMENTS FOR EXISTING BUILDING

(Amd) **1101.1 Scope.** The provisions of this chapter shall apply to buildings for which a building permit was applied for on or after January 1, 2006, and prior to the adoption of this Code, and not undergoing any alterations, renovations, or change of use. Buildings for which a permit was applied for prior to, January 1, 2006 shall be governed by the Connecticut State Fire Prevention Code.

(Amd) **1101.2 Intent.** The intent of this chapter is to provide a minimum degree of fire and life safety to persons occupying existing buildings by providing minimum code requirements where such existing buildings do not comply with the minimum requirements found elsewhere in this code.

(Amd) **1101.3 Conflicts.** Where a conflict exists between a provision in this Chapter and a code requirement in effect at the time of construction, the code requirement in effect at the time of construction shall prevail.

(Del) **1101.4 Owner notification.** Delete entire section.

(Amd) **1103.1 Required construction.** Existing buildings shall comply with not less than the minimum provisions specified in Table 1103.1 and as further enumerated in Sections 1103.2 to 1103.10, inclusive.

The provisions of this chapter shall not be construed to allow the elimination of *fire protection systems* or a reduction in the level of fire safety provided in buildings constructed in accordance with previously adopted codes.

Exceptions:

1. Where a change in fire-resistance rating has been approved in accordance with Section 501.2 or 802.6 of the 2021 *International Existing Building Code* portion of the Connecticut State Building Code.
2. Group U occupancies.

(Amd) **1103.1.1 Historic buildings.** Historic buildings shall be evaluated on a case-by-case basis with use of the code modification process in accordance with section 29-296 of the Connecticut General Statutes.

(Amd) **1103.3 Existing elevators.** Existing elevators shall comply with the Connecticut Safety Code for Elevators and Escalators.

(Amd) **1103.4 Vertical openings.** Interior vertical openings, including, but not limited, to stairways, elevator hoistways, service and utility shafts, that connect two or more stories of a building, shall be enclosed or protected as required by Chapter 7.

(Del) **1103.4.1 Group I-2 and I-3 occupancies.** Delete section.

(Del) **1103.4.2 Three to five stories.** Delete section.

(Del) **1103.4.3 More than five stories.** Delete section.

(Del) **1103.4.4 Atriums and covered malls.** Delete section.

(Del) **1103.4.5 Escalators in Group B and M occupancies.** Delete section.

(Del) **1103.4.6 Escalators connecting four or fewer stories.** Delete section.

(Del) **1103.4.7 Escalators connecting more than four stories.** Delete section.

(Del) **1103.4.8 Occupancies other than Groups I-2 and I-3.** Delete section.

(Del) **1103.4.9 Waste and linen chutes.** Delete section.

(Del) **1103.4.10 Flue fed incinerators.** Delete section.

(Amd) **1103.5 Sprinkler systems.** An automatic sprinkler system shall be provided in existing buildings as required by Chapter 9.

(Del) **1103.5.1 Group A-2.** Delete section.

(Del) **1103.5.2 Group I-2.** Delete section.

(Del) **1103.5.3 Group I-2 Condition 2.** Delete section.

(Del) **1103.5.5 Pyroxylin plastics.** Delete section.

(Amd) **1103.6 Standpipes.** Standpipes shall be provided in existing buildings as required by Chapter 9.

(Amd) **1103.7 Fire alarm systems.** An *approved* fire alarm system shall be installed in existing buildings and structures as required by Chapter 9 and provide occupant notification in accordance with Section 907.5 unless other requirements are provided by other sections of this code.

Exception: Occupancies with an existing, previously *approved* fire alarm system.

(Amd) **1103.8.2 Interconnection.** Where more than one smoke alarm is required to be installed within an individual *dwelling or sleeping unit*, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. Physical interconnection of smoke alarms shall not be required where listed wireless alarms are installed and all alarms sound upon activation of one alarm. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

(Amd) **1103.8.3 Power source.** Single-station smoke alarms shall receive their primary power from the building wiring provided that such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms with integral strobes that are not equipped with battery backup shall be connected to an emergency electrical system. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

(Amd) **1104.1 General.** *Means of egress* in existing buildings shall comply with Chapter 10. Where the provisions of this chapter conflict with the building code that applied at the time of construction, the most restrictive provision shall apply.

(Del) **1104.2 Elevators, escalators and moving walks.** Delete section.

(Del) **1104.3 Exit sign illumination.** Delete section.

(Del) **1104.4 Power source.** Delete section.

(Del) **1104.5 Illumination emergency power.** Delete section in its entirety.

(Del) **1104.6 Guards.** Delete section in its entirety.

(Del) **1104.7 Size of doors.** Delete section in its entirety.

(Del) **1104.8 Opening force for doors.** Delete section.

(Del) **1104.9 Revolving doors.** Delete section in its entirety.

(Del) **1104.10 Stair dimensions for existing stairways.** Delete section in its entirety.

(Del) **1104.11 Winders.** Delete section.

(Del) **1104.12 Curved stairways.** Delete section.

(Del) **1104.13 Stairway handrails.** Delete section in its entirety.

(Del) **1104.14 Slope of ramps.** Delete section.

(Del) **1104.15 Width of ramps.** Delete section.

(Del) **1104.16 Fire escape stairways.** Delete section in its entirety.

(Del) **1104.17 Corridor construction.** Delete section in its entirety.

(Del) **1104.18 Dead ends.** Delete section.

(Del) **1104.19 Exit access travel distance.** Delete section.

(Del) **1104.20 Common path of egress travel.** Delete section.

(Del) **1104.21 Stairway discharge identification.** Delete section.

(Del) **1104.22 Exterior stairway protection.** Delete section.

(Del) **1104.23 Minimum aisle width.** Delete section.

(Del) **1104.24 Stairway floor number signs.** Delete section.

(Del) **1104.25 Egress path markings.** Delete section.

SECTION 1105
(Amd) CODE REQUIREMENTS
FOR EXISTING GROUP I-2

(Del) **1105.2 Applicability.** Delete section.

(Del) **1105.3 Construction.** Delete section.

(Del) **1105.4 Incidental Uses in Existing I-2.** Delete section in its entirety.

(Del) **1105.5 Corridor Construction.** Delete section in its entirety.

(Del) **1105.6 Means of Egress.** Delete section in its entirety.

(Del) **1105.7 Smoke Compartments.** Delete section in its entirety.

(Del) **1105.8 Group I-2 care suites.** Delete section.

(Del) **1105.9 Group I-2 automatic sprinkler systems.** Delete section.

(Del) **1105.10 Group I-2 automatic fire alarm systems.** Delete section.

(Del) **1105.11 Essential electrical systems.** Delete section in its entirety.

CHAPTER 12
ENERGY SYSTEMS

(Add) **1203.2.20 Electric fire pumps.** Buildings provided with standby electrical power for the purpose of continuing operations or occupancy shall provide standby power in accordance with Article 701 of the 2020 NFPA 70, National Electrical Code, portion of the Connecticut State Building Code for any electric fire pump installed to provide an adequate water supply or minimum operating pressure to a required automatic sprinkler system.

(Amd) **1205.2.3 Building-integrated photovoltaic (BIPV) systems.** Where building-integrated photovoltaic (BIPV) systems are installed in a manner that creates areas with electrical hazards to be hidden from view, markings shall be provided to identify the hazardous areas to avoid. The markings shall be reflective and be visible from grade.

(Add) **1205.2.3.1 Required signage.** Where a BIPV system is installed, a placard shall be provided on the outside of the building at the electrical service meter location to which the BIPV system is connected. The placard shall display a firefighter Maltese cross with "PV" printed in the center of the cross. The placard shall be not less than 4 inches by 6

inches in size and made of a durable material approved by the authority having jurisdiction.

(Amd) **TABLE 1207.6**
ELECTROCHEMICAL ESS TECHNOLOGY-SPECIFIC REQUIREMENTS

COMPLIANCE REQUIRED ^b		BATTERY TECHNOLOGY				OTHER ESS AND BATTERY TECHNOLOGIES ^b	CAPACITOR ESS ^b
Features	Section	Lead-Acid	Ni-Cd and Ni-MH	Lithium-ion	Flow		
Exhaust Ventilation	1207.6.1	Yes	Yes	No ^f	Yes	Yes	Yes
Explosion control	1207.6.3	Yes ^a	Yes ^a	Yes	No	Yes	Yes
Safety caps	1207.6.4	Yes	Yes	No	No	Yes	Yes
Spill control and neutralization	1207.6.2	Yes ^c	Yes ^c	No	Yes	Yes	Yes
Thermal runaway	1207.6.5	Yes ^d	Yes	Yes	No	Yes	Yes

a. Not required for lead-acid and nickel-cadmium batteries at facilities under the exclusive control of communications utilities that comply with NFPA 76 and operate at less than 50 VAC and 60 VDC.

b. Protection shall be provided unless documentation acceptable to the fire code official is provided in accordance with Section 104.8.2 that provides justification why the protection is not necessary based on the technology used.

c. Applicable to vented-type (i.e., flooded) nickel-cadmium and lead-acid batteries.

d. Not required for vented-type (i.e., flooded) lead-acid batteries.

e. Reserved.

f. Exhaust ventilation is required when flammable gasses are released under abnormal conditions.

1207.6.1.2.4 Gas detection system. Where required by Section 1207.6.1.2, rooms, areas and walk-in units containing ESS shall be protected by an *approved* continuous gas detection system that complies with Section 916 and with the following:

1. The gas detection system shall be designed to activate the mechanical ventilation system when the level of flammable gas in the room, area or walk-in unit exceeds 25 percent of the LFL or where the level of toxic or highly toxic gasses exceeds one-half (1/2) of the IDLH, or where gas indicative of venting from a lithium-ion cell is detected.
2. The mechanical ventilation system shall remain on until the flammable gas detected is less than 25 percent of the LFL.
3. The gas detection system shall be provided with a minimum of 2 hours of

standby power in accordance with Section 1203.2.5.

4. Failure of the gas detection system shall annunciate a trouble signal at an approved central station, proprietary or remote station service in accordance with NFPA 72, or shall initiate an audible and visible trouble signal at an approved constantly attended on-site location.

(Add) **1207.6.6.** The thermal runaway detector shall activate upon detection of gas vapors produced by liquid electrolyte in a lithium-ion cell at the start of a battery venting event. Upon detection of gas vapors, the detection system shall shut down the affected ESS rack and transmit a fire alarm signal. Detection of a thermal runaway event shall activate the mechanical ventilation when it is provided as a method of explosion control.

CHAPTERS 13 through 19 RESERVED

(Del) CHAPTER 20 AVIATION FACILITIES

Delete chapter in its entirety and replace with the following.

(Add) CHAPTER 20 AVIATION FACILITIES

(Add) **2001.1 Scope.** Airports, heliports, helistops, and aircraft hangers shall be in accordance with this chapter and Section 116 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Add) **2001.2 Regulations not covered.** Regulations not specifically addressed shall be in accordance with NFPA 407, NFPA 409, NFPA 410 and NFPA 415.

(Add) **2001.3 Permits.** The applicable provisions of Section 105.5 shall apply for permits to airport terminal buildings and hangars.

C H A P T E R 2 1

DRY CLEANING

(Amd) **2101.1 Scope.** Dry cleaning plants shall comply with the requirements of this chapter and Section 116 for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

C H A P T E R 2 2

COMBUSTIBLE DUST-PRODUCING OPERATIONS

(Amd) **2201.1 Scope.** Combustible dust producing operations shall comply with the provisions of NFPA 652 and Section 116 for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

C H A P T E R 2 3

MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

(Amd) **2301.1 Scope.** Automotive motor fuel-dispensing facilities, marine motor fuel-dispensing facilities, fleet motor fuel-dispensing facilities, aircraft motor vehicle fuel-dispensing facilities and repair garages shall be in accordance with this chapter, Section 116, and the Connecticut State Building Code for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Add) **2301.7 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56. This includes purging into or out of service.

(Del) **SECTION 2305
OPERATIONAL REQUIREMENTS**

Delete section in its entirety.

(Amd) **2307.1 General.** Motor fuel-dispensing facilities for liquefied petroleum gas (LP-Gas) fuel shall be in accordance with this section, Chapter 61 and NFPA 30A.

(Add) **2307.6.5 Emergency shutoff control.** The system shall be provided with an emergency shut-off switch located within 100 feet (30m) of, but not less than 20 feet (6m) from, dispensers.

**CHAPTER 24
FLAMMABLE FINISHES**

(Amd) **2401.1 Scope.** Locations or areas where any of the activities under 1. to 5., inclusive, are conducted shall be in accordance with this chapter, and Section 116 for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

1. The application of flammable finishes to articles or materials by means of spray apparatus.
2. The application of flammable finishes by dipping or immersing articles or materials into the contents of tanks, vats or containers of *flammable* or *combustible liquids* for coating, finishing, treatment or similar processes.
3. The application of flammable finishes by applying combustible powders to articles or materials utilizing powder spray guns, electrostatic powder spray guns, fluidized beds or electrostatic fluidized beds.
4. Floor surfacing or finishing operations using Class I or II liquids in areas exceeding 350 square feet (32.5 m²).
5. The application of flammable finishes consisting of dual-component coatings or Class I or II liquids where applied by brush or roller in quantities exceeding 1 gallon (4 L).

(Amd) **2401.3 Permits.** Permits shall be required as set forth in Section 105.5.

C H A P T E R 2 5 FRUIT AND CROP RIPENING

(Amd) **2501.1 Scope.** Ripening processes where ethylene gas is introduced into a room to promote the ripening of fruits, vegetables and other crops shall comply with this chapter and Section 116 for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Exception: Mixtures of ethylene and one or more inert gases in concentrations that prevent the gas from reaching greater than 25 percent of the lower explosive limit (LEL) when released to the atmosphere.

C H A P T E R 2 6 FUMIGATION AND INSECTICIDAL FOGGING

(Amd) **2601.1 Scope.** Fumigation and insecticidal fogging operations within buildings, structures and spaces shall comply with this chapter for items involving building construction services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

C H A P T E R 2 7 SEMICONDUCTOR FABRICATION FACILITIES

(Amd) **2701.1 Scope.** Semiconductor fabrication facilities and comparable research and development areas classified as Group H-5 shall comply with this chapter and the 2021 *International Building Code* portion of the Connecticut State Building Code for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and

activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. The use, storage and handling of hazardous materials in Group H-5 shall comply with this chapter and the Connecticut State Fire Prevention Code.

(Del) **2701.4 Existing buildings and existing fabrication areas.** Delete section.

CHAPTER 28 LUMBERYARDS AND AGRO-INDUSTRIAL, SOLID BIOMASS AND WOODWORKING FACILITIES

(Amd) **2801.1 Scope.** The storage, manufacturing and processing of solid biomass feedstock, timber, lumber, plywood, veneers and agro-industrial byproducts shall be in accordance with this chapter for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Amd) **2810.3 Fire prevention plan.** The *owner* or *owner's* authorized representative shall submit a fire prevention plan for review and approval by the *fire code official* that includes all of the following:

1. Frequency of walk-through inspections to verify compliance with the plan.
2. Hot work permit program in accordance with the requirements of the Connecticut State Fire Prevention Code and Chapter 35.
3. Preventative maintenance program for equipment associated with pallet activities.
4. Inspection, testing and maintenance of *fire protection systems* in accordance with Chapter 9.

(Amd) **2810.9 Fire flow.** Fire flow requirements for the site shall be determined by the *fire chief* in conjunction with the *fire code official*.

CHAPTER 29 MANUFACTURE OF ORGANIC COATINGS

2901.1 Scope. Organic coating manufacturing processes shall comply with this chapter, except that this chapter shall not apply to processes manufacturing nonflammable or water-thinned coatings or to operations applying coating materials for items involving

building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components, services or systems, and for the purposes of prevention of fire and other related emergencies.

(Amd) **2909.4 Nitrocellulose storage.** Nitrocellulose storage shall be located on a detached pad or in a separate structure or a room enclosed in accordance with the 2021 *International Building Code* portion of the Connecticut State Building Code. The nitrocellulose storage area shall not be utilized for any other purpose. Electrical wiring and equipment installed in storage areas adjacent to process areas shall comply with Section 2904.2. Also refer to section 29-343 of the Connecticut General Statutes for the definition of “explosive” and the Connecticut Explosives Code adopted pursuant to section 29-349 of the Connecticut General Statutes.

(Amd) **2909.4.2 Spills.** Spilled nitrocellulose shall be promptly wetted with water and disposed of by use or burning in the open at a detached location approved by the local fire marshal and the local open burning official.

C H A P T E R 3 0 I N D U S T R I A L O V E N S

(Amd) **3001.1 Scope.** This chapter shall apply to the installation and operation of industrial ovens and furnaces. Industrial ovens and furnaces shall comply with the applicable provisions of this chapter, NFPA 54, the 2021 *International Mechanical Code* portion of the Connecticut State Building Code, and NFPA 86 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. The terms “ovens” and “furnaces” are used interchangeably in this chapter.

(Amd) **3001.2 Permits.** Permits shall be required as set forth in Section 105.5.

C H A P T E R 3 1

TENTS, TEMPORARY SPECIAL EVENT STRUCTURES AND OTHER MEMBRANE STRUCTURES

(Amd) **3101.1 Scope.** Tents, temporary special event structures and *membrane structures* shall comply with this chapter. The provisions of Section 3103 are applicable only to temporary tents and membrane structures. The provisions of Sections 3104 and 3106 are applicable to temporary and permanent tents and membrane structures. The provisions of Section 3105 are applicable to temporary special event structures. The provisions of Section 3106 are applicable to outdoor assembly events. Other temporary structures shall comply with the 2021 *International Building Code* portion of the Connecticut State Building Code. Membrane structures covering water storage facilities, water clarifiers, water treatment plants, sewage treatment plants, greenhouses and similar facilities not used for human occupancy, are required to meet only the requirements of Section 3104.2.1. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Amd) **3103.2 Approval required.** Tents and membrane structures having an area in excess of 400 square feet (37 m²) shall not be erected, operated or maintained for any purpose without obtaining approval from the *fire code official*.

Exceptions:

1. Tents used exclusively for recreational camping purposes.
2. Tents open on all sides which comply with all of the following:
 - 2.1 Individual tents having a maximum size of 700 square feet (65 m²)
 - 2.2 The aggregate area of multiple tents placed side by side without a fire break clearance of 12 feet (3,658 mm), not exceeding 700 square feet (65 m²) total.
 - 2.3 A minimum clearance of 12 feet (3,658 mm) to all other structures and tents.
3. Tents 900 square feet (84 m²) and smaller in total area when occupied by fewer than 50 persons, which have no heating appliances, no installed electrical service and are erected for fewer than 72 hours.

(Amd) **3103.4 Permits.** Permits shall be required as set forth in Section 105.5.

(Amd) **3103.5 Use period.** Temporary, air-supported, air-inflated or tensioned *membrane structures* shall not be erected for a period of more than 180 consecutive calendar days out of any 365 consecutive calendar days on a single premises.

(Amd) **3103.6 Construction documents.** A detailed site and floor plan for *tents* or *membrane structures* with an *occupant load* of 50 or more shall be provided with each application for approval. The *tent* or *membrane structure* floor plan shall indicate details of the *means of egress* facilities, seating capacity, arrangement of the seating and location and type of heating and electrical equipment.

(Add) **3103.6.1 Structural Stability.** *Construction documents* containing structural stability analysis shall be approved by the *building code official*.

(Amd) **3103.9 Structural stability and anchorage required.** *Tents* or *membrane structures* and their appurtenances shall be designed and installed to withstand the elements of weather and prevent collapsing. Documentation of structural stability shall be furnished to and approved by the *building code official*.

(Del) **3103.9.1 Tents and membrane structures greater than one story.** Delete section.

(Del) **3103.9.2 Tents and membrane structures greater than 7,500 square feet.** Delete section.

(Del) **3103.9.3 Tents and membrane structures with an occupant load greater than 1,000.** Delete section.

(Add) **3103.12.9** *Tent* stakes adjacent to any *means of egress* from any tent open to the public shall be railed off, capped, or covered so as not to present a hazard.

(Add) **3104.2.1 Membrane and interior liner material.** Membranes and interior liners shall be either noncombustible as set forth in Section 703.5 of the 2021 *International Fire Code* Portion of the Connecticut State Building Code or meet the fire propagation performance criteria of NFPA 701 and the manufacturer's test protocol.

Exception: Plastic less than 20 mil (0.5 mm) in thickness used in greenhouses, where occupancy by the general public is not authorized, and for aquaculture pond covers is not required to meet the fire propagation performance criteria of NFPA 701.

(Amd) **3105.3 Permits.** Permits shall be required as set forth in Section 105.5.

(Amd) **3106.6.2 Generators.** Generators shall be installed not less than 10 feet (3,048 mm) from combustible materials and shall be isolated from the public by physical guard, fence, or enclosure installed not less than 3 feet (914 mm) away from the internal combustion power source.

Exception:

Generators 7.5KW or less shall be separated from *tents* or *membrane structures* by not less than 5 feet (1,524 mm).

(Amd) **3107.12.6 Outdoor cooking.** Outdoor cooking that produces sparks shall not be performed within 20 feet (6,096 mm) of a *tent* or *membrane structure*

Exception: *As approved by the fire code official.*

(Amd) **3107.15.1 Batteries.** Batteries shall be disconnected except where the *fire code official* requires that the batteries remain connected to maintain safety features.

(Amd) **3107.16 Separation of generators.** Generators and other internal combustion power sources shall be separated from *tents* or *membrane structures* by not less than 20 feet (6096 mm) and shall be isolated from contact with the public by fencing, enclosure or other approved means.

Exception:

Generators 7.5KW or less shall be separated from *tents* or *membrane structures* by not less than 5 feet (1,524 mm).

CHAPTER 32 HIGH-PILED COMBUSTIBLE STORAGE

(Amd) **3201.1 Scope.** High-Piled combustible storage shall comply with the requirements this chapter and Section 116 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. In addition to the requirements of this chapter, the following material-specific requirements shall apply:

1. Aerosols shall be in accordance with Chapter 51.
2. *Flammable* and *combustible liquids* shall be in accordance with Chapter 57.
3. Hazardous materials shall be in accordance with Chapter 50.
4. Storage of combustible paper records shall be in accordance with NFPA 13.
5. Storage of *combustible fibers* shall be in accordance with Chapter 37.
6. General storage of combustible material shall be in accordance with Chapter 3.

(Amd) **3201.2 Permits.** Permits shall be required as set forth in Section 105.5.

CHAPTER 33 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

(Add) **3301.3 Occupied buildings.** In buildings under construction and during the course of additions, renovations or *alterations* to existing buildings, occupied areas shall be separated from work areas on the same floor by a barrier having at least a 1-hour fire resistance rating.

Exception: *As approved by the fire code official.*

C H A P T E R 3 4 TIRE REBUILDING AND TIRE STORAGE

(Amd) **3401.1 Scope.** Tire rebuilding and tire storage shall comply with the requirements this chapter and Section 116 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. Tire rebuilding plants, tire storage and tire byproduct facilities shall comply with this chapter, other applicable requirements of this code and NFPA 13. Tire storage in buildings shall also comply with Chapter 32.

(Amd) **3406.1 Required access.** New tire storage yards shall be provided with fire apparatus access roads in accordance with Section 503 and Section 3406.2.

C H A P T E R 3 5 WELDING AND OTHER HOT WORK

(Amd) **3501.1 Scope.** Welding and allied processes, cutting, open torches, heat-treating, power-driven fasteners, hot riveting and other *hot work* operations and equipment shall comply with this chapter, Section 116 and NFPA 51B for items involving building construction, services, or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

C H A P T E R 3 6 MARINAS

(Amd) **3601.1 Scope.** Marina facilities shall comply with the requirements this chapter and Section 116 for items involving building construction, services, or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Add) **3601.3 Permits.** Permits shall be required as set forth in Section 105.5.

CHAPTER 37 COMBUSTIBLE FIBERS

(Amd) **3701.1 Scope.** The equipment involving combustible fibers shall comply with the requirements this chapter and Section 1415.9.3 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

CHAPTER 38 HIGHER EDUCATION LABORATORIES

(Amd) **3801.1 Scope.** Higher education laboratories complying with the requirements of this chapter shall be permitted to exceed the maximum allowable quantities of hazardous materials in *control areas* set forth in Chapter 50 without requiring classification as a Group H occupancy. Except as specified in this chapter, such laboratories shall comply with all applicable provisions of this code and the 2021 *International Building Code* portion of the Connecticut State Building Code and Section 116 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Add) **3801.3 Permits.** Permits shall be required as set forth in Section 105.5.

(Del) **3805 NONSPRINKLERED LABORATORIES** Delete section in its entirety.

(Del) **3806 EXISTING SPRINKLERED LABORATORIES** Delete section in its entirety.

CHAPTER 39 PROCESSING AND EXTRACTING FACILITIES

(Amd) **3901.1 Scope.** Plant processing or extraction facilities shall comply with the requirements this chapter, Section 116, and the 2021 *International Building Code* portion of the Connecticut State Building Code for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. The extraction process includes the act of extraction of the oils and fats by use of a solvent, desolventizing of the raw material, production of the miscella, distillation of the solvent from the miscella and solvent recovery. The use, storage, transfilling and handling of hazardous materials in these facilities shall comply with this chapter, other applicable provisions of this code, the 2021 *International Building Code* portion of the Connecticut State Building Code and NFPA 36.

(Del) **3901.2 Existing buildings or facilities.** Delete section.

(Amd) **3901.3 Permits.** Permits shall be required as set forth in Section 105.5.

CHAPTER 40 STORAGE OF DISTILLED SPIRITS AND WINES

(Amd) **4001.1 Scope.** Storage of distilled spirits and wines in barrels and casks shall comply with the requirements this chapter in addition to other applicable requirements of this code, and Section 116 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Add) **4001.1.2 Permits.** Permits shall be required as set forth in Section 105.5.

(D E L) C H A P T E R 4 1

(A D D) C H A P T E R 4 1

Fixed Guideways Transit and Passenger Rail Systems

(Amd) **4001.1 General.** Fixed guideway transit and passenger rail system facilities shall comply with NFPA 130.

**(A m d) C H A P T E R S 4 2 t h r o u g h 4 9
RESERVED**

Part V – Hazardous Materials

**C H A P T E R 5 0
HAZARDOUS MATERIALS – GENERAL PROVISIONS**

(Amd) **5001.1 Scope.** Prevention, control and mitigation of dangerous conditions related to storage, dispensing, use and handling of hazardous materials shall comply with the requirements this chapter in addition to other applicable requirements of this code, and Section 1415.9.3 for items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. Where applicable, NFPA 400 shall also apply.

This chapter shall apply to all hazardous materials, including those materials regulated elsewhere in this code, except that where specific requirements are provided in other chapters, those specific requirements shall apply in accordance with the applicable chapter. Where a material has multiple hazards, all hazards shall be addressed.

Exceptions:

1. In retail or wholesale sales occupancies, medicines, foodstuff, cosmetics, and commercial or institutional products containing not more than 50 percent by volume of water-miscible liquids and with the remainder of the solutions not being flammable, provided that such materials are packaged in individual containers not exceeding 1.3 gallons (5 L).
2. Alcoholic beverages in retail or wholesale sales occupancies provided that the liquids are packaged in individual containers not exceeding 1.3 gallons (5 L).

3. Application and release of pesticide and agricultural products and materials intended for use in weed abatement, erosion control, soil amendment or similar applications where applied in accordance with the manufacturers' instructions and label directions.
4. The off-site transportation of hazardous materials where in accordance with Department of Transportation (DOTn) regulations.
5. Building materials not otherwise regulated by this code.
6. Refrigeration systems (see Section 605).
7. Stationary storage battery systems regulated by Section 1206.2.
8. The display, storage, sale or use of fireworks and *explosives* in accordance with Chapter 56.
9. *Corrosives* utilized in personal and household products in the manufacturers' original consumer packaging in Group M occupancies.
10. The storage of beer, distilled spirits and wines in barrels and casks.
11. The use of wall-mounted dispensers containing alcohol-based hand rubs classified as Class I or II liquids where in accordance with Section 5705.5.
12. Specific provisions for flammable liquids in motor fuel-dispensing facilities, repair garages, airports and marinas in Chapter 23.
13. Storage and use of fuel oil in tanks and containers connected to oil-burning equipment. Such storage and use shall be in accordance with Section 605. For abandonment of fuel oil tanks, Chapter 57 applies.
14. Storage and display of aerosol products complying with Chapter 51.
15. Storage and use of *flammable* or *combustible liquids* that do not have a fire point when tested in accordance with ASTM D92, not otherwise regulated by this code.
16. *Flammable* or *combustible liquids* with a *flash point* greater than 95°F (35°C) in a water-miscible solution or dispersion with a water and inert (noncombustible) solids content of more than 80 percent by weight, which do not sustain combustion, not otherwise regulated by this code.
17. Commercial cooking oil storage tank systems located within a building and designed and installed in accordance with Section 607 and NFPA 30.

(Amd) **5001.1.1 Permits.** Permits shall be required as set forth in Section 105.5.

(Add) **5001.7 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56, *Fire and Explosion Prevention during Cleaning and Purging of Flammable Gas Piping Systems*. This includes purging into or out of service.

(Amd) **5003.3 Release of hazardous materials.** Release of hazardous materials shall be in accordance with the Regulations of Connecticut State Agencies adopted by the Department of Energy and Environmental Protection pursuant to title 22a of the Connecticut General Statutes.

(Del) **5003.3.1 Unauthorized discharges.** Delete section in its entirety.

(Amd) **5003.9. General safety precautions.** General precautions for the safe storage, handling or care of hazardous materials shall be in accordance with Sections 5003.9.1 to 5003.9.10, inclusive, and section 29-307a of the Connecticut General Statutes.

CHAPTER 51 AEROSOLS

(Amd) **5101.1 Scope.** The provisions of this chapter, the 2021 *International Building Code* portion of the Connecticut State Building Code and NFPA 30B shall apply to the manufacturing, storage and display of aerosol products, aerosol cooking spray products and plastic aerosol 3 products as it relates to items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. Manufacturing of aerosol products, aerosol cooking spray products and plastic aerosol 3 products using hazardous materials shall also comply with Chapter 50.

CHAPTER 53 COMPRESSED GASES

5301.1 Scope. Storage, use and handling of *compressed gases* in *compressed gas* containers, cylinders, tanks and systems shall comply with this chapter, NFPA 55 and NFPA 400, including those gases regulated elsewhere in this code. as it relates to items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Partially full *compressed gas* containers, cylinders or tanks containing residual gases shall be considered as full for the purposes of the controls required.

Liquefied natural gas for use as a vehicular fuel shall also comply with NFPA 52 and NFPA 59A.

Compressed gases classified as hazardous materials shall also comply with Chapter 50 for general requirements and chapters addressing specific hazards, including Chapters 58 (Flammable Gases), 60 (Highly Toxic and Toxic Materials), 63 (Oxidizers, Oxidizing Gases and Oxidizing Cryogenic Fluids) and 64 (Pyrophoric Materials).

Compressed hydrogen (CH₂) shall also comply with the applicable portions of Chapters 23 and 58 of this code, the *International Fuel Gas Code* and NFPA 2.

Cutting and welding gases shall also comply with Chapter 35.

Exceptions:

1. Gases used as refrigerants in refrigeration systems (see Section 608).
2. Compressed natural gas (CNG) for use as a vehicular fuel shall comply with Chapter 23, NFPA 52 and the *International Fuel Gas Code*.
3. *Cryogenic fluids* shall comply with Chapter 55.
4. LP-gas shall comply with Chapter 61 and the *International Fuel Gas Code*.

(Add) **5301.3 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56, *Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems*. This includes purging into or out of service.

(Amd) **5306.5 Medical gas systems and equipment.** Medical gas systems and equipment shall be installed, tested and *labeled* in accordance with NFPA 99 and the general provisions of this chapter.

CHAPTER 54 CORROSIVE MATERIALS

(Amd) **5401.1 Scope.** The storage and use of *corrosive* materials shall be in accordance with this chapter and NFPA 400 as it relates to items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Compressed gases shall also comply with Chapter 53.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies complying with Section 5003.11.
2. Stationary storage battery systems in accordance with Section 1206.15.
3. This chapter shall not apply to R-717 (ammonia) where used as a refrigerant in a refrigeration system (see Section 608).

CHAPTER 55 CRYOGENIC MATERIALS

5501.1 Scope. Storage, use and handling of *cryogenic fluids* shall comply with this chapter, NFPA 55 and NFPA 400 as it relates to items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies. *Cryogenic fluids* classified as hazardous materials shall also comply with the general requirements of Chapter 50. Partially full containers containing residual *cryogenic fluids* shall be considered as full for the purposes of the controls required.

Exceptions:

1. Fluids used as refrigerants in refrigeration systems (see Section 608).
2. Liquefied natural gas (LNG), which shall comply with NFPA 59A.

Oxidizing *cryogenic fluids*, including oxygen, shall comply with Chapter 63, as applicable.

Flammable *cryogenic fluids*, including hydrogen, methane and carbon monoxide, shall comply with Chapters 23 and 58, as applicable.

Inert *cryogenic fluids*, including argon, helium and nitrogen, shall comply with ANSI/CGA P-18.

(Add) **5501.3 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56, *Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems*. This includes purging into or out of service.

CHAPTER 56 EXPLOSIVES AND FIREWORKS

(Amd) **5601.1 Scope.** The provisions of this chapter shall govern the possession, manufacture, storage, handling, sale and use of explosives, explosive materials, fireworks and small ammunition. In addition to the requirements of this code, compliance with sections 29-343 to 29-370, inclusive, of the Connecticut General Statutes and sections 29-357-1b to 29-357-12b, inclusive, of the Regulations of the Department of Emergency Services and Public Protection pertaining to explosives, fireworks and special effects is required.

(Del) **5601.1.1 Explosive material standard.** Delete section.

(Del) **5601.1.2 Explosive material terminals.** Delete section.

(Amd) **5601.1.3 Sparklers and fountains.** The possession, storage, handling and use of sparklers and fountains shall be in compliance with sections 29-343 to 29-370, inclusive, of the Connecticut General Statutes and sections 29-357-1b to 29-357-12b, inclusive, of the Regulations of the Department of Emergency Services and Public Protection.

(Amd) **5601.1.4 Rocketry.** The storage, handling and use of model and high-power rockets shall comply with section 29-367 of the Connecticut General Statutes and sections 29-367-1 to 29-367-3, inclusive of the Regulations of Connecticut State Agencies.

(Amd) **5601.1.5 Ammonium nitrate.** The storage, handling and use of ammonium nitrate shall comply with section 29-349 of the Connecticut General Statutes and sections 29-349-106 to 29-349-378, inclusive, of the Regulations of Connecticut State Agencies.

(Amd) **5601.2 Permit required.** Permits shall be required as set forth in section 105.5.

(Del) **5601.2.1 Residential uses.** Delete section.

(Del) **5601.2.2 Sale and retail display.** Delete section.

(Del) **5601.2.3 Permit restrictions.** Delete section.

(Del) **5601.2.4 Financial responsibility.** Delete section in its entirety.

(Del) **5601.3 Prohibited explosives.** Delete section.

(Del) **5601.4 Qualifications.** Delete section.

(Del) **5601.5 Supervision.** Delete section.

(Del) **5601.6 Notification.** Delete section.

(Del) **5601.7 Seizure.** Delete section.

(Del) **5601.8 Establishment of quantity of explosives and distances.** Delete section in its entirety.

(Del) **5603 RECORD KEEPING AND REPORTING** Delete section in its entirety.

(Del) **5604 EXPLOSIVE MATERIALS STORAGE AND HANDLING** Delete section in its entirety.

(Del) **5605 MANUFACTURE, ASSEMBLY AND TESTING OF EXPLOSIVES, EXPLOSIVE MATERIALS AND FIREWORKS** Delete section in its entirety.

(Del) **5606 SMALL ARMS AMMUNITION AND SMALL ARMS AMMUNITION COMPONENTS** Delete section in its entirety.

(Del) **5607 BLASTING** Delete section in its entirety.

(Amd) **5608.1 General.** Outdoor fireworks displays and use of pyrotechnics before a *proximate audience* and pyrotechnic special effects in motion picture, television, theatrical and group entertainment productions shall comply with sections 29-357 and 29-357a of the Connecticut General Statutes and the Department of Emergency Services and Public Protection's regulations pertaining to explosives and fireworks. (29-357-1b to 29-357-12b, inclusive, and 29-106 to 20-378, inclusive).

(Del) **5608.2 Permit application.** Delete section in its entirety.

(Del) **5608.3 Approved fireworks displays.** Delete section.

(Del) **5608.4 Clearance.** Delete section.

(Del) **5608.5 Storage of fireworks at display site.** Delete section in its entirety.

(Del) **5608.6 Installation of mortars.** Delete section.

(Del) **5608.7 Handling.** Delete section.

(Del) **5608.8 Fireworks display supervision.** Delete section.

(Del) **5608.9 Post fireworks display inspection.** Delete section.

(Del) **5608.10 Disposal.** Delete section.

(Amd) **5609.1. General.** The retail display and sale of sparklers and fountains shall comply with the applicable requirements of NFPA 1124.

(Add) **5609.1.1** The provisions of NFPA 1124, 2006 edition, are amended for use in Connecticut as follows:

(Amd) NFPA 1124, **7.3.7 Storage Rooms.** Storage rooms containing consumer fireworks, regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, or separated from the retail sales area by a fire barrier having a fire resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, and separated by a minimum of 4 feet (1.22 m) of clear space.

(Amd) NFPA 1124, **7.5.3 Storage Rooms.** Storage rooms containing consumer fireworks, regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, or separated from the retail

sales area by a *fire barrier* having a *fire-resistance* rating of not less than 1 hour. The quantity of *fireworks* permitted in storage shall not exceed 3,600 cubic feet (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic feet (34 m³) or less, separated by a minimum of 4 feet (1.22 m) of clear space.

(Add) **5609.2 Permit required.** Permits for the retail sale of sparklers and fountains shall be required as set forth in Section 105.5.

CHAPTER 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

(Amd) **5701.1 Scope and application.** Prevention, control and mitigation of dangerous conditions related to storage, use, dispensing, mixing and handling of flammable and combustible liquids shall be in accordance with this chapter, Chapter 50, and NFPA 30. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Del) **5703.6.3.1 Existing piping.** Delete section.

(Del) **5706.3 Well drilling and operating.** Delete section in its entirety.

(Del) **5706.6 Tank vehicles and vehicle operation.** Delete section in its entirety.

(Del) **Section 5707 ON-DEMAND MOBILE FUELING OPERATIONS** Delete section in its entirety.

CHAPTER 58 FLAMMABLE GASES AND FLAMMABLE CRYOGENIC FLUIDS

(Amd) **5801.1 Scope.** The storage and use of flammable gases and flammable *cryogenic fluids* shall be in accordance with this chapter, NFPA 2, NFPA 55 and NFPA 400. *Compressed gases* shall also comply with Chapter 53 and *cryogenic fluids* shall also comply with Chapter 55. Flammable *cryogenic fluids* shall comply with Section 5806. Hydrogen motor fuel-dispensing stations and repair garages and their associated above-ground hydrogen storage systems shall also be designed, constructed and maintained in accordance with Chapter 23. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be

applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Exceptions:

1. Gases used as refrigerants in refrigeration systems (see Section 608).
2. Liquefied petroleum gases and natural gases regulated by Chapter 61.
3. Fuel-gas systems and appliances regulated under the *International Fuel Gas Code* other than gaseous hydrogen systems and appliances.
4. Pyrophoric gases in accordance with Chapter 64.

(Add) **5801.3 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56, *Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems*. This includes purging into or out of service.

CHAPTER 59 FLAMMABLE SOLIDS

(Amd) **5901.1 Scope.** The storage and use of flammable solids shall be in accordance with this chapter and NFPA 400. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services and/or systems, and for the purposes of prevention of fire and other related emergencies.

CHAPTER 60 HIGHLY TOXIC AND TOXIC MATERIALS

(Amd) **6001.1 Scope.** The storage and use of highly toxic and toxic materials shall comply with this chapter and NFPA 400. *Compressed gases* shall also comply with Chapter 53. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure

that are not used to support the building components services or systems. and for the purposes of prevention of fire and other related emergencies.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies complying with Section 5003.11.
2. Conditions involving pesticides or agricultural products as follows:
 - 2.1. Application and release of pesticide, agricultural products and materials intended for use in weed abatement, erosion control, soil amendment or similar applications when applied in accordance with the manufacturer's instruction and label directions.
 - 2.2. Transportation of pesticides in compliance with the Federal Hazardous Materials Transportation Act and regulations thereunder.
 - 2.3. Storage in *dwelling*s or private garages of pesticides registered by the U.S. Environmental Protection Agency to be utilized in and around the home, garden, pool, spa and patio.

CHAPTER 61 LIQUEFIED PETROLEUM GASES

(Amd) **6101.1 Scope.** Storage, handling and transportation of liquefied petroleum gas (LP-gas) and the installation of LP-gas equipment pertinent to systems for such uses shall comply with this chapter and NFPA 58. Properties of LP-gases shall be determined in accordance with Appendix B of NFPA 58. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

(Amd) **6101.2 Permits.** Permits shall be required as set forth in Section 105.5. Distributors shall not fill an LP-gas container for which a permit is required unless a permit for installation has been issued for that location by the *fire code official*.

(Add) **6101.4 Cleaning and purging of flammable gas piping systems.** The cleaning and purging of any flammable gas piping system shall be in accordance with NFPA 56, *Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems*. This includes purging into or out of service.

(Add) **6106.4 Written emergency plan.** A written emergency response plan shall be required for industrial plants, bulk plants, and dispensing stations. The facility emergency response plan, when required, shall be in writing and amended as required but at least every two years. Written documentation of the current emergency response plan shall be

maintained at the facility and shall be provided upon written request to the local fire marshal and emergency response agencies. The fire safety analysis and special fire protection provisions referred to in Section 6.29 of NFPA 58 shall be incorporated into the emergency response plan as appropriate.

(Add) **6106.5 Identification.** LP-gas fuel suppliers shall affix and maintain in a legible condition, their firm name(s) and emergency telephone number(s) in a readily visible location on or near LP-gas supplier-owned Department of Transportation (DOT) and American Society of Mechanical Engineers (ASME) containers installed on a consumer's premises.

(Add) **6106.5.1** The firm name(s) and emergency telephone number(s) on the containers shall be at least one half (1/2) inch high and of contrasting color to the container.

(Add) **6106.5.2** The emergency telephone number(s) shall be staffed 24 hours a day to ensure that the LP-gas supplier is available in the event of an emergency at the consumer's premises.

(Add) **6106.6 Ownership.** Cylinders, tanks or containers shall be filled, evacuated or transported only by the owner of the cylinder, tank or container or upon the owner's authorization.

(Amd) **6107.4 Protecting containers from vehicles.** Where exposed to vehicular damage due to proximity to alleys, driveways, or parking areas, LP-gas containers, regulators and piping shall be protected in accordance with Section 312 and NFPA 58.

CHAPTER 62 ORGANIC PEROXIDES

(Amd) **6201.1 Scope.** The storage and use of organic peroxides shall be in accordance with this chapter, Chapter 50 and NFPA 400. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Unclassified detonable organic peroxides that are capable of *detonation* in their normal shipping containers under conditions of fire exposure shall be stored in accordance with Chapter 56.

CHAPTER 63 OXIDIZERS, OXIDIZING GASES AND OXIDIZING CRYOGENIC FLUIDS

(Amd) **6301.1 Scope.** The storage and use of oxidizing materials shall be in accordance with this chapter, Chapter 50 and NFPA 400. Oxidizing gases shall also comply with Chapter 53. Oxidizing *cryogenic fluids* shall also comply with Chapter 55. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies complying with Section 5003.11.
2. Bulk oxygen systems at industrial and institutional consumer sites shall be in accordance with NFPA 55.
3. Liquid oxygen stored or used in home health care in Group I-1, I-4 and R occupancies in accordance with Section 6306.

CHAPTER 64 PYROPHORIC MATERIALS

(Amd) **6401.1 Scope.** The storage and use of pyrophoric materials shall be in accordance with this chapter and NFPA 400. *Compressed gases* shall also comply with Chapter 53. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

CHAPTER 65 PYROXLIN (CELLULOSE NITRATE) PLASTICS

(Amd) **6501.1 Scope.** This chapter shall apply to the storage and handling of plastic substances, materials or compounds with cellulose nitrate (pyroxylin) as a base, by whatever name known, in the form of blocks, sheets, tubes or fabricated shapes. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas,

hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Cellulose nitrate (pyroxylin) motion picture film shall comply with the requirements of Section 306.

CHAPTER 66 UNSTABLE (REACTIVE) MATERIALS

(Amd) **6601.1 Scope.** The storage and use of unstable (reactive) materials shall be in accordance with this chapter and NFPA 400. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Compressed gases shall also comply with Chapter 53.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies complying with Section 5003.11.
2. Detonable unstable (reactive) materials shall be stored in accordance with Chapter 56.

CHAPTER 67 WATER-REACTIVE SOLIDS AND LIQUIDS

(Amd) **6701.1 Scope.** The storage and use of water-reactive solids and liquids shall be in accordance with this chapter and NFPA 400. The provisions of this code regulates items involving building construction, services or systems. Pursuant to section 29-291a of the Connecticut General Statutes, the Connecticut State Fire Prevention Code shall be applicable for oil burners, flammable and combustible liquids, gas equipment and piping, liquefied gas and liquefied natural gas, hazardous chemicals, and processes and activities that occur in the building or structure that are not used to support the building components services or systems, and for the purposes of prevention of fire and other related emergencies.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies, complying with Section 5003.11.
2. Detonable water-reactive solids and liquids shall be stored in accordance with Chapter 56.

CHAPTER 80 REFERENCED STANDARDS

(Add) **80.1 General.** When a requirement differs between this code and a referenced code or standard, the requirement of this code shall apply. Where the extent of a referenced code or standard includes subject matter that is within the scope of this code, the provisions of this code, as applicable, shall take precedence over the provisions that are in the referenced code or standard. The documents or portions thereof listed in Chapter 80 as referenced, except as amended, shall be considered part of the requirements of this code to the extent called for by this code.

(Amd) NFPA

National Fire Protection Association
1 Batterymarch Park
Quincy, MA 02169-7471

02—20: Hydrogen Technologies Code

1206.3, 1206.4, 2309.3.1.1, 2309.3.1.2, 2309.6, 2311.8, 2311.8.2,
2311.8.10, 2311.8.11, 5301.1, 5801.1

04—21: Standard for Integrated Fire Protection and Life Safety System Testing

901.6.2.1, 901.6.2.2

10—18: Standard for Portable Fire Extinguishers

Table 901.6.1, 906.2, Table 906.3(1), Table 906.3(2), 906.3.2, 906.3.4,
3006.3

11—16: Standard for Low-, Medium-, and High-Expansion Foam

904.7, 5704.2.9.2.2

12—18: Standard on Carbon Dioxide Extinguishing Systems

Table 901.6.1, 904.8, 904.12, 1207.5.5

12A—18: Standard on Halon 1301 Fire Extinguishing Systems

Table 901.6.1, 904.9

13—19: Standard for the Installation of Sprinkler Systems

903.3.1.1, 903.3.2, 903.3.8.2, 903.3.8.5, 904.13, 905.3.4, 907.6.4, 914.3.2,
1019.3, 1206.3.5.1, 3201.1, 3204.2, 3205.5, Table 3206.2, 3206.4.1,
3206.10, 3207.2, 3207.2.1, 3208.2.2, 3208.2.2.1, 3208.4, 3210.1, 3401.1,
5104.1, 5104.1.1, 5106.5.7, 5704.3.3.9, Table 5704.3.6.3(7), 5704.3.7.5.1,
5704.3.8.4

13D—19: Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes

903.3.1.3

13R—19: Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies

903.3.1.2, 903.3.5.2, 903.4

14—19: Standard for the Installation of Standpipe and Hose Systems

905.2, 905.3.4, 905.4.2, 905.6.2, 905.8

15—17: Standard for Water Spray Fixed Systems for Fire Protection

1207.5.5, 5704.2.9.2.3

16—19: Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems

904.7, 904.13

17—21: Standard for Dry Chemical Extinguishing Systems

Table 901.6.1, 904.6, 904.13

17A—21: Standard for Wet Chemical Extinguishing Systems

Table 901.6.1, 904.5, 904.13

20—19: Standard for the Installation of Stationary Pumps for Fire Protection

913.1, 913.2, 913.5.1

22—18: Standard for Water Tanks for Private Fire Protection

507.2.2

24—19: Standard for Installation of Private Fire Service Mains and Their Appurtenances

507.2.1, 2809.5

25—20: Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems

507.5.3, Table 901.6.1, 904.7.1, 912.7, 913.5

30—21: Flammable and Combustible Liquids Code

607.1, 5001.1, 5701.2, 5703.6.2, 5703.6.2.1, 5704.2.7, 5704.2.7.1, 5704.2.7.2, 5704.2.7.3.2, 5704.2.7.4, 5704.2.7.6, 5704.2.7.7, 5704.2.7.8, 5704.2.7.9, 5704.2.9.3, 5704.2.9.4, 5704.2.9.6.1.1, 5704.2.9.6.1.2, 5704.2.9.6.1.3, 5704.2.9.6.1.4, 5704.2.9.6.1.5, 5704.2.9.6.2, 5704.2.9.7.3, 5704.2.10.2, 5704.2.11.3, 5704.2.11.4.2, 5704.2.12.1, 5704.3.1, 5704.3.6, Table 5704.3.6.3(1), Table 5704.3.6.3(2), Table 5704.3.6.3(3), 5704.3.7.2.3, 5704.3.8.4, 5706.8.3

30A—21: Code for Motor Fuel-Dispensing Facilities and Repair Garages

2301.4, 2301.5, 2301.6, 2306.6.3, 2310.1

30B—19: Code for the Manufacture and Storage of Aerosol Products

5101.1, 5103.1, 5104.1, Table 5104.3.1, Table 5104.3.2, Table 5104.3.2.2, 5104.3.3, 5104.4.1, 5104.5.2, 5104.6, 5104.8.2, 5106.2.2, 5106.2.4, 5106.3.2, Table 5106.4, 5106.5.1, 5106.5.6, 5107.1

31—20: Standard for the Installation of Oil-Burning Equipment

605.1.6, 605.4.1, 605.4.3

32—16: Standard for Drycleaning Facilities

2107.1, 2107.3

33—18: Standard for Spray Application Using Flammable or Combustible Materials

2403.3

34—18: Standard for Dipping, Coating, and Printing Processes Using Flammable or Combustible Liquids

2405.3, 2405.4.1.1

35—16: Standard for the Manufacture of Organic Coatings

2901.3, 2905.4

36—21: Standard for Solvent Extraction Plants

3909.1

40—19: Standard for the Storage and Handling of Cellulose Nitrate Film

306.2

45—19: Standard on Fire Protection for Laboratories Using Chemicals

3803.1.5, 3804.1.1.7, 3805.2.1, 3805.2.2

51—18: Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting and Allied Processes

3501.5, 3507.1, 3509.1

51B—19: Standard for Fire Prevention During Welding, Cutting, and Other Hot Work

3501.1

52—19: Vehicular Gaseous Fuel Systems Code

319.9.2, 5301.1

54—21: National Fuel Gas Code

102.14,

55—20: Compressed Gases and Cryogenic Fluids Code

3508.1, 5301.1, 5307.4.2, 5501.1, 5801.1, 6301.1

56—20: Standard for Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems

3307.2.1

58—20: Liquefied Petroleum Gas Code

319.8.3, 603.4.2.1.1, 2311.5, 3903.6, 6101.1, 6103.1, 6103.2.1, 6103.2.1.2, 6103.2.1.7, 6103.2.2, 6104.1, 6104.3.2, 6104.4, 6105.2, 6106.2, 6106.3, 6107.2, 6107.4, 6108.1, 6108.2, 6109.11.2, 6111.3

59A—19: Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)

5301.1, 5501.1

61—20: Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities

Table 2205.1

68—13: Standard on Explosion Protection by Deflagration Venting

911.1, 911.4, Table 2205.1

69—19: Standard on Explosion Prevention Systems

911.1, 911.3, Table 2205.1

70—20: National Electrical Code -- as AMENDED by the State Building Code

309.2, 603.1, 603.1.1, 603.2.1, 603.4, 603.4.1, 603.5, 603.8, 605.1.2, 605.1.6, 605.6.2, 607.6, 607.7, 608.17, 608.18, 904.3.1, 907.6.1, 909.12.2, 909.16.3, 910.4.6, 1006.2.2.4, 1010.2.9.2, 1201.2, 1203.1.3, 1205.1, 1206.4, 1206.14, 1206.3, 1207.4.1, 1207.4.2, 1207.4.8, 1207.5.3, 1207.10.6, 1207.10.7.4, 1207.11.5, 1207.11.10, 2006.3.4, 2104.2.3, 2108.2, 2203.4.1, 2203.5, Table 2205.1, 2301.5, 2305.4, 2308.8.1.2.4, 2309.2.3, 2311.3.1, 2311.8.10, 2403.2.1, 2403.2.1.1, 2403.2.1.4, 2403.2.5, 2404.6.1.2.2, 2404.9.4, 2504.5, 2603.2.1, 2703.7.1, 2703.7.2, 2703.7.3, 2803.4, 2904.1, 3103.12.6.1, 3106.6, 3107.12.7, 3305.7, 3506.4, 4003.3.3, 4003.3.4, 5003.8.7.1, 5003.9.4, 5303.7.6, 5303.8, 5303.16.11, 5303.16.14, 5503.6, 5503.6.2, 5703.1, Table 5703.1.1, 5703.1.3, 5704.2.8.12, 5704.2.8.17, 5706.2.8, 5803.1.5, 5803.1.5.1, 5807.1.10, 5906.5.5, 5906.5.6, 6109.15.1

72—19: National Fire Alarm and Signaling Code

508.1.6, Table 901.6.1, 903.4.1, 904.3.5, 907.1.2, 907.2, 907.2.6, 907.2.9.3, 907.2.11, 907.2.13.2, 907.3, 907.3.3, 907.3.4, 907.5.2.1.2, 907.5.2.1.3, 907.5.2.1.3.2, 907.5.2.2, 907.5.2.2.5, 907.6, 907.6.1, 907.6.2, 907.6.6, 907.7, 907.7.1, 907.7.2, 907.8, 907.8.2, 907.8.4, 917.1, 1103.3.2, 1203.2.4, 1207.5.4, 1207.6.1.2.3, 1207.6.1.2.4, Table 1207.7, 2810.11

76—16: Standard for the Fire Protection of Telecommunications Facilities

1207.1.2.1, 1207.2.1, 1207.3.1, 1207.3.7.1, 1207.4.1, 1207.5.1, 1207.5.2, 1207.5.3, 1207.5.5, Table 1207.6, 1207.6.2.3, Table 1207.7

77—14: Recommended Practice on Static Electricity

Table 2205.1

80—19: Standard for Fire Doors and Other Opening Protectives

705.2, 706.1, 1010.3.3, 1032.2.2

85—19: Boiler and Combustion Systems Hazards Code

Table 2205.1

86—19: Standard for Ovens and Furnaces

3001.1

92—18: Standard for Smoke Control Systems

909.7, 909.8

96—21: Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations

606.3, 904.13

99—21: Health Care Facilities Code

603.1.2, 603.5.1.1, 609.1, 1105.11.1, 1105.11.2, 1203.4.1, 1203.5.1,
5003.7.4, 5306.4, 5306.5

101—21: Life Safety Code -- as AMENDED by Part IV of this Code.

1030.6.2

105—19: Standard for Smoke Door Assemblies and Other Opening Protectives

705.2, 706.1, 909.20.4.1

110—19: Standard for Emergency and Standby Power Systems

913.5.2, 913.5.3, 1203.1.3, 1203.4, 1203.5

111—19: Standard on Stored Electrical Energy Emergency and Standby Power Systems

1203.1.3, 1203.4, 1203.5

120—20: Standard for Fire Prevention and Control in Coal Mines

Table 2205.1

130—20: Standard for Fixed Guideway Transit and Passenger Rail Systems

400.1

160—21: Standard for the Use of Flame Effects Before an Audience

308.3.2

170—18: Standard for Fire Safety and Emergency Symbols

1025.2.6.1

204—18: Standard for Smoke and Heat Venting

Table 901.6.1, 910.5.1, 910.5.2

211—19: Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances

603.2

232—17: Standard for the Protection of Records

3210.1.1

241—19: Standard for Safeguarding Construction, Alteration, and Demolition Operations

3301.1, 3308.2

253—19: Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source

804.3.1, 804.3.2, 804.4

260—19: Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture

805.1.1.1, 805.2.1.1, 805.3.1.1, 805.4.1.1

261—18: Standard Method of Test for Determining Resistance of Mock-up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes

805.2.1.1, 805.3.1.1, 805.4.1.1, 805.1.1.1

265—19: Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile or Expanded Vinyl Wall Coverings in Full Height Panels and Walls

803.5.1, 803.5.1.1

286—19: Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth

803.1, 803.1.1, 803.1.1.1, 803.3, 803.12, 803.13, 804.1.1, 804.2.4

289—19: Standard Method of Fire Test for Individual Fuel Packages

807.3, 807.4.1, 807.5.1.1, 808.3

303—21: Fire Protection Standard for Marinas and Boatyards

3603.5, 3603.6, 3604.2

318—18: Standard for the Protection of Semiconductor Fabrication Facilities

2703.16

326—20: Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair

3510.1

385—17: Standard for Tank Vehicles for Flammable and Combustible Liquids

5706.5.4.5, 5706.6, 5706.6.1, 5707.2

400—19: Hazardous Materials Code

5601.1.5, Table 6303.1.4, 6304.1.2, Table 6304.1.5(1), Table 6304.1.5(2), 6404.1, 6601.1, 6701.1

407—17: Standard for Aircraft Fuel Servicing

2006.2, 2006.3

409—16: Standard on Aircraft Hangars

914.8.3, Table 914.8.3, 914.8.3.1, 914.8.6

410—20: Standard on Aircraft Maintenance

2004.7

415—16: Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways

2001.2

484—19: Standard for Combustible Metals

320.3.4, 320.6, Table 2205.1

495—18: Explosive Materials Code

202, 911.1, 911.5, 5601.1.1, 5601.1.5, 5604.2, 5604.6.2, 5604.6.3, 5604.7.1, 5605.1, 5605.2.3, 5606.1, 5606.5.2.1, 5605.2.3, 5607.1, 5607.9, 5607.11, 5607.15

498—18: Standard for Safe Havens and Interchange Lots for Vehicles Transporting Explosives

5601.1.2

502—20: Standard for Road Tunnels, Bridges, and Other Limited Access Highways

403.10.6

505—18: Fire Safety Standard for Powered Industrial Trucks, Including Type Designations, Areas of Use, Conversions, Maintenance, and Operations

309.2, 4003.3.3

652—19: Standard on the Fundamentals of Combustible Dust

320.3.5, 2203.4.8, 2203.5, 2204.1, 2204.2, 2205.1.1

654—20: Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids

320.3.5, 2203.1, 2203.5, Table 2205.1

655—17: Standard for Prevention of Sulfur Fires and Explosions

Table 2205.1

664—20: Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities

2203.1, 2203.5, Table 2205.1, 2805.3

701—19: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films

807.3, 807.4.1, 807.5.1.2, 2603.5, 3104.2

703—21: Standard for Fire-Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials

803.4

704—17: Standard System for the Identification of the Hazards of Materials for Emergency Response

202, 608.8, 5003.2.2.2, 5003.5, 5003.10.2, 5005.1.10, 5005.1.12, 5005.2.1.1, 5005.4.4, 5503.4.1, 5704.2.3.2

720—15: Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment

915.5.1, 915.5.2, 915.6

750—19: Standard on Water Mist Fire Protection Systems

202, Table 901.6.1, 904.11.1.1, 904.13, 1207.5.5

780—17: Standard for the Installation of Lightning Protection Systems

4003.4

853—20: Installation of Stationary Fuel Cell Power Systems

1206.3, 1206.4, 1206.6.2, 1206.11, 1206.12

855—20: Standard for the Installation of Stationary Energy Storage Systems

1207

914—19: Code for Fire Protection of Historic Structures

1122—18: Code for Model Rocketry

5601.1.4

1123—18: Code for Fireworks Display

202, 5604.2, 5608.1, 5608.2.2, 5608.5, 5608.6

1124—06: Code for the Manufacture, Transportation, and Storage and Retail Sales of Fireworks and Pyrotechnic Articles -- as AMENDED by Section 5609.1.2 of this Code

202, 5601.1.3, 5604.2, 5605.1, 5605.3, 5605.4, 5605.5, 5609.1

1125—17: Code for the Manufacture of Model Rocket and High-Power Rocket Motors

5601.1.4

1126—21: Standard for the Use of Pyrotechnics Before a Proximate Audience

5604.2, 5605.1, 5608.1, 5608.2.2, 5608.4, 5608.5

1127—18: Code for High Power Rocketry

5601.1.4

1221—19: Standard for the Installation, Maintenance, and Use of Emergency Services Communications Systems

510.4.2, 510.5

2001—18: Standard on Clean Agent Fire Extinguishing Systems

Table 901.6.1, 904.10, 1207.5.5

2010—20: Standard for Fixed Aerosol Fire-Extinguishing Systems

Table 901.6.1, 904.12, 1207.5.5

State of Connecticut

Department of Emergency Services and Public Protection
1111 Country Club Road
Middletown, CT

Sections 29-357-1b to 29-357-12b, inclusive, of the Regulations of Connecticut State Agencies; Connecticut Fireworks and Special Effects Code.

Sections 29-349-106 to 29-378, inclusive of the Regulations of Connecticut State Agencies; Connecticut Storage, Transportation and Use, of Explosives and Blasting Agents Code.

State of Connecticut

Department of Administrative Services
450 Columbus Blvd.
Hartford, CT 06103

State Fire Prevention Code - 2022

The Connecticut State Fire Prevention Code adopted pursuant to section 29-291a of the Connecticut General Statutes.

Building Code - 2022

The Connecticut State Building Code adopted pursuant to section 29-252 of the Connecticut General Statutes.

Safety Code for Elevators and Escalators - 2018

Sections 29-192-1e to 29-192-16e, inclusive, of the Regulations of Connecticut State Agencies, concerning the Safety Code for Elevators and Escalator. Adopted pursuant to section 29-192 of the Connecticut General Statutes.

A P P E N D I X A
BOARD OF APPEALS

(Del) **Delete Appendix.**

A P P E N D I X B
FIRE-FLOW REQUIREMENTS FOR BUILDINGS

This Appendix is adopted by the State of Connecticut as guidance.

A P P E N D I X C
FIRE HYDRANT LOCATIONS AND DISTRIBUTION

(Del) **Delete Appendix.**

(D E L) A P P E N D I X D
FIRE APPARATUS ACCESS ROADS

(A D D) A P P E N D I X D
FIRE APPARATUS ACCESS

D1.2 Fire apparatus access.

D1.2.1 Fire department access and fire apparatus access roads shall be provided and maintained in accordance with this appendix.

D1.2.2 Access to structures or areas.

D1.2.2.1 Access box(es). The AHJ shall have the authority to require an access box(es) to be installed in an accessible location where access to or within a structure or area is difficult because of security. The access box(es) shall be of an approved type listed in accordance with UL 1037.

D1.2.2.2 Access to gated subdivisions or developments. The AHJ shall have the authority to require fire department access be provided to gated subdivisions or developments through the use of an approved device or system.

D1.2.2.3 Access maintenance. The owner or occupant of a structure or area, with required fire department access as specified in D1.2.2.1 or D1.2.2.2, shall notify the AHJ when the access is modified in a manner that could prevent fire department access.

D1.2.3 Fire apparatus access roads.

D1.2.3.1 Required access.

D1.2.3.1.1 Approved fire apparatus access roads shall be provided for every facility, building, or portion of a building hereafter constructed or relocated.

D1.2.3.1.2 Fire apparatus access roads shall consist of roadways, fire lanes, parking lot lanes, or a combination thereof.

D1.2.3.1.3 The provisions of D1.2.3.1 through D1.2.3.2.1 shall be permitted to be modified by the AHJ where any of the following conditions exists:

- (1) Agricultural buildings having an area not exceeding 400 square feet (37m²)
- (2) Sheds and other detached buildings having an area not exceeding 400 square feet (37m²)

D1.2.3.1.4 When fire apparatus access roads cannot be installed due to location on property, topography, waterways, nonnegotiable grades, or other similar conditions, the AHJ shall be authorized to require additional fire protection features.

D1.2.3.2 Access to building.

D1.2.3.2.1 A fire apparatus access road shall extend to within 50 ft (15 m) of at least one exterior door that can be opened from the outside and that provides access to the interior of the building.

D1.2.3.2.1.1 Where a one- or two-family dwelling, or townhouse, is protected with an approved automatic sprinkler system that is installed in accordance with Section 13.3, the distance in D1.2.3.2.1 shall be permitted to be increased to 150 ft (46 m).

D1.2.3.2.2 Fire apparatus access roads shall be provided such that any portion of the facility or any portion of an exterior wall of the first story of the building is located not more than 150 ft (46 m) from fire apparatus access roads as measured by an approved route around the exterior of the building or facility.

D1.2.3.2.2.1 Where buildings are protected throughout with an approved automatic sprinkler system that is installed in accordance with NFPA 13, NFPA 13R, or NFPA 13D, the distance in D1.2.3.2.2 shall be permitted to be increased to 450 ft (137 m).

D1.2.3.3 Multiple access roads. More than one fire apparatus access road shall be provided when it is determined by the AHJ that access by a single road could be impaired by vehicle congestion, condition of terrain, climate conditions, or other factors that could limit access.

D1.2.3.5 Specifications.

D1.2.3.5.1 Dimensions.

D1.2.3.5.1.1 Fire apparatus access roads shall have an unobstructed width of not less than 20 ft (6.1 m).

D1.2.3.5.1.1.1 Where approved by the AHJ, the width of fire apparatus access roads shall be permitted to be less than the minimum specified in D1.2.3.5.1.1.

D1.2.3.5.1.1.2 The width of fire apparatus access roads shall be increased when the minimum width specified in D1.2.3.5.1.1 is not adequate to accommodate fire apparatus.

D1.2.3.5.1.2 Fire apparatus access roads shall have an unobstructed vertical clearance of not less than 13 ft 6 in. (4.1 m).

D1.2.3.5.1.2.1 Vertical clearance shall be permitted to be reduced where approved by the AHJ, provided such reduction does not impair access by fire apparatus, and approved signs are installed and maintained indicating the established vertical clearance when approved.

D1.2.3.5.1.2.2 Vertical clearances shall be increased when vertical clearances are not adequate to accommodate fire apparatus.

D1.2.3.5.2 Surface. Fire apparatus access roads shall be designed and maintained to support the imposed loads of fire apparatus and shall be provided with an all-weather driving surface.

D1.2.3.5.3 Turning radius.

D1.2.3.5.3.1 The turning radius of a fire apparatus access road shall be as approved by the AHJ.

D1.2.3.5.3.2 Turns in fire apparatus access roads shall maintain the minimum road width.

D1.2.3.5.3.3 Fire apparatus access roads connecting to roadways shall be provided with curb cuts extending at least 2 ft (0.61 m) beyond each edge of the fire apparatus access road.

D1.2.3.5.4 Dead ends. Dead-end fire apparatus access roads in excess of 150 ft (46 m) in length shall be provided with approved provisions for the fire apparatus to turn around.

D1.2.3.5.5 Bridges.

D1.2.3.5.5.1 When a bridge is required to be used as part of a fire apparatus access road, it shall be constructed and maintained in accordance with nationally recognized standards.

D1.2.3.5.5.2 The bridge shall be designed for a live load sufficient to carry the imposed loads of fire apparatus.

D1.2.3.5.5.3 Vehicle load limits shall be posted at both entrances to bridges where required by the AHJ.

D1.2.3.5.6 Grade.

D1.2.3.5.6.1 The gradient for a fire apparatus access road shall not exceed the design limitations of the fire apparatus of the fire department and shall be subject to approval by the AHJ.

D1.2.3.5.6.2 The angle of approach and departure for any means of fire apparatus access road shall not exceed 1 ft drop in 20 ft (0.3 m drop in 6 m) or the design limitations of the fire apparatus of the fire department and shall be subject to approval by the AHJ.

D1.2.3.5.7 Traffic calming devices. The design and use of traffic calming devices shall be approved by the AHJ.

D1.2.3.6 Marking of fire apparatus access road.

D1.2.3.6.1 Where required by the AHJ, approved signs, approved roadway surface markings, or other approved notices shall be provided and maintained to identify fire apparatus access roads or to prohibit the obstruction thereof or both.

D1.2.3.6.2 A marked fire apparatus access road shall also be known as a fire lane.

D1.2.4 Obstruction and control of fire apparatus access road.

D1.2.4.1 General.

D1.2.4.1.1 The required width of a fire apparatus access road shall not be obstructed in any manner, including by the parking of vehicles.

D1.2.4.1.2 Minimum required widths and clearances established under D1.2.3.5 shall be maintained at all times.

D1.2.4.1.3 Facilities and structures shall be maintained in a manner that does not impair or impede accessibility for fire department operations.

D1.2.4.1.4 Entrances to fire apparatus access roads that have been closed with gates and barriers in accordance with D1.2.4.2.1 shall not be obstructed by parked vehicles.

D1.2.4.2 Closure of accessways.

D1.2.4.2.1 The AHJ shall be authorized to require the installation and maintenance of gates or other approved barricades across roads, trails, or other accessways not including public streets, alleys, or highways.

D1.2.4.2.2 Where required, gates and barricades shall be secured in an approved manner.

D1.2.4.2.3 Roads, trails, and other accessways that have been closed and obstructed in the manner prescribed by D1.2.4.2.1 shall not be trespassed upon or used unless authorized by the owner and the AHJ.

D1.2.4.2.4 Public officers acting within their scope of duty shall be permitted to access restricted property identified in D1.2.4.2.1.

D1.2.4.2.5 Locks, gates, doors, barricades, chains, enclosures, signs, tags, or seals that have been installed by the fire department or by its order or under its control shall not be removed, unlocked, destroyed, tampered with, or otherwise vandalized in any manner.

D1.2.4.2.6 Gates shall comply with D1.2.4.2.6.1 and D1.2.4.2.6.2.

D1.2.4.2.6.1 Electric gate operators and systems, where provided, shall be installed, maintained, listed, and labeled in accordance with UL 325, *Door, Drapery, Gate, Louver, and Window Operators and Systems*.

D1.2.4.2.6.2 Gates intended for automatic operation shall be designed, constructed, installed, and maintained to comply with ASTM F2200, *Standard Specification for Automated Vehicular Gate Construction*.

D1.2.4.2.7 When authorized by the AHJ, public officers acting within their scope of duty shall be permitted to obtain access through secured means identified in D1.2.4.2.1.

A P P E N D I X E

HAZARD CATEGORIES

This Appendix is adopted by the State of Connecticut as guidance.

A P P E N D I X F

HAZARD RANKING

This Appendix is adopted by the State of Connecticut as guidance.

A P P E N D I X G

CRYOGENIC FLUIDS – WEIGHT AND VOLUME EQUIVALENTS

This Appendix is adopted by the State of Connecticut as guidance.

A P P E N D I X H

HAZARDOUS MATERIALS MANAGEMENT PLAN (HMMP) AND HAZARDOUS MATERIALS INVENTORY STATEMENT (HMIS) INSTRUCTIONS

This Appendix is adopted by the State of Connecticut.

(Add) **SECTION H100**
Reference to Connecticut General Statutes

(Add) **H100.1 Manufacturing establishments.** Manufacturing establishments, as defined in section 29-307a of the Connecticut General Statutes, shall comply with the reporting requirements found in section 29-307a of the Connecticut General Statutes.

A P P E N D I X I
FIRE PROTECTION SYSTEMS – NONCOMPLIANT CONDITIONS

This Appendix is adopted by the State of Connecticut.

A P P E N D I X J
BUILDING INFORMATION SIGN

This Appendix is adopted by the State of Connecticut as guidance.

A P P E N D I X K
CONSTRUCTION REQUIREMENTS FOR EXISTING AMBULATORY CARE FACILITIES

(Del) **Delete Appendix.**

A P P E N D I X L
REQUIREMENTS FOR FIRE FIGHTER AIR REPLENISHMENT SYSTEMS

(Del) **Delete Appendix.**

A P P E N D I X M
HIGH-RISE BUILDINGS – RETROACTIVE AUTOMATIC SPRINKLER REQUIREMENT

(Del) **Delete Appendix.**

A P P E N D I X N
INDOOR TRADE SHOWS AND EXHIBITIONS

This Appendix is adopted by the State of Connecticut as amended.

(Amd) **N106.1 Automatic sprinkler systems.** An *approved automatic sprinkler system* in accordance with Section 903.3.1.1 of this code shall be provided in covered booths exceeding 400 square feet (37 m²) in floor area per level.

(Amd) **N106.2 Fire alarm and detection.** Each covered booth with a floor area exceeding 400 square feet (37 m²) on any level shall be provided with an *approved fire alarm system* in accordance with Section 907.2.

PART IV—Existing Buildings/Occupancies

Amendments to the 2021 NFPA 101[®], Life Safety Code

CHAPTER 1 *

ADMINISTRATION

(Del) **1.1.1** Delete section.

(Del) **1.1.6 Injuries from Falls.** Delete section.

(Amd) **1.3.1** This Part shall only apply to an occupancy or use located within buildings or structures, or portions thereof that existed, or for which a building permit was applied for, prior to January 1, 2006.

Part III of this code shall be applicable for buildings or structures, or portions thereof for which a building permit was applied for on or after December 31, 2005.

Part III of this code shall apply to all buildings or structures, or portions thereof, undergoing a change of occupancy classification or sub-classifications.

The design and construction of new structures shall comply with Part III of this code.

Repairs, alterations and additions to existing structures shall comply with Part III of this code.

For existing occupancies subject to an abatement order for violations of Part IV of this code, only new fire protection, electrical and mechanical system work shall be subject to the requirements of Part III.

Where the wording of a section in NFPA 101[®] *Life Safety Code*[®] says 'Where required by Chapters 11 through 43' it shall be read as 'Where required by Chapters 11 through 42'.

(Del) **1.4.3* Equivalent Compliance.** Delete section See Part I for modifications.

CHAPTER 2

REFERENCED PUBLICATIONS

(Amd) **2.2 NFPA Publications.** National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471. The documents referenced in this section, shall be considered part of the requirements of this code to the extent called for by this code. In addition to the referenced publications found in Chapter 2, the following are added.

NFPA 70 2020 edition as amended by the State Building Code.

415 2021 ed

731 2020 ed

CHAPTER 3 DEFINITIONS

(Amd) **3.3.37* Building.** Any structure used or intended for supporting or sheltering any use or occupancy. For application of this code, each portion of a building completely separated from other portions by fire walls which have been designed and constructed in accordance with the State Building Code and have been approved by the building official shall be considered separate buildings.

(Amd) **3.3.66* Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.

(Amd) **3.3.68 Dwelling Unit.** One or more rooms arranged for the use of one or more individuals living together, providing complete, independent living facilities, including permanent provisions for living, sleeping, eating, cooking and sanitation.

(Amd) **3.3.68.1 One- and Two-Family Dwelling Unit.** A building that contains not more than two dwelling units, each dwelling unit is occupied by members of a single family with not more than six outsiders, if any, accommodated in rented rooms.

(Amd) **3.3.68.2. One Family Dwelling Unit.** A building that consists solely of a single dwelling unit with independent permanent cooking and bathroom facilities which the dwelling unit is occupied by members of a single family with not more than six outsiders, if any, accommodated in rented rooms.

(Amd) **3.3.68.3. Two-Family Dwelling Unit.** A building that consists solely of two dwelling units with permanent cooking and bathroom facilities and each dwelling unit is occupied by members of a single family with not more than six outsiders, if any, accommodated in rented rooms.

(Amd) **3.3.99* Fire Code.** The Connecticut State Fire Prevention Code adopted pursuant to section 29-291a of the Connecticut General Statutes.

(Amd) **3.3.198.3 * Business Occupancy.** An occupancy used for the transaction of business other than mercantile. A business occupancy shall also include a training and skill development not in a school or academic program.

(Amd) **3.3.198.5* Detention and Correctional Occupancy.** An occupancy, other than one whose primary intended use is healthcare, ambulatory health care, or residential board and care, used to lawfully incarcerate or lawfully detain four or more persons under varied degrees of

restraint or security where such occupants are mostly incapable of self-preservation because of security measures not under the occupants' control.

(Amd) **3.3.198.6* Educational Occupancy.** An occupancy used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week. Training and skill development not within a school or academic program shall be classified as business occupancies.

(Amd) **3.3.254* Self-Preservation (Day-Care Occupancy).** The ability of a client to evacuate a day-care occupancy without direct intervention by a staff member. Clients under the age of 3 years shall be considered incapable of self-preservation.

(Add) **3.4 Connecticut Specific Definitions**

(Add) **3.4.1 Bed and Breakfast or Bed and Breakfast Establishment.** A building:

- (1) That provides sleeping accommodations to the public for a fee for no more than 16 persons with guest rooms limited to the first or second floor of the structure,
- (2) Where the owner occupies the facility or an adjacent property as his or her primary place of residence,
- (3) Where cooking or food warming of any type is not allowed in guest rooms, and
- (4) That has a maximum of three stories in height and does not contain a mixed occupancy.

(Add) **3.4.2 In-home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit, shall be classified as a single-family dwelling.

(Add) **3.4.3 Group B College Occupancies.** A building, structure, or portion thereof that is of a Group B Business occupancy classification and associated with a facility of higher education above the twelfth grade. This definition does not include training or skill development facilities.

(Add) **3.4.4 Group B Medical and Dental Occupancies.** Group B medical and dental occupancies that provide services or treatment for four or more patients who may simultaneously be rendered incapable of taking action for self-preservation under emergency conditions. The occupancy shall include, but not be limited to, the following:

- (1) Outpatient clinics with general anesthesia or life-support equipment;
- (2) Dental centers providing treatment under general anesthesia;
- (3) One-day surgical centers;
- (4) Physician's offices providing treatment under general anesthesia.

Facilities such as the above that do not provide general anesthesia or life-support equipment simultaneously to four or more patients shall be classified as Group B Business occupancy.

(Add) **3.4.5 In-home industrial occupancies, other than high hazard industrial occupancies.** Customary in-home industrial occupancies, located within a single-family dwelling premises, in which processing, assembling, mixing, packaging, finishing, decorating or repair operations are

conducted and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling premises, shall be classified as a single-family residential occupancy.

(Add) **3.4.6 Fireworks.** Fireworks has the same meaning as provided in section 29-356 of the Connecticut General Statutes and includes any device that meets the definition of 1.3G fireworks and 1.4G fireworks, but excludes sparklers and fountains, as defined in section 29-356 of the Connecticut General Statutes.

Fireworks, 1.3G. Large fireworks devices, which are *explosive materials*, intended for use in fireworks displays and designed to produce audible or visible effects by combustion, *deflagration* or *detonation*. Such 1.3G fireworks include, but are not limited to, firecrackers containing more than 130 milligrams (2 grains) of explosive composition, aerial shells containing more than 40 grams of pyrotechnic composition and other display pieces which exceed the limits for classification as 1.4G fireworks. Such 1.3G fireworks are also identified as Fireworks, UN-0335 pursuant to 49.CFR 172.101.

Fireworks, 1.4G. Small fireworks devices containing restricted amounts of pyrotechnic composition designed primarily to produce visible or audible effects by combustion or *deflagration* which comply with the construction, chemical composition and labeling requirements for Fireworks, UN 0336, pursuant to CFR 172.101 and those set forth in 16 CFR Parts 1500 and 1507.

(Add) **3.4.7 Sparklers and Fountains.** The terms “sparklers” and “fountains” have the same meanings as provided in section 29-356 of the Connecticut General Statutes.

CHAPTER 4

GENERAL

(Amd) **4.4.1 Options.** Life safety meeting the goals and objectives of Sections 4.1 and 4.2 shall be provided in accordance with the Prescriptive –based provisions per Section 4.4.2.

(Del) **4.4.3** Delete section.

(Del) **4.5 Fundamental Requirements.** Delete section.

(Del) **4.6.1.2** Delete section.

(Del) **4.6.1.3** Delete section.

(Del) **4.6.4 Historic Buildings.** Delete section.

(Del) **4.6.5* Modification of Requirements for Existing Buildings.** Delete section.

(Del) **4.6.7.1** Delete section.

(Del) **4.6.7.2** Delete section.

(Del) **4.6.10.2*** Delete section.

(D E L) C H A P T E R 5 P E R F O R M A N C E - B A S E D O P T I O N

(Del) Delete chapter in its entirety.

C H A P T E R 6 C L A S S I F I C A T I O N O F O C C U P A N C Y A N D H A Z A R D O F C O N T E N T S

(Amd) **6.1.3.1* Educational Occupancy.** An occupancy used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week. Training and skill development not within a school or academic program shall be classified as business occupancies.

(Amd) **6.1.7.1 Detention and Correctional Occupancy.** An occupancy, other than one whose primary intended use is healthcare, ambulatory health care, or residential board and care, used to lawfully incarcerate or lawfully detain four or more persons under varied degrees of restraint or security where such occupants are mostly incapable of self-preservation because of security measures not under the occupants' control.

(Amd) **6.1.8.1.1 One- and Two-Family Dwelling Unit.** A building that contains not more than two dwelling units, each dwelling unit is occupied by members of a single family with not more than six outsiders, if any, accommodated in rented rooms.

(Amd) **6.1.8.1.4* Definition—Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.

(Add) **6.1.8.1.6 Definition—Bed and Breakfast or Bed and Breakfast Establishment.** An existing building:

- (1) That provides sleeping accommodations to the public for a fee for no more than 16 persons with guest rooms limited to the first or second floor of the structure;
- (2) Where the owner occupies the facility or an adjacent property as his or her primary place of residence;
- (3) Where cooking or food warming of any type is not allowed in guest rooms; and
- (4) That has a maximum of three stories in height and does not contain a mixed occupancy.

(Amd) **6.1.11.1 Business Occupancy.** An occupancy used for the transaction of business other than mercantile. A business occupancy shall also include a training and skill development not in a school or academic program.

(Amd) **6.1.11.2 In-Home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit, shall be classified as a single-family residential occupancy.

(Add) **6.1.11.3 Group B College Occupancies.** A building, structure, or portion thereof that is of a Group B Business occupancy classification and associated with a facility of higher education above the twelfth grade. This definition does not include training or skill development facilities.

(Add) **6.1.11.4 Group B Medical and Dental Occupancies.** Group B medical and dental occupancies that provide services or treatment for four or more patients who may simultaneously be rendered incapable of taking action for self-preservation under emergency conditions. The occupancy shall include, but not be limited to, the following:

- Outpatient clinics with general anesthesia or life-support equipment;
- Dental centers providing treatment under general anesthesia;
- One-day surgical centers;
- Physician's offices providing treatment under general anesthesia.

Facilities such as the above that do not provide general anesthesia or life-support equipment simultaneously to four or more patients shall be classified as Group B Business occupancy.

(Amd) **6.1.12.2 In-Home Industrial Occupancies, Other Than High Hazard Industrial Occupancies.** Customary in-home industrial occupancies, located within a single-family dwelling premises, in which processing, assembling, mixing, packaging, finishing, decorating or repair operations are conducted and employ a maximum of one employee within the dwelling in addition to the residents of the dwelling premises, shall be classified as a single-family residential occupancy.

(Amd) **6.1.14.1.1** Multiple occupancies shall comply with the requirements of Sections 6.1.14.1 and 6.1.14.3.

(Del) **6.1.14.4 Separated occupancies.** Delete section in its entirety.

CHAPTER 7 MEANS OF EGRESS

(Amd) **7.1.3.2.1** Where this Code requires an exit to be separated from other parts of the building, the separating construction shall meet the requirements of Section 8.2 and the following:

- (1) *The separation shall have a minimum 1-hour fire resistance rating where the exit connects three or fewer stories. Existing wall or ceiling finishes consisting of wood or

metal lath and plaster in good repair satisfy this requirement in non-high-rise buildings.

(2) The separation specified in Section 7.1.3.2.1(1), other than an existing separation, shall be supported by construction having not less than a 1-hour fire resistance rating.

(3) *The separation shall have a minimum 2-hour fire resistance rating where the exit connects four or more stories, unless one of the following conditions exists.

(a) In existing non-high-rise buildings, existing exit stair enclosures shall have a minimum 1-hour fire resistance rating. Existing wall or ceiling finishes consisting of wood or metal lath and plaster in good repair satisfy this requirement in non-high-rise buildings.

(b) In existing buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, existing exit stair enclosures shall have a minimum 1-hour fire resistance rating.

(c) The minimum 1-hour enclosures in accordance with Sections 29.2.2.1.2, and 31.2.2.1.2 shall be permitted as an alternative to the requirement of 7.1.3.2.1(3).

(4) The minimum 2-hour fire-resistance rated separation required by 7.1.3.2.1 (3) shall be constructed of an assembly of noncombustible or limited-combustible materials and shall be supported by construction having a minimum 2-hour fire resistance rating unless otherwise permitted by 7.1.3.2.1 (6).

(5)* Structural elements, or portions thereof, that support exit components and either penetrate into a fire-resistance-rated assembly or are installed within a fire-resistance-rated wall assembly shall be protected, as a minimum, to the fire resistance rating required by 7.1.3.2.1(1) or 7.1.3.2.1(3).

(6) Fire-retardant-treated wood enclosed in noncombustible or limited-combustible materials shall be permitted in accordance with NFPA 220.

(7) Openings in the separation shall be protected by fire door assemblies equipped with door closers complying with 7.2.1.8.

(8)* Openings in exit enclosures shall be limited to door assemblies from normally occupied spaces and corridors and door assemblies for egress from the enclosure, unless one of the following conditions exists:

(a) Vestibules that separate normally unoccupied spaces from an exit enclosure shall be permitted, provided the vestibule is separated from adjacent spaces by corridor walls and related opening protectives as required for the occupancy involved but not less than a smoke partition in accordance with Section 8.4.

(b) In buildings of Type I or Type II construction, as defined in NFPA 220 (see 8.2.1.2), fire-protection-rated door assemblies to normally unoccupied building service equipment support areas as addressed in Section 7.14 shall be permitted, provided the space is separated from the exit enclosure by fire barriers as required by 7.1.3.2.1(3).

(c) Openings in exit passageways in mall buildings as provided in Chapters 36 and 37 shall be permitted.

(d) In buildings of Type I or Type II construction, as defined in NFPA 220 (see 8.2.1.2), existing fire-protection-rated door assemblies to interstitial spaces shall be permitted, provided that such spaces meet all of the following criteria:

- i. The space is used solely for distribution of pipes, ducts, and conduits.
 - ii. The space contains no storage.
 - iii. The space is separated from the exit enclosure in accordance with Section 8.3.
- (e) Existing openings to mechanical equipment spaces protected by approved existing fire-protection-rated door assemblies shall be permitted, provided that the following criteria are met:
 - i. The space is used solely for non-fuel-fired mechanical equipment.
 - ii. The space contains no storage of combustible materials.
 - iii. The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7 or the mechanical equipment space is provided with sprinkler protection in accordance with Section 9.7 and provided with complete smoke detection in accordance with Section 9.6.
- (9) Penetrations into, and openings through, an exit enclosure assembly shall be limited to the following:
 - (a) Door assemblies permitted by 7.1.3.2.1(8)
 - (b)* Electrical conduit serving the exit enclosure
 - (c) Pathways for devices for security and communication systems serving the exit enclosure, where pathways are installed in metal conduit
 - (d)* Required exit door openings
 - (e) Ductwork and equipment necessary for independent stair pressurization
 - (f) Water or steam piping necessary for the heating or cooling of the exit enclosure
 - (g) Sprinkler piping
 - (h) Standpipes
 - (i) Existing penetrations
 - (j) Penetrations for fire alarm circuits, where the circuits are installed in metal conduit
- (10) Penetrations or communicating openings shall be prohibited between adjacent exit enclosures.
- (11) All penetrations in fire barriers separating the exit from other parts of the building shall be protected in accordance with 8.3.4.
- (12) Membrane penetrations shall be permitted on the exit access side of the exit enclosure and shall be protected in accordance with 8.3.4.7.

(Add) **7.1.5.1.1** In existing buildings, projections from the ceiling are permitted but not less than 72 inches (1,830 mm) nominal above the finished floor where the projection is provided with padding and illumination by both normal and emergency sources.

(Add) **7.1.5.4** Door closers and stops shall not reduce the headroom to less than 78 inches (1,981 mm).

(Add) **7.1.9.1 Security Devices.** Any security device or system that emits any medium that could obscure a means of egress in any building, structure or premises shall be prohibited.

(Add) **7.1.10.1.1 Clearance for Inclined Lifts on Stairways** Where a platform or chair lift is installed on an exit stair in an existing building, the minimum clear width on the stair when the inclined lift is in the down or operating position shall be:

- (1) 18 inches (460 mm) when the stair serves fewer than 10 people
- (2) 22 inches (560 mm) when the stair serves fewer than 50 people
- (3) As required by this code when the stair serves 50 or more people

(Amd) **7.2.1.3.3** Thresholds at door openings shall not exceed ½ in. (13 mm) in height or ¾ in. (19.1 mm) in height for sliding doors serving dwelling units.

(Amd) **7.2.1.6.2.1** Where permitted in Chapter 11 through Chapter 42, inclusive, entrance doors to buildings and tenant spaces in the means of egress may be equipped sensor-released electrical lock hardware that prevents egress, provided the following criteria are met:

- (1) A sensor shall be provided on the egress side, arranged to electrically unlock the door leaf in the direction of egress upon detection of an approaching occupant.
- (2) Door leaves shall automatically unlock in the direction of egress upon loss of power to the sensor or to the part of the access control system that locks the door leaves.-
- (3) The doors shall be arranged to unlock in the direction of egress from a manual release device complying with all of the following criteria:
 - (a) A manual release device shall be located on the egress side 40 in. to 48 in. (1015 mm to 1220 mm) vertically above the floor, within 60 inches (1525 mm) of the secured door openings.
 - (b) The manual release device shall be readily accessible and clearly identified by a sign that reads as follows: "PUSH TO EXIT".
 - (c) When operated, the manual release device shall result in direct interruption of power to the lock – independent of the locking system electronics – and the lock shall remain unlocked for not less than 30 seconds.
- (4) Activation of the building fire-protective signaling system, if provided, shall automatically unlock the door leaves in the direction of egress, and the door leaves shall remain unlocked until the fire-protective signaling system has been manually reset.
- (5) Activation of the manual fire alarm boxes that activate the building fire protective signaling system specified in Section 7.2.1.6.2(4) shall not be required to unlock the door leaves.
- (6) Activation of the building automatic sprinkler or fire detection system, if provided, shall automatically unlock the door leaves in the direction of egress, and the door leaves shall remain unlocked until the fire-protective signaling system has been manually reset.
- (7) The egress side of sensor- released electrically locked egress doors, other than existing sensor-released electrically locked egress doors, shall be provided with emergency lighting in accordance with Section 7.9.

(Amd) **7.2.2.1.2** The requirements of Section 7.2.2.1.1 shall not apply to aisle stairs as provided in Chapter 13.

(Add) **7.2.2.2.1.1.1** Existing stairs may remain in use if the minimum width clear of all obstructions,

except projections not more than 4½ inches (114 mm) at or below handrail height on each side is 28 inches (710 mm) and the total occupant load of all floors served by the stair is fewer than 30 persons.

(Add) **7.2.2.2.1.1.2** Existing projections from the ceiling in existing stairs may conform to the requirements of 7.1.5.1.1.

(Add) **7.2.2.2.4.4** Existing stairs containing winders may also be continued in use provided all of the following are met:

- (1) Such winders have a minimum depth of tread of 7½ inches (191 mm) at a point 12 inches (305 mm) from the narrowest edge.
- (2) The nosing of each winder tread shall be made readily visible by the application of a 2 inches wide stripe for the full width of the tread that is of a distinctive or contrasting color.
- (3) The area of the winder shall be provided with both normal illumination and emergency lighting in accordance with Section 7.8 and Section 7.9.
- (4) A handrail shall be provided for the full length of stair travel at the side of the stair having the widest tread portion.

(Amd) **7.2.2.3.6.1** Variation in excess of 3/8 inches (9.5 mm) in the depth of adjacent treads or in the height of adjacent risers shall be prohibited unless otherwise permitted in Section 7.2.2.3.6.3.

(Amd) **7.2.2.4.5.5*** Handrails shall be installed to provide a clearance of not less than 1½ inches (38 mm) between the handrail and the wall to which it is fastened.

(Del) **7.2.2.5.2* Exposures.** Delete section.

(Amd) **7.2.2.6.3.1*** Outside stairs shall be separated from the interior of the building by construction with the fire resistance rating required for enclosed stairs with fixed or self-closing opening protectives, except as follows:

- (1) Outside stairs serving an exterior exit access balcony that has two remote outside stairways or ramps shall be permitted to be unprotected.
- (2) In existing buildings, existing outside stairs serving not in excess of four adjacent stories, including the story of exit discharge, may be unprotected where there is a remotely located second exit.
- (3) The fire resistance rating of a separation extending 10 feet (3,050 mm) from the stairs shall not be required to exceed 1 hour where openings have not less than a ¾-hour fire protection rating.
- (4) Outside stairs in existing buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7 shall be permitted to be unprotected.

(Amd) **7.2.8.2.2** The requirements of Section 7.2.8.2 shall be permitted to be modified by the State Fire Marshal where automatic sprinkler protection is provided, in occupancies limited to low hazard contents or where other special conditions exist.

(Del) 7.2.12.3.2* Delete section.

(Amd) **Table 7.3.1.2 Occupant Load Factor**

Use	(ft²/person)^a	(m²/person)^a
Assembly Use		
Concentrated use, w/out fixed seating	7 net	0.65 net
Less concentrated use, w/out fixed seating	15 net	1.4 net
Bench-type seating	1 person/18 linear in.	1 person/455 linear mm
Fixed seating	Use number of fixed seats	
Waiting spaces	See 13.1.7.2.	See 13.1.7.2.
Kitchens	100	9.3
Exhibit gallery and Museum	30 net	2.8 net
Library stack areas	100	9.3
Library reading rooms	50 net	4.6 net
Swimming pools	50 (water surface)	4.6 (water surface)
Swimming pool decks	30	2.8
Exercise rooms	50	4.6
Stages	15 net	1.4 net
Lighting and access catwalks, galleries, gridirons	100 net	9.3 net
Casinos and similar gaming areas	11	1
Skating rinks	50	4.6
Airport terminal areas		
Baggage Claim	20	1.9
Baggage handling	300	27.9
Concourse	100	9.3
Waiting areas	15	1.4
Business Use (other than below)		
Concentrated Business Use ^b	50	4.6
Air traffic control tower tower observation levels	40	3.7
Collaboration rooms/spaces <= 450 ft ² (41.8 m ²) in area ^b .	30	2.5
Collaboration rooms/spaces > 450 ft ² (41.8 m ²) in area ^b	15	1.4
Day-Care Use	35 net	3.3 net
Detention and Correctional Use	120	11.1
Educational Use		
Classrooms	20 net	1.9 net
Shops, laboratories, vocational rooms	50 net	4.6 net
Health Care Use		
Inpatient treatment departments	240	22.3
Sleeping departments	120	11.1

Ambulatory health care	150	13
Outpatient treatment departments	100	9.3
Industrial Use		
General and high hazard industrial	100	9.3
Special-purpose industrial	MP	MP
Mercantile Use		
Sales area on street floor ^{b,c}	30	2.8
Sales area on two or more street floors ^c	40	3.7
Sales area on floor below street floor ^c	30	2.8
Sales area on floors above street floor ^c	60	5.6
Floors or portions of floors used only for offices	See business use.	See business use.
Floors or portions of floors used only for storage, receiving, and shipping, and not open to general public	300	27.9
Mall buildings ^d	Per factors applicable to use of space ^e	
Residential Use		
Hotels and dormitories	200	18.6
Apartment buildings	200	18.6
Board and care, large	200	18.6
Storage Use		
In storage occupancies	MP	MP
In mercantile occupancies	300	27.9
In other than storage and mercantile occupancies	500	46.5

MP: The occupant load is the maximum probable number of occupants present at any time.

^aAll factors are expressed in gross area unless marked “net.”

^bSee A7.3.1.2

^cFor determining occupant load in mercantile occupancies where, due to differences in the finished ground level of streets on different sides, two or more floors directly accessible from streets (not including alleys or similar back streets) exist, each such floor is permitted to be considered a street floor. The occupant load factor is one person for each 40 ft² (3.7 m²) of gross floor area of sales space.

^dFor determining occupant load in mercantile occupancies with no street floor, as defined in 3.3.283, but with access directly from the street by stairs or escalators, the floor at the point of entrance to the mercantile occupancy is considered the street floor.

^eFor any food court or other assembly use areas located in the mall that are not included as a portion of the gross leasable area of the mall building, the occupant load is calculated based on the occupant load factor for that use as specified in Table 7.3.1.2. The remaining mall area is not required to be assigned an occupant load.

^fThe portions of the mall concourse not used as gross leasable area are not required to be assessed an occupant load based on Table 7.3.1.2. However, means of egress from a mall concourse are required to be provided for an occupant load determined by dividing

the gross leasable area of the mall building (not including anchor stores) by the appropriate lowest whole number occupant load factor from Figure 7.3.1.2(a) or Figure 7.3.1.2(b). Each individual tenant space is required to have means of egress to the outside or to the mall based on occupant loads calculated by using the appropriate occupant load factor from Table 7.3.1.2. Each individual anchor store is required to have means of egress independent of the mall.

(Add) **7.4.1.6.1.1** The provisions of Section 7.4.1.6 shall not apply to buildings for which a building permit was issued prior to June 15, 1994.

(Amd) **7.7.1.2** Exit discharge paths to a public way shall have a width of not less than 28 inches (710 mm).

(Amd) **7.9.1.1*** Emergency lighting facilities for means of egress shall be provided in accordance with Section 7.9 for the following:

- (1) Buildings or structures where required in Chapter 11 through Chapter 42, inclusive, where the building or structure is required to have two or more means of egress.
- (2) Underground and limited-access structures as addressed in Section 11.7, where the building or structure is required to have two or more means of egress.
- (3) High-rise buildings as required by other sections of this code.
- (4) Doors equipped with delayed-egress locks.
- (5) Stair shaft and vestibule of smoke enclosures, for which the following also shall apply:
 - (a) The stair shaft and vestibule shall be permitted to include a standby generator that is installed for the smoke proof enclosure mechanical ventilations equipment.
 - (b) The standby generator shall be permitted to be used for the stair shaft and vestibule emergency lighting power supply.

(Del) **7.15 Occupant Evacuation Elevators.** Delete section in its entirety.

(Del) **7.16 Emergency Stair Travel Devices.** Delete section in its entirety.

CHAPTER 8 FEATURES OF FIRE PROTECTION

(Amd) **Table 8.3.3.2.2 Minimum Fire Protection Ratings for Opening Protectives in Fire-Resistance-Rating Assemblies.**

Component	Walls and Partitions (hr.)	Fire Door Assemblies (hr.)	Fire Window Assemblies (hr.)
	2	1½	NP

Elevator hoistways	1	1	NP
Vertical shafts (including stairways, exits, and refuse chutes)	2	1½	NP
	1	1	NP (¾ in other than exits)
Other than exits	½	1/3	(1/3 in other than exits)
Fire barriers	2	1½	NP
	1	¾	¾
Horizontal exits	2	1½	NP
Exit access corridors ¹	1	1/3	¾
	½	1/3	1/3
Smoke barriers ¹	½	1/3	¾
Smoke partitions ^{1,2}	½	1/3	1/3

Note: NP = not permitted.

¹ Fire doors are not required to have a hose stream test per NFPA 252.

² For residential board and care, see Section 33.2.3.1.1.

(Add) **8.3.3.2.4.1** Doors having a 20-minute fire protection rating or door assemblies consisting of door frames constructed of at least ¾ inches thick hardwood stock and 1¾ inches thick solid core doors that are self-closing and positive-latching may be used in vertical openings and in exit enclosures provided the building has either partial automatic sprinkler protection in accordance with Section 9.7 or a partial fire detection system in accordance with Section 9.6. These systems shall include either a sprinkler or fire detector opposite the center of and inside any door that opens into the exit, and provisions for occupant notification in accordance with Section 9.6.3.

(Add) **8.3.3.2.4.2** Doors having a 20-minute fire protection rating or door assemblies consisting of door frames constructed of at least ¾ inches thick hardwood stock and 1¾ inches thick solid core doors that are self-closing and positive-latching may be used in vertical openings and in exit enclosures provided the building has either full automatic sprinkler protection in accordance with Section 9.7 or a full fire detection system in accordance with Section 9.6.

(Del) **8.3.3.6.1** Delete section.

(Del) **8.3.3.6.2** Delete section.

(Del) **8.3.3.6.3** Delete section.

(Del) **8.3.3.6.4** Delete section.

(Del) **8.3.3.6.5** Delete section.

(Del) **8.3.3.6.6** Delete section.

(Del) **8.3.3.6.7** Delete section.

(Del) **8.3.3.6.8** Delete section.

(Del) **8.3.3.6.9** Delete section.

(Del) **8.3.3.6.10** Delete section.

(Amd) **8.6.7* Atriums.** Unless prohibited by Chapters 11 through Chapter 42 of this code, an atrium shall be permitted, provided that all of the following conditions are met:

- (1) The atrium is separated from the adjacent spaces by fire barriers with not less than a 1-hour fire resistance rating, with opening protectives for corridor walls, unless one of the following is met:
 - (a) The requirement of 8.6.7(1) shall not apply to existing, previously approved atriums.
 - (b) Any number of levels of the building shall be permitted to open directly to the atrium without enclosure, based on the results of the engineering analysis required in 8.6.7(5), except that two levels of the building may open directly to the atrium without enclosure or the need for the engineering analysis.
 - (c) *Glass walls and inoperable windows shall be permitted in lieu of the fire barriers where all the following are met:
 - i. Automatic sprinklers are spaced along both sides of the glass wall and the inoperable windows at intervals not to exceed 6 feet (1830 mm).
 - ii. The automatic sprinklers specified in 8.6.7(1)(c)i are located at a distance from the glass wall not to exceed 12 inches (305 mm) and arranged so that the entire surface of the glass is wet upon operation of the sprinklers.
 - iii. The glass wall is of tempered, wired, laminated, or ceramic glass held in place by a retention system that allows the glass framing system to deflect without breaking (loading) the glass before the sprinklers operate.
 - iv. The automatic sprinklers required by 8.6.7(1)(c)i are not required on the atrium side of the glass wall and the inoperable window where there is no walkway or other floor area on the atrium side above the main floor level.
 - v. Doors in the glass walls are of glass or other material that resists the passage of smoke.
 - vi. Doors in the glass walls are self-closing or automatic-closing upon detection of smoke.
 - vii. The glass is continuous vertically, without horizontal mullions, window treatments, or other obstructions that would interfere with the wetting of the entire glass surface.
- (2) Access to exits is permitted to be within the atrium, and exit discharge in accordance with 7.7.2 is permitted to be within the atrium.
- (3) The occupancy within the atrium meets the specifications for classification as low or ordinary hazard contents. (see 6.2.2.)
- (4) The entire building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless that area of a building adjacent to or above the atrium need not be sprinkled provided that portion of the building is separated from the atrium portion by a 2-hour fire barrier wall or horizontal assembly or both.
- (5) *For other than existing, previously approved atriums, and atriums connecting less than

three stories, an engineering analysis is performed that demonstrates that the building is designed to keep the smoke layer interface above the highest unprotected opening to adjoining spaces, or 6 feet (1830 mm) above the highest floor level of exit access open to the atrium, for a period equal to 1.5 times the calculated egress time or 20 minutes, whichever is greater.

- (6) *For other than existing, previously approved atriums, and atriums connecting less than three stories, where an engineered smoke control system is installed to meet the requirements of 8.6.7(5), the system is independently activated by each of the following:
- (a) Upon initiation of a smoke detection system or actuation of the required automatic sprinkler system within the atrium or areas open to the atrium.
 - (b) Manual controls that are readily accessible to the fire department.

(Amd) **8.6.9.1** Where permitted by Chapters 11 through Chapter 42, unenclosed vertical openings not concealed within the building construction shall be permitted as follows:

- (1) Such openings shall connect not more than two adjacent stories (one floor pierced only).
- (2) Such openings shall be separated from unprotected vertical openings serving other floors by a barrier complying with 8.6.5.
- (3) Such openings shall be separated from corridors, unless they are located within buildings protected throughout by an automatic sprinkler system in other than residential or institutional occupancies.
- (4) *In other than approved, existing convenience openings, such openings shall be separated from other fire or smoke compartments on the same floor.
- (5) *Such openings shall not serve as a required means of egress.

(Amd) **8.6.10.3 Openness.** Mezzanines shall be in accordance with Section 8.6.10.3.1, Section 8.6.10.3.2, Section 8.6.10.3.3, Section 8.6.10.3.4 or Section 8.6.10.3.5.

(Add) **8.6.10.3.3** A mezzanine or portions thereof are not required to be open to the room in which the mezzanines are located, provided the aggregate floor area of the enclosed space does not exceed 10 percent of the mezzanine area.

(Add) **8.6.10.3.4** In industrial facilities, mezzanines used for control equipment may be glazed on all sides.

(Add) **8.6.10.3.5** In industrial occupancies permitted to be of unlimited area by the State Building Code, mezzanines or portions thereof are not required to be open to the room in which the mezzanines are located, provided an approved fire alarm system is installed throughout the entire building or structure and notification appliances are installed throughout the mezzanines in accordance with the provisions of NFPA 72[®]. In addition, the fire alarm system shall be initiated by automatic sprinkler water flow.

(Amd) **8.7.3.1** The storage and handling of flammable liquids or gases shall be in accordance with the Connecticut State Fire Prevention Code.

(Amd) **8.7.3.3* Alcohol-Based Hand-Rub Dispensers.** Where permitted by Chapters 11 through 42, alcohol-based hand-rub dispensers shall be permitted provided they comply with the Connecticut State Fire Prevention Code.

CHAPTER 9

BUILDING SERVICE FIRE PROTECTION, and LIFE SAFETY EQUIPMENT

(Add) **9.2.3.1 Isolated Cooking Operations.** The requirements for the hood, grease removal devices, duct and fixed fire extinguishing system may be waived by the authority having jurisdiction for cooking operations in free standing tents, mobile units or other small buildings located greater than 30 feet from grandstands or other public buildings and occupied by employees only, when the clearance to combustibles, safety controls, portable fire extinguishers, staff training, fuel use, storage, and shut off of fuel, and electrical shut off for equipment are in compliance with this code.

(Del) **9.3.3 Acceptance Testing.** Delete section.

(Del) **9.3.5 Integrated System Testing.** Delete section.

(Amd) **9.4.2.1** New and existing elevators, escalators, dumbwaiters, and moving walks shall be installed and maintained in accordance with the requirements of the Connecticut Safety Code for Elevators and Escalators enforced by the Connecticut Department of Administrative Services.

(Del) **9.4.2.2** Delete section.

(Del) **9.4.2.3** Delete section.

(Del) **9.4.2.4** Delete section.

(Del) **9.4.3 Fire Fighters' Emergency Operations.** Delete section in its entirety.

(Del) **9.4.4 Number of Cars.** Delete section.

(Del) **9.4.5* Elevator Machine Rooms.** Delete section.

(Del) **9.4.6 Elevator Testing.** Delete section in its entirety.

(Del) **9.6.2.10.3 Smoke Alarms in Sleeping Rooms.** Delete section.

(Del) **9.6.2.10.3.1** Delete section.

(Amd) **9.6.2.10.4** Where two or more smoke alarms are required within a dwelling unit, suite of rooms, or similar area, they shall be arranged so that operation of any smoke alarm shall cause the alarm of all smoke alarms within the dwelling unit, suite of rooms, or similar area to sound,

except when:

- (1) Otherwise permitted by another section of this code.
- (2) Configurations provide equivalent distribution of the alarm signal.
- (3) Installation existed prior to October 16, 1999.

(Amd) **9.6.2.10.9** Smoke alarms shall receive their operating power as follows:

- (1) In buildings for which a building permit for new occupancy was issued on or after October 1, 1985, smoke alarms shall be powered by both alternating current (AC) and batteries (DC).
- (2) In buildings for which a building permit for new occupancy was issued on or after October 1, 1976, smoke alarms shall be powered by the household electrical service.
- (3) In buildings for which a building permit was issued prior to October 1, 1976, smoke alarms may be battery powered.

(Amd) **9.6.2.10.10** Unless otherwise provided by the manufacturer's instructions, smoke alarms shall not remain in service longer than 10 years from the date of manufacture. Combination smoke/carbon monoxide alarms shall be replaced when the end-of-life signal activates or 10 years from the date of manufacture, whichever comes first, unless otherwise provided by the manufacturer's instructions.

(Amd) **9.6.2.10.11** The alarms shall sound only within an individual dwelling unit, suite of rooms, or similar area and shall not actuate the building fire alarm system, unless otherwise permitted by the authority having jurisdiction.

(Amd) **9.6.3.2.4** Detectors in accordance with 23.3.4.3.1(2) shall not be required to activate the building evacuation system.

(Del) **9.6.3.3** Delete section.

(Add) **9.6.3.7.2.1** When selective occupant notification is utilized in accordance with Section 9.6.3.6.2 or Section 9.6.3.6.3, the portions of the building that do not receive the initial notification of alarm shall be separated from areas of the immediate emergency and initial evacuation by construction having a fire resistance rating of at least 1 hour.

(Amd) **9.7.1.2** Sprinkler piping serving not more than six sprinklers for any isolated hazardous area shall be permitted to be connected directly to a domestic water supply system having a capacity sufficient to provide 0.15 gallons per minute/square foot (6.1L/min/m²) throughout the entire enclosed area. Such system shall be installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, with respect to the materials and installation practices. An indicating shutoff valve, supervised in accordance with Section 9.7.2 or NFPA 13, Standard for the Installation of Sprinkler Systems, may be installed in an accessible, visible, location between the sprinklers and the connection to the domestic water supply.

(Del) **9.7.1.3** Delete section.

(Add) **9.7.1.6 Statutory requirements.** An automatic fire sprinkler system shall be installed in accordance with the provisions of Section 9.7.1 as required by the provisions of section 29-315 of the Connecticut General Statutes in effect on October 1, 1973. For the purpose of this section, building height shall be measured from the lowest level of fire department vehicle access to the floor of the highest occupiable story. (See Section 3.3.36.7) The provisions of Section 9.8.1 shall not apply to these systems.

(Add) **9.7.1.7 Electric Fire Pumps.** Buildings provided with standby electrical power for the purpose of continuing operations or occupancy shall provide standby power in accordance with Article 701 of the National Electrical Code for any electric fire pump installed to provide an adequate water supply or minimum operating pressure to a required automatic sprinkler system, except that existing installations may be continued in service subject to the approval of the authority having jurisdiction.

(Add) **9.10.1.1 Water Supply.** In buildings equipped throughout with an automatic sprinkler system where the highest floor level is not more than 150 feet above the lowest level of fire department vehicle access, Class I standpipes shall have an automatic or manual-wet supply.

(Add) **9.11.1.1** When a fire protection system is out of service for more than 4 hours in a 24-hour period, the AHJ shall be permitted to require the building to be evacuated or an approved fire watch to be provided for all portions left unprotected by the fire protection system shutdown until the fire protection system has been returned to service.

(Add) **9.11.3.3** The responsible person conducting an inspection, testing, or maintenance shall make records of all inspections, tests, and maintenance of the systems and its components and make the records available to the AHJ upon request. In the event of a system deficiency discovered during a required inspection or other event, the system shall be immediately tagged by such responsible person conducting the inspection noting the issue and date. The discovered deficiencies shall be noted on the inspection report and a copy of such report shall be immediately forwarded to the AHJ. Contact information for the responsible person shall be included in the report.

(Del) **9.11.4 Integrated Fire Protection and Life Safety System Testing.** Delete section in its entirety.

(Del) **9.13 Special Inspections and Tests.** Delete section in its entirety.

(Del) **9.14 Risk Analysis for Mass Notification Systems.** Delete section in its entirety.

(Del) **9.15.1.** Delete section.

(Del) **9.15.2.** Delete section.

(Add) **10.3.9.2.1 Natural Cut Christmas Trees.** Combustible vegetation, including natural cut Christmas trees shall be in accordance with Table 10.3.9.2.1.

(Add) Table 10.3.9.2.1

Table 10.13.1.1 Provisions for Christmas Trees by Occupancy

Occupancy	No Trees Permitted	Cut Tree Permitted With Automatic Sprinkler System	Cut Tree Permitted Without Automatic Sprinkler System	Balled Tree Permitted
Ambulatory health care				X
Apartment buildings		Within unit	Within unit	X
Assembly				X
Board and care				X
Business		X		X
Day-care		X		X
Detention and correctional	X			
Dormitories			**	X
Educational				X
Health care				X
Hotels				X
Industrial		X	X	X
Lodging and rooming		X		X
Mercantile		X		X
Storage		X	X	X

** Cut trees in dwelling units that are associated with supervisory personnel in dormitory occupancies are permitted subject to the approval of the AHJ.

CHAPTER 11
SPECIAL STRUCTURES AND HIGH-RISE BUILDINGS

(Amd) **11.7.3.4** Underground and limited access structures, and all areas and floor levels traversed in traveling to the exit discharge, shall be protected by an approved, supervised automatic sprinkler system in accordance with Section 9.10, unless such structures meet one of the following criteria:

- (1) They have an occupant load of 100 or fewer persons in existing underground or limited access portions of the structure.
- (2) The structure is a single-story underground or limited access structure that is permitted to have a single exit per Chapter 13 through Chapter 42.

(Del) **11.8.4.3 Risk Analysis for Mass Notification Systems.** Delete section.

(Del) **11.8.5.4** Delete section.

(Amd) **11.8.6 Emergency Command Center.** Emergency command center shall be in accordance with 11.8.6.1.

(Del) **11.8.6.2.** Delete section.

(Del) **11.8.6.3.** Delete section.

(Del) **11.8.6.4.** Delete section.

(Del) **11.8.6.5.** Delete section.

(Del) **11.8.6.6.** Delete section.

(Del) **11.8.6.7.** Delete section.

(Del) **11.8.8 Stairway Video Monitoring.** Delete section.

(Del) **11.8.9. Integrated Fire Protection and Life Safety System Testing.** Delete section.

(Del) **11.9.1.6.3** Delete section.

(Del) **11.10 Temporary Membrane Structures.** Delete section.

(Del) **11.11 Tents.** Delete section.

(DEL) CHAPTER 12
NEW ASSEMBLY OCCUPANCIES

(Del) Delete chapter in its entirety.

CHAPTER 13 EXISTING ASSEMBLY OCCUPANCIES

(Del) **13.1.1.4** Delete section.

(Del) **13.1.6 Minimum Construction Requirements.** Delete section.

(Amd) **13.2.3.6.1** Every assembly occupancy shall be provided with a main entrance/exit. With respect to the capacity of such main entrance/exit, the requirements of section 29-381a of the Connecticut General Statutes shall supersede the requirements of Sections 13.2.3.6.2 to 13.2.3.6.6, inclusive.

(Amd) **13.2.5.2 Common Path of Travel.** The common paths of travel shall be permitted for the first 30 feet (9.14 m) from any point where the common path serves any number of occupants, and for the first 75 feet (23 m) from any point where the common path serves not more than 50 occupants.

(Amd) **13.2.5.3 Dead End Corridors.** Dead-end corridors shall not exceed 20 feet (6.1 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **13.3.2.1.2** Rooms or spaces for the storage, processing, or use of materials specified in Section 13.3.2.1.2(1) to Section 13.3.2.1.2(3), inclusive, shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Boiler and furnace rooms, unless otherwise protected by the following:
 - i. The requirement of Section 13.3.2.1.2(1)(a) shall not apply to rooms enclosing furnaces, heating and air-handling equipment, or compressor equipment, where any piece of equipment has a total aggregate input rating less than or equal to 400,000 BTU/hr. (422 MJ), nor to rooms containing a boiler not over 15 psi and 10 horsepower.
 - ii. The requirement of Section 13.3.2.1.2(1)(a) shall not apply to attic locations of the rooms addressed in Section 13.3.2.1.2(1)(a)(i) provided such rooms comply with the draftstopping requirements of 8.6.11.
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
 - (d) Laundries over 100 feet² (9.3 m²).

- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Maintenance shops, including woodworking and painting areas.
 - (b) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
- (3) Protection as permitted in accordance with 9.7.1.2 where automatic extinguishing is used to meet the requirements of 13.3.2.1.2(1) or (2).

(Amd) **13.3.5.1** Buildings with occupant loads greater than 300 for which a permit for new occupancy was issued on or after April 15, 1987, or the occupant load is increased shall be protected by an approved supervised automatic sprinkler system in accordance with Section 9.7.1.1(1) as follows:

- (1) Throughout the story containing the assembly occupancy.
- (2) Throughout any story below the story containing the assembly occupancy.
- (3) In the case of an assembly occupancy located below the level of exit discharge, throughout any story intervening between this story and the level of exit discharge, including the level of exit discharge.

(Amd) **13.3.5.6** The requirements of Section 13.3.5.4 shall not apply to the following:

- (1) Assembly occupancies used primarily for worship with fixed seating.
- (2) Assembly occupancies consisting of a single multi-purpose room less than 12,000 square ft. (1,100 sq. m) and not used for exhibition or display.
- (3) Gymnasiums, skating rinks, swimming pools used exclusively for participant sport with no audience facilities for more than 300 occupants.

(Add) **13.3.5.7** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **13.3.6 Corridors.** Interior corridors and lobbies shall be separated from use areas by fire barriers having a fire resistance rating of not less than 1 hour in accordance with Section 8.3, except under any of the following conditions:

- (1) Where assembly rooms served by the corridor or lobby have at least 50 per cent of their exit capacity discharging directly to the outside, independent of corridors and lobbies.
- (2) When the building is protected throughout by an approved supervised automatic sprinkler system installed in accordance with Section 9.7.1.
- (3) Where lobbies serve only one assembly area that meet the requirements of intervening rooms (see Section 7.5.1.2), such lobbies need not have a fire resistance rating.
- (4) Construction for which a permit was issued prior to April 15, 1987.

(Add) **13.3.6.1** Openings in corridor partitions required to have a fire resistance rating shall be protected in accordance with Section 8.3.

(Amd) **13.4.7.7.1.** On every legitimate stage, the main proscenium opening used for viewing performances shall be provided with one of the following proscenium opening protection methods as follows:

- (1) The proscenium opening protection shall comply with 12.4.7.7 and be protected by a listed, minimum 20-minute opening protective assembly, a fire curtain complying with NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, or an approved water curtain complying with NFPA 13, *Standard for the Installation of Sprinkler Systems*.
- (2) Asbestos shall be permitted in lieu of a listed fabric.
- (3) Manual curtains of any size shall be permitted.

(Amd) **13.4.7.7.3** Proscenium opening protection provided by other than a fire curtain in accordance with 12.4.7.7 (see 13.4.7.7.2(1) and 13.4.7.7.1) shall activate upon automatic detection of fire and upon manual activation.

(Add) **13.4.7.12 Standpipes.**

(Add) **13.4.7.12.1** Stages greater than 1,000 feet² (93 m²) in area shall be equipped with 1½-inch (38-mm) hose connections for first aid firefighting at each side of the stage.

(Add) **13.4.7.12.2** Hose connections shall be in accordance with NFPA 13 unless Class II or Class III standpipes in accordance with NFPA 14 are used.

(Add) **13.4.10.1.1.1** The provisions of Section 13.4.10 shall not apply to portable grandstand and bleachers providing seating for fewer than 100 persons located outside of a building.

(Amd) **13.7.3 Open Flame Devices and Pyrotechnics.** Open flame devices and pyrotechnics shall be in accordance with the Connecticut State Fire Prevention Code and section 29-357a and 29-359 of the Connecticut General Statutes.

(Amd) **13.7.5.4.2.1** At least one battery cable shall be removed from the batteries used to start the vehicle engine, and the disconnected battery cable shall then be taped, except where the manufacturer's instructions indicate that this may cause damage to the vehicles operating systems.

(Del) **13.7.14 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D e l) C H A P T E R 1 4 NEW EDUCATIONAL OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 1 5

EXISTING EDUCATIONAL OCCUPANCIES

(Amd) **15.1.2.2** Educational occupancies shall include preschools, kindergartens, and other schools meeting both of the following criteria:

- (1) The purpose is primarily educational, even though the children who attend such schools are of preschool age.
- (2) The children are all 3 years of age or older.

(Add) **15.1.4.1.1** Buildings or spaces where training and skill development occur not within a school or academic program shall be classified as business occupancies.

(Amd) **15.2.2.2.4.1** Classroom doors and doors to other instructional spaces shall be permitted to be locked to prevent unwanted entry provided that the locking means is approved and all of the following conditions are met:

- (1) The locking means shall be capable of being engaged from the egress side without opening the door.
- (2) The unlocking and unlatching from egress side of the side of the door can be accomplished without the use of a key, tool, or special knowledge or effort.
- (3) The releasing mechanism shall unlock and unlatch the door with not more than one releasing operation.
- (4) The releasing mechanism for unlocking and unlatching shall be located at a height not less than 34 in. (865 mm) and not exceeding 48 in. (1220 mm) above the finished floor.
- (5) Locks, if remotely engaged, shall be unlockable from the egress side of the door without the use of a key, tool, or special knowledge or effort.
- (6) The door shall be capable of being unlocked and opened from outside the room with the necessary key or other credential.
- (7) The locking means shall not modify the door closer, panic hardware, or fire exit hardware or impair their operation.
- (8) Modifications to fire door assemblies, including door hardware, shall be in accordance with NFPA 80.
- (9) The emergency action plan, required by 15.7.1 shall address the use of the locking and unlocking means from both sides of the door.
- (10) Staff shall be drilled in the engagement and release of the locking means, from both sides of the door, as part of the emergency egress drills required by 15.7.2.

(Amd) **15.2.2.2.4.2** Where existing classroom doors and doors to instructional spaces are replaced, they shall comply with the provisions for new construction as found in Part III.

(Add) **15.2.4.3** A one-story educational occupancy may have a single exit provided the occupancy has a maximum of 50 occupants and a maximum travel distance of 75 feet (23 m) to the exit.

(Amd) **15.2.5.3** No dead-end corridor shall exceed 20 feet (6.1 m), other than in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 50 feet (15 m), except that a dead-

end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **15.2.9.1** Emergency lighting shall be provided in accordance with Section 7.9 unless otherwise permitted by either Section 15.2.9.2 or Section 15.2.9.3.

(Add) **15.2.9.3** Educational occupancies permitted to have a single means of egress in accordance with Section 15.2.4.1 shall not be required to have emergency lighting.

(Amd) **15.2.11.1.1** Every room or space greater than 250 feet² (23.2 m²) and used for classroom or other educational purposes or normally subject to student occupancy shall have not less than one outside window for emergency escape/ventilation and rescue with an associated opening in the outside wall that complies with the following, unless otherwise permitted by Section 15.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 22 inches (560 mm) in width, 22 inches (560 mm) in height and 3.3 feet² (0.31 m²) in area.
- (2) The bottom of the opening shall be not more than 44 inches (1,120 mm) above the floor, and any latching device shall be capable of being operated from not more than 54 inches (1,370 mm) above the floor. Where the bottom of the window opening is higher than 44 inches (1,120 mm) but less than 60 inches (1,525 mm) above the floor, a stair fixed in place at the window may be utilized to meet the 44 in. (1120 mm) sill height and 54 inches (1,370 mm) latch operation. Said stair shall have a minimum width equal to or exceeding the operable width of the opening and centered on such opening, a maximum riser height of 8 inches (205 mm), a minimum tread depth of 9 inches (230 mm) and shall be provided with a handrail on at least one side.
- (3) The opening in the outside wall for rescue shall allow a rectangular solid, with a width and height that provides not less than a 5.7 feet² (0.5 m²) opening and a depth of not less than 20 inches (510 mm), to pass fully through the opening.

(Amd) **15.2.11.1.2** The requirements of Section 15.2.11.1.1 shall not apply to any of the following:

- (1) Buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) Where the room or space has a door leading directly to an exit or directly to the outside of the building.
- (3) Where the room has a door, in addition to the door that leads to the exit access corridor as required by Section 15.2.5.5, and such door leads directly to another corridor located in a compartment separated from the compartment housing the corridor addressed in Section 15.2.5.5 by smoke partitions in accordance with Section 8.4.
- (4) Rooms located four or more stories above the finished ground level.
- (5) Where awning-type or hopper-type windows that are hinged or subdivided to provide a clear opening of not less than 4 feet² (0.38m²) or any dimension of not less than 22 inches (560 mm) meet the following:
 - (a) Such windows shall be permitted to continue in use.

- (b) Screen walls or devices located in front of required windows shall not interfere with rescue operations.
- (6) Where the room or space complies with all of the following:
- (a) One door providing direct access to an adjacent classroom and a second door providing direct access to another adjacent classroom shall be provided.
 - (b) The two classrooms to which exit access travel is made in accordance with Section 15.2.11.1.2(6)(a) shall each provide exit access in accordance with Section 15.2.11.1.2(2) or Section 15.2.11.1.2(3).
 - (c) The corridor required by Section 15.2.5.5, and the corridor addressed by Section 15.2.11.1.2(3), if provided, shall be separated from the classroom by a wall that resists the passage of smoke, and all doors between the classrooms and the corridor shall be self-closing or automatic-closing in accordance with Section 7.2.1.8.
 - (d) The length of travel to exits along such paths shall not exceed 150 feet (46 m).
 - (e) Each communicating door shall be marked in accordance with Section 7.10.
 - (f) No locking device shall be permitted on the communicating doors.
- (7) Where the building is protected throughout by an approved automatic fire detection system, the length of travel to an exit does not exceed 100 feet (30 m) and a window is provided in each room for ventilation. Smoke detection shall be used in all spaces except where not appropriate due to environmental conditions.

(Amd) **15.3.2.1** Rooms or spaces for the storage, processing, or use of materials shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
- (a) Boiler and furnace rooms where any piece of equipment is greater than 400,000 BTU per hour input, or any boiler greater than 15 psi and 10 horsepower, unless such rooms enclose only air-handling equipment.
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
 - (d) Janitor closets (see also 15.3.2.1(4)).
 - (e) Laundries over 100 feet² (9.3 m²).
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
- (a) Maintenance shops, including woodworking and painting areas.
 - (b) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction.

- (c) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
- (3) Where automatic extinguishing is used to meet the requirements of Section 15.3.2.1(1) or 15.3.2.1(2), the protection shall be permitted in accordance with Section 9.7.1.2.
- (4) Where janitor closets addressed in Section 15.3.2.1(1)(d) are protected in accordance with the sprinkler option of Section 15.3.2.1(1), the janitor closet doors shall be permitted to have ventilating louvers.

(Add) **15.3.4.4 Carbon Monoxide (CO) Detection.**

(Add) **15.3.4.4.1 General.** In rooms containing permanently installed fuel-burning heating equipment, carbon monoxide detection shall be provided on the ceiling or in accordance with the manufacturer's instructions. The carbon monoxide detectors shall be located as remotely as possible from the heating equipment.

Exception: Rooms with cooking appliances, laboratories and maintenance spaces.

(Add) **15.3.4.4.2 Signage.** A sign shall be provided at all entrances to rooms described in Section 15.3.4.4.1 indicating that carbon monoxide detectors are located within the space.

(Add) **15.3.4.4.3 Detection Equipment.** Single and multiple station carbon monoxide alarms, carbon monoxide detection equipment and sensors must meet or exceed UL Standards 2034 or 2075 as applicable.

(Add) **15.3.4.4.4 Installation.** Carbon monoxide detectors shall be installed in accordance with the manufacturer's instructions.

(Add) **15.3.4.4.5 Power Source.** Carbon monoxide detectors may be battery operated or 120 volt AC plug-in equipment that has a battery as its backup power source.

(Add) **15.3.4.4.6 Supervision.** If connected to a fire alarm signaling system, the carbon monoxide detection shall only activate a supervisory signal and shall not activate the building fire evacuation signal.

(Add) **15.3.4.4.7 Maintenance.** Carbon monoxide detectors shall be maintained and tested in accordance with the manufacturer's instructions and Section 9.8.

(Amd) **15.3.5.3** Automatic sprinkler protection shall not be required where student occupancy exists below the level of exit discharge, provided either of the following criteria is met:

- (1) Every classroom has at least one exterior exit door at ground level.
- (2) Windows for rescue and ventilation are provided in accordance with Section 15.2.11.1.

(Add) **15.3.5.6** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **15.3.6 Corridors.** Corridors shall be separated from other parts of the story by walls having a ½-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by one of the following:

- (1) Corridor protection shall not be required where all spaces normally subject to student occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with Section 7.5.3.
- (2) In buildings protected throughout by an approved automatic sprinkler system with valve supervision in accordance with Section 9.7, corridor walls shall not be required to be rated.
 - a. Corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with Section 8.4.
 - b. The provisions of 8.4.3.5 shall not apply to normally occupied classrooms.
- (3) Where the corridor ceiling is an assembly having a ½-hour fire resistance rating where tested as a wall, the corridor wall shall be permitted to terminate at the corridor ceiling.
- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other spaces by walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3.
- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (6) Existing doors in ½-hour fire resistance rated corridor walls may be 1¾ inches (44 mm) thick solid-bonded wood core doors or the equivalent.

(Add) **15.3.6.1 Self-closing devices** may be omitted on doors between corridors and classrooms, except rooms or areas used as shops or laboratories, where the facility has a written and practiced fire exit drill policy which provides for the closing of all corridor doors upon evacuation, and where said policy provides for doors to classrooms not in use to be kept closed.

(Del) **15.3.4.5 Risk Analysis for Mass Notification Systems.** Delete section.

(Amd) **15.7.2.4 Fire Drills. Crisis Response Drills.** (a) Each local and regional board of education shall provide for a fire drill to be held in the schools of such board not later than thirty days after the first day of each school year and at least once each month thereafter, except as provided in subsection (b) of this section.

(b) Each such board shall substitute a crisis response drill for a fire drill once every three months and shall develop the format of such crisis response drill in consultation with the appropriate local law enforcement agency. A representative of such agency may supervise and participate in any such crisis response drill.

(Del) **15.7.6 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

**(DEL) CHAPTER 16
NEW DAY-CARE OCCUPANCIES**

(Del) Delete chapter in its entirety.

CHAPTER 17 EXISTING DAY-CARE OCCUPANCIES

(Amd) **17.1.1.4** The requirements of Section 17.1 to Section 17.5, inclusive, shall apply to existing day-care occupancies in which more than 12 clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day. An existing day-care occupancy has the option of meeting the requirements of Part III of this Code in lieu of Chapter 17. An existing day-care occupancy that meets the requirements of Part III shall be judged as meeting the requirements of Chapter 17.

(Amd) **17.1.1.5** The requirements of Section 17.1 and Sections 17.4 through 17.6 shall apply to existing day-care homes as defined in 17.1.4. An existing day-care home shall be permitted the option of meeting the requirements of Part III of this code in lieu of Chapter 17. An existing day-care home that meets the requirements of Part III of this Code shall be judged as meeting the requirements of Chapter 17.

(Amd) **17.1.2.1 General.** Occupancies that include preschools, kindergartens, and other schools whose purpose is primarily educational for children 3 years of age or older, even though the children who attend such schools are of preschool age, shall comply with the provisions of Chapter 15.

(Amd) **17.1.2.3* Conversions.** A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms to the requirements of Part III of this code.

(Amd) **Table 17.1.6.1 Location and Construction Type Limitations.**

Location of Occupancy	Day-Care Sprinklered Building	Construction Type
1 story below LED	Yes	I(443), I(332), II(222), II(111), II(000), III(211), IV(2HH), V(111)
	No	I(443), I(332), II(222), II(111), III(211), IV(2HH), V(111)
Level of exit discharge	Yes	Any type
	No	Any type
1 story above LED	Yes	Any type
	No	I(443), I(332), II(222)
	No	II(111)*, III(211)*, V(111)*
2 stories above LED	Yes	I(443), I(332), II(222)
	Yes	II(111)*, III(211)*, V(111)*
	No	I(443), I(332), II(222)
≥3 stories above LED but not high-rise	Yes	I(443), I(332), II(222)
	Yes	II(111)*
	No	I(443), I(332), II(222)
High-rise	Yes	I(443), I(332), II(222)
	No	Not permitted

LED: Level of exit discharge.

*Permitted only if clients capable of self-preservation.

(Amd) **17.2.2.2.6.1** Classroom doors and doors to other client care spaces shall be permitted to be locked to prevent unwanted entry provided that the locking means is approved and all of the following conditions are met:

- (1) The locking means shall be capable of being engaged from the egress side without opening the door.
- (2) The unlocking and unlatching from egress side of the side of the door can be accomplished without the use of a key, tool, or special knowledge or effort.
- (3) The releasing mechanism shall unlock and unlatch the door with not more than one releasing operation.
- (4) The releasing mechanism for unlocking and unlatching shall be located at a height not less than 34 in. (865 mm) and not exceeding 48 in. (1220 mm) above the finished floor.
- (5) Locks, if remotely engaged, shall be unlockable from the egress side of the door without the use of a key, tool, or special knowledge or effort.
- (6) The door shall be capable of being unlocked and opened from outside the room with the necessary key or other credential.

(7) The locking means shall not modify the door closer, panic hardware, or fire exit hardware or impair their operation.

(8) Modifications to fire door assemblies, including door hardware, shall be in accordance with NFPA 80.

(9) The emergency action plan, required by 15.7.1 shall address the use of the locking and unlocking means from both sides of the door.

(10) Staff shall be drilled in the engagement and release of the locking means, from both sides of the door, as part of the emergency egress drills required by 15.7.2.

(Amd) **17.2.2.6.2** Where existing classroom doors and doors to instructional spaces are replaced, they shall comply with the provisions for new construction as found in Part III.

(Amd) **17.2.4.1** The number of means of egress shall be in accordance with Section 7.4.1.1 and Section 7.4.1.3 to Section 7.4.1.6, inclusive, or the CSFSC, Part III, Section 1006.

(Amd) **17.2.5.3** No dead-end corridor shall exceed 20 ft (6.1 m), other than in buildings protected throughout by an approved, supervised, automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 50 ft (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **17.2.11.1.1** Every room or space greater than 250 ft² (23.2 m²) and used for client occupancy shall have not less than one outside window for emergency escape/ventilation and rescue with an associated opening in the outside wall that complies with the following, unless otherwise permitted by Section 17.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 22 inches (560 mm) in width, 22 inches (560 mm) in height and 3.3 ft² (0.31 m²) in area.
- (2) The bottom of the opening shall be not more than 44 inches (1,120 mm) above the floor, and any latching device shall be capable of being operated from not more than 54 inches (1,370 mm) above the finished floor.
- (3) The opening in the outside wall for rescue shall allow a rectangular solid, with a width and height that provides not less than a 5.7 ft² (0.5 m²) opening and a depth of not less than 20 inches (510 mm), to pass fully through the opening.

(Amd) **17.2.11.1.2** The requirements of Section 17.2.11.1.1 shall not apply to any of the following:

- (1) Buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) Where the room or space has a door leading directly to an exit or directly to the outside of the building.
- (3) Where the room has a door, in addition to the door that leads to the exit access corridor, and such door leads directly to an exit or directly to another corridor located in a compartment separated from the compartment housing the initial corridor addressed in

Section 17.2.5.5 by smoke partitions in accordance with Section 8.4.

- (4) Rooms located four or more stories above the finished ground level.
- (5) Where awning-type or hopper-type windows that are hinged or subdivided to provide a clear opening of not less than 4 ft² (0.38m²) or any dimension of not less than 22 inches (560 mm) meet the following:
 - (a) Such windows shall be permitted to continue in use.
 - (b) Screen walls or devices located in front of required windows shall not interfere with rescue operations.
- (6) Where the room or space complies with all of the following:
 - (a) One door providing direct access to an adjacent room and a second door providing direct access to another adjacent room shall be provided.
 - (b) The two rooms to which exit access travel is made in accordance to Section 17.2.11.1.2(6)(a) shall each provide exit access in accordance with Section 17.2.11.1.2(2) or Section 17.2.11.1.2(3).
 - (c) The corridor required by Section 17.2.5.5, and the corridor addressed by Section 17.2.11.1.2(3), if provided, shall be separated from the room by a wall that resists the passage of smoke, and all doors between the rooms and the corridor shall be self-closing or automatic-closing in accordance with Section 7.2.1.8.
 - (d) The length of travel to exits along such paths shall not exceed 150 feet (46 m).
 - (e) Each communicating door shall be marked in accordance with Section 7.10.
 - (f) No locking device shall be permitted on the communicating doors.
- (7) Where the building is protected throughout by an approved automatic fire detection system, the length of travel to an exit does not exceed 100 feet (30 m) and a window is provided in each room for ventilation. Smoke detection shall be used in all spaces except where not appropriate due to environmental conditions.

(Amd) **17.3.2.1** Rooms or spaces for the storage, processing, or use of materials specified in Section 17.3.2.1(1) to Section 17.3.2.1(3), inclusive, shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms, by automatic extinguishing systems as specified in Section 8.7, in the following areas:
 - (a) Boiler and furnace rooms where any piece of equipment is greater than 400,000 BTU per hour input, or any boiler is greater than 15 psi and 10 horsepower, unless such rooms enclose only air-handling equipment.
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
 - (d) Janitor closets.
 - (e) Laundries with an area greater than 100 feet² (9.3 m²).

- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Maintenance shops, including woodworking and painting areas.
 - (b) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards.
- (3) Where automatic extinguishing is used to meet the requirements of Section 17.3.2.1(1) and Section 17.3.2.1(2), the protection shall be permitted in accordance with Section 9.7.1.2.

(Add) **17.3.5.5** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **17.3.6 Corridors.** Every interior corridor shall be constructed of walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following:

- (1) Corridor protection shall not be required where all spaces normally subject to client occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with Section 7.5.3.
- (2) In buildings protected throughout by an approved automatic sprinkler system with valve supervision in accordance with Section 9.7.
- (3) Where the corridor ceiling is an assembly having a ½-hour fire resistance rating where tested as a wall, the corridor walls may terminate at the corridor ceiling.
- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other spaces by walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3.
- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (6) Existing doors in ½-hour fire resistance rated corridors may be 1¾ inches (44 mm) thick, solid-bonded wood core doors or the equivalent.

(Add) **17.3.6.1** Self-closing devices may be omitted on doors between corridors and client activity rooms where the facility has a written and practiced fire exit drill policy which provides for the closing of all corridor doors upon evacuation and where said policy provides for doors to client activity rooms not in use to be kept closed.

(Amd) **17.6.1.1.2*** The requirements of Section 17.6 shall apply to existing day-care homes in which more than 3, but not more than 12, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit.

(Add) **17.6.1.1.6** The requirements of Section 17.6 shall not apply to facilities located within residential living units or private dwellings and that provide care, maintenance and supervision to not more than 9 children except that during the school year a maximum of 3 additional children who are in school full time shall be permitted for up to 3 hours before school and up to 3 hours after school. Such facilities are subject to the regulations adopted by the Connecticut Department of Public Health and are exempt from the requirements of this code.

(Amd) **17.6.1.4.2* Conversions.** A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms to the requirements for new day-care occupancies with more than 12 clients in accordance with Part III of this code.

(Del) **17.6.1.7** Delete section.

(Del) **17.7.6 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 1 8 NEW HEALTH CARE OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 1 9 EXISTING HEALTH CARE OCCUPANCIES

(Amd) **19.1.1.1.1*** The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as health care occupancies, unless the State Fire Marshal has determined equivalent safety has been provided in accordance with Section 1.4.

(Amd) **19.1.1.1.7** It shall be recognized that, in buildings housing certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the State Fire Marshal may grant appropriate variations or exemptions in accordance with section 29-296 of the Connecticut General Statutes those sections of this code that would otherwise require means of egress to be kept unlocked.

(Amd) **19.1.1.4.1 Additions.** Alterations, renovations, additions or change of use to existing buildings, as defined in Part I, Section 102.2 of this Code, shall conform to the requirements of Part III of the CSFSC.

(Del) **19.1.1.4.1.1** Delete section.

(Del) **19.1.1.4.1.2** Delete section.

(Del) **19.1.1.4.1.3** Delete section.

(Amd) **19.1.1.4.2 Changes in Use or Occupancy Classification.** Changes in use or occupancy classification shall be in compliance with the requirements of Part III of this code.

(Amd) **19.1.1.4.3 Rehabilitation.** Shall be in compliance with the requirements of Part III of the CSFSC.

(Del) **19.1.1.4.3.1** Delete section.

(Del) **19.1.1.4.3.2** Delete section.

(Del) **19.1.1.4.3.3** Delete section.

(Del) **19.1.1.4.3.4** Delete section.

(Amd) **19.1.1.4.4 Construction, Repair, and Improvement Operations.** Shall be in compliance with the requirements of Part III of the CSFSC.

(Amd) **19.1.3.9** Egress provisions for areas of health care facilities that correspond to other occupancies shall meet the corresponding requirements of this code for such occupancies. It shall be recognized that, in buildings housing certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the State Fire Marshal may grant appropriate variations or exemptions in accordance with section 29-296 of the Connecticut General Statutes to those sections of this code that would otherwise require means of egress to be kept unlocked.

(Amd) **19.2.2.2.5** Door-locking arrangements permitted by Section 19.1.1.1.7 shall be in accordance with either Section 19.2.2.2.5.1 or Section 19.2.2.2.5.2.

(Add) **19.2.4.2.1** A single exit shall be permitted for a one-story building with a maximum occupant load of 10 persons and a maximum travel distance of 75 feet (23 m) to the exit.

(Amd) **19.2.5.3* Dead End Corridors.** Existing dead-end corridors not exceeding 30 ft. (9.1 m) shall be permitted. Existing dead-end corridors exceeding 30 ft. (9.1 m) shall be permitted to continue in use if it is impractical and unfeasible to alter them. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **19.2.9.1** Emergency lighting shall be provided in accordance with Section 7.9 unless otherwise permitted by Section 19.2.9.2.

(Amd) **19.2.9.2** Health care occupancies permitted to have a single means of egress in accordance with Section 19.2.4.2.1 shall not be required to have emergency lighting.

(Amd) **19.3.2.1.5** Hazardous areas shall include, but not be restricted to, the following:

- (1) Boiler and fuel-fired heater rooms where any piece of equipment is greater than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower.
- (2) Central/bulk laundries larger than 100 feet² (9.3 m²).
- (3) Paint shops.
- (4) Repair shops.
- (5) Soiled linen rooms.
- (6) Trash collection rooms.
- (7) Rooms or spaces larger than 50 feet² (4.6 m²), including repair shops, used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction.
- (8) Laboratories employing flammable or combustible materials in quantities less than those that would be considered a severe hazard.

(Add) **19.3.5.1.1** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **19.3.5.7*** Where this code permits exceptions for fully sprinklered buildings or smoke compartments, the sprinkler system shall meet all of the following criteria:

- (1) It shall be in accordance with Section 9.7.
- (1) It shall be installed in accordance with 9.7.1.1 (1) unless it is an approved existing system.
- (2) It shall be electrically connected to the fire alarm system.
- (3) It shall be fully supervised.

(Del) **19.4.3 High-Rise Buildings.** Delete section in its entirety.

(Amd) **19.7.9.1** Construction, repair, and improvement operations shall comply with the requirements Part III of this code.

(Del) **19.7.9.2** Delete section.

(Del) **19.7.9.3** Delete section.

(Del) **19.7.10 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 2 0 NEW AMBULATORY HEALTH CARE OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 2 1 EXISTING AMBULATORY HEALTH CARE OCCUPANCIES

(Amd) **21.1.1.1.5** It shall be recognized that, in buildings housing certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the State Fire Marshal may grant appropriate variations or exemptions in accordance with section 29-296 of the Connecticut General Statutes to those sections of this code that would otherwise require means of egress to be kept unlocked.

(Amd) **21.1.1.4.1.1** Alterations, renovations, additions or change of use to existing buildings shall conform to the requirements of Part III of this Code.

(Del) **21.1.1.4.1.2** Delete section.

(Del) **21.1.1.4.1.3** Delete section.

(Amd) **21.1.1.4.2 Changes in Use or Occupancy Classification.** Changes in use or occupancy classification shall be in compliance with the requirements of Part III of this Code.

(Amd) **21.1.1.4.3 Renovations, Alterations, and Modernizations.** Shall be in compliance with the requirements of Part III of the CSFSC.

(Amd) **21.1.1.4.4 Construction, Repair, and Improvement Operations.** Shall be in compliance with the requirements of Part III of the CSFSC.

(Amd) **21.1.3.6** Egress provisions for areas of ambulatory health care facilities that correspond to other occupancies shall meet the corresponding requirements of this Code for such occupancies, and, where the clinical needs of the occupant necessitate the locking of means of egress, staff shall be present for the supervised release of occupants during all times of use and such arrangement shall comply with Section 21.1.1.1.5.

(Del) **21.1.6.6** Delete section.

(Amd) **21.2.2.2.9** Sensor-released electrical locking systems complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces. These doors shall not be secured from the egress side when the occupancy is open to the general public.

(Add) **21.2.4.2.1** A single exit shall be permitted for a one-story building with a maximum occupant load of 10 persons and a maximum travel distance of 75 feet (23 m) to the exit.

(Amd) **21.2.9.1** Emergency lighting shall be provided in accordance with Section 7.9 unless otherwise permitted by Section 21.2.9.1.1.

(Add) **21.2.9.1.1** Ambulatory health care occupancies permitted to have a single means of egress in accordance with Section 21.2.4.2.1 shall not be required to have emergency lighting.

(Amd) **21.3.1.1** Vertical openings shall be enclosed or protected in accordance with Section 8.6,

unless otherwise permitted by any of the following:

- (1) Previously approved vertical openings.
- (2) Unenclosed vertical openings in accordance with 8.6.9.1 shall be permitted.
- (3) Unprotected vertical openings shall be permitted in buildings complying with all of the following:
 - (a) Where protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1)
 - (b) Where no unprotected vertical opening serves as any part of any required means of egress
 - (c) Where required exits consist of exit doors that discharge directly to the finished ground level in accordance with 7.2.1, outside stairs in accordance with 7.2.2, smokeproof enclosures in accordance with 7.2.3, or horizontal exits in accordance with 7.2.4.

(Amd) **21.4.3.1** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Del) **21.4.3.1.1** Delete section.

(Del) **21.4.3.1.2** Delete section.

(Del) **21.4.3.2** Delete section.

(Del) **21.4.3.3** Delete section.

(Del) **21.7.10 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 2 2 NEW DETENTION AND CORRECTIONAL OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 2 3 EXISTING DETENTION AND CORRECTIONAL OCCUPANCIES

(Amd) **23.2.5.2* Dead-End Corridors.** Existing dead-end corridors greater than 50 feet (15 m) shall be altered wherever possible so that exits are accessible in not less than two different directions from all points in aisles, passageways and corridors. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **23.2.11.1.3** Where egress doors are locked with key-operated locks, the keys necessary for unlocking doors installed in the means of egress shall be individually identified by both touch

and sight. The provisions of 23.7.7 shall apply.

(Amd) **Table 23.3.2.1 Hazardous Area Protection**

Hazardous Area Description	Separation/Protection*
Areas not incidental to residential housing	2 hours
Boiler and fuel-fired heater rooms where any piece of equipment is greater than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower	1 hour or sprinklers
Central or Bulk laundries >100 ft ² (>9.3 m ²)	1 hour or sprinklers
Commercial cooking equipment	In accordance with 9.2.3
Commissaries	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers [†]
Hobby/handicraft shops	1 hour or sprinklers
Central or Bulk laundries >100 ft ² (>9.3 m ²)	1 hour or sprinklers
Maintenance shops	1 hour or sprinklers [†]
Padded cells	1 hour and sprinklers
Soiled linen rooms	1 hour or sprinklers
Storage rooms > 50 ft ² (>4.6 m ²)	1 hour or sprinklers
Trash collection rooms	1 hour or sprinklers

*Minimum fire resistance rating

(Add) **23.3.5.1.1** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **23.4.6.1.4** The lockup shall be permitted to comply with the requirements for the predominant occupancy in which the lockup is placed, provided that all of the following criteria are met:

- (1) * Doors and other physical restraints to free egress by detainees can be readily released by staff within 2 minutes of the onset of a fire or similar emergency.
- (2) Staff is in sufficient proximity to the lockup so as to be able to effect the 2-minute release required by 23.4.5.1.4(1) whenever detainees occupy the lockup.
- (3) Staff is authorized to effect the release required by 23.4.5.1.4(1).
- (4) Staff is trained and practiced in effecting the release required by 23.4.5.1.4(1).
- (5) Where the release required by 23.4.5.1.4(1) is effected by means of remote release, detainees are not to be restrained from evacuating without the assistance of others.
- (6) A reliable means of two way communication, or a video monitor, to a constantly attended location shall be provided in lockup areas that are not under constant direct staff.

(Del) **23.7.8 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

CHAPTER 24 ONE AND TWO FAMILY DWELLING

(Amd) **24.1.1.1*** The requirements of this chapter shall apply to dwelling units located in any building or structure; existing one- and two-family dwelling units, which shall include those buildings containing not more than two dwelling units in which each dwelling unit is occupied by members of a single family with not more than six outsiders, if any, accommodated in rented rooms, except those occupancies classified as health care, residential board and care or detention and correctional.

Buildings that contain a maximum of two dwelling units and no other occupancies are specifically exempted by section 29-292 of the Connecticut General Statutes from the jurisdiction of this code, except for the specific smoke detection provisions set forth in Section 24.3.4.

(Add) **24.1.3.1.1** Where one or two dwelling units are present in a building containing another occupancy, each dwelling shall be provided with a primary means of escape in accordance with Section 24.2.2.2. If the primary means of escape consists of an interior stairway, the stairway shall be separated by at least ½-hour fire barriers with all openings protected by self-closing doors of an equivalent rating.

(Amd) **24.1.3.2** No dwelling unit may have its sole means of escape through another dwelling unit or other occupancy.

(Del) **24.1.3.2.1** Delete section.

(Del) **24.1.3.2.2** Delete section.

(Amd) **24.2.2.3.3*** A window or door shall provide a clear opening in the outside wall of not less than 5.7 feet² (0.53 m²) for access into the building. The window opening for escape/ventilation by occupants shall provide a clear opening of not less than 20 inches (508 mm) in width and 22 inches (560 mm) in height, and 3.3 feet² (0.31 m²) in total area. This window shall be operable from the inside by occupants without the use of tools, keys, or special effort. The bottom of the opening shall be not more than 44 inches (1,120 mm) above the floor. Such means of escape shall be acceptable where one of the following criteria is met:

- (1) The window shall be within 240 inches (6,100 mm) of grade.
- (2) The window shall be directly accessible to fire department rescue apparatus as approved by the authority having jurisdiction.
- (3) The window or door shall open onto an exterior balcony.
- (4) Windows having a sill height below the adjacent ground level shall be provided with a window well meeting the following criteria:
 - (a) The window well shall have horizontal dimensions that allow the window to be fully opened.
 - (b) The window well shall have an accessible net clear opening of not less than 9 feet² (0.82 m²) with a length and width of not less than 36 inches (915 mm).

- (c) A window well with a vertical depth of more than 44 inches (1120 mm) shall be equipped with an approved permanently affixed ladder or with steps meeting the following criteria:
- i. The ladder or steps shall not encroach more than 6 inches (150 mm) into the required dimensions of the window well.
 - ii. The ladder or steps shall not be obstructed by the window.

(Add) **24.2.2.3.3.1 Alternative Compliance to Section 24.2.2.3.3(4)(c).** The 44-in. (1120 mm) maximum height of the sill above the floor level may be measured vertically above a fixed, permanent platform, step, or steps whose minimum width shall equal or exceed the width of the opening and a maximum riser height of 8 inches (205 mm) and a minimum tread depth of 9 inches (229 mm).

(Add) **24.2.5.1.1.1** Maximum riser heights of 8¼ inches (209.5 mm) and minimum tread depths of 9 inches (229 mm) shall be permitted.

(Del) **24.2.8 Grab Bars and Stanchions for Bathtubs, Bathtub-Shower Combinations, and Showers.** Delete section in its entirety.

(Amd) **24.3.4.1.3** In buildings for which a building permit for new occupancy was issued before October 1, 1976, approved smoke alarms powered by batteries shall be permitted.

(Add) **24.3.4.1.3.1** Smoke alarms added to comply with the provisions of 24.3.4.1.1 (1) shall be permitted to be battery operated.

(Add) **24.3.4.1.3.2** Buildings for which a building permit for new occupancy was issued on or after May 1, 1999, shall be interconnected in accordance with NFPA 72, Section 29.8.2.1.1.

(Add) **24.3.4.1.4** Smoke detection and warning equipment (smoke alarms) shall also be provided in accordance with section 29-453 of the Connecticut General Statutes.

(Amd) **24.3.4.2.1** Carbon monoxide detection and warning equipment as required by section 29-292 and section 29-453 of the Connecticut General Statutes shall be installed in accordance with Section 24.3.4.2.2 where either of the following conditions exist:

- (1) Dwelling or sleeping units with communicating attached garages, unless the attached garage is defined as open parking structure by the Connecticut State Building Code, or the attached garage is mechanically ventilated in accordance with the International Mechanical Code portion of the State Building Code.
- (2) Dwelling or sleeping units containing fuel-burning appliances or fuel burning fireplaces.

(Del) **24.3.5* Extinguishment requirements.** Delete section in its entirety.

RESERVED

CHAPTER 26

(AMD) LODGING OR ROOMING HOUSES AND BED AND BREAKFASTS

(Amd) **26.1.1.1*** The requirements of this chapter shall apply to buildings or portions thereof that do not qualify as a one- or two-family dwelling that provide sleeping accommodations for a total of 16 or fewer persons on either a transient or permanent basis, with or without meals, but without separate cooking facilities for individual occupants except as provided in Chapter 24.

(Del) **26.1.1.4** Delete section.

(Del) **26.1.1.5** Delete section.

(Add) **26.2.1.1.3 Illumination.** The primary means of escape within bed and breakfast establishments shall be provided with illumination in accordance with Section 7.8, unless illumination is provided upon activation of the fire alarm system or loss of power. The foot-candle values of illumination provided shall be as required by Sections 7.9.2.1.1 and 7.9.2.1.2.

(Amd) **26.2.2.4** Where an interior stair connects the street floor with the story next above or below only, but not with both, the interior stair shall be required to be enclosed only on the street floor. In bed and breakfasts, this exception shall not apply to stairs below the street floor.

(Add) **26.2.3.7** Sensor-released electric locking system egress doors complying with Section 7.2.1.6.2 shall be permitted.

(Del) **26.2.4 Grab Bars for Bathtubs, Bathtub–Shower Combinations and Showers.** Delete section in its entirety.

(Add) **26.3.1.1.4** In lodging or rooming houses, two or fewer stories in height, and in bed and breakfast establishments, stair enclosures shall not be required for levels at and above the street floor level when the building is provided with an approved household fire warning system in accordance with the requirements of NFPA 72[®]. This system shall consist of a control unit with smoke detectors, a manual fire alarm box on each floor level, and occupant notification with a heat detector installed in the kitchen. The kitchen shall also be separated by ½-hour fire-resistive construction, or shall be protected by a limited area sprinkler system, or the range top shall be protected by a listed residential range top extinguisher unit.

(Del) **26.3.3.3 Interior Finish.** Delete section in its entirety.

(Amd) **26.3.4.5.3** Each lodging or rooming house shall install a smoke alarm that, when activated, shall provide an approved visible alarm suitable to warn occupants in at least one room.

(Amd) **26.3.4.6.1** Carbon monoxide detection and warning equipment as required by section 29-

292 and section 29-453 of the Connecticut General Statutes shall be installed in accordance with Section 26.3.4.6.2 where either of the following conditions exist:

- (1) Dwelling or sleeping units with communicating attached garages, unless the attached garage is defined as open parking structure by the Connecticut State Building Code, or the attached garage is mechanically ventilated in accordance with the International Mechanical Code portion of the State Building Code.
- (2) Dwelling or sleeping units containing fuel-burning appliances or fuel burning fireplaces.

(Add) **26.3.4.6.1.1** In sleeping rooms in lodging and rooming houses or bed and breakfasts that have a fireplace, woodstove, or similar appliance shall be equipped with carbon monoxide detection and warning equipment within the sleeping room. This equipment shall be permitted to be battery operated.

(Amd) **26.3.6.1** Automatic sprinkler protection shall be provided as required by Section 9.7.1.6, and in lodging or rooming houses which were created by the application for a building permit for either new construction, change of use or occupancy that occurred on or after May 1, 1999. The requirement for lodging or rooming houses shall not apply to those lodging and rooming houses that complied with the exception to Section 20.3.5.2 of the Connecticut State Fire Safety Code effective May 1, 1999.

(Del) **26.3.6.2.4** Delete section.

(Amd) **26.4 Special Structures.** Lodging and rooming houses shall comply with Chapter 11 where located in a special structure.

(Add) **26.3.6.3** Portable fire extinguishers shall be required only in kitchens of bed and breakfasts. These portable fire extinguishers shall be installed and maintained in accordance with Section 9.9, unless the range top is protected by a listed residential range top extinguisher unit.

(Amd) **26.5. Elevators, Escalators, and Conveyors.** Elevators, Escalators, and Conveyors shall comply with the provisions of the State Elevator Code adopted pursuant to Chapter 538 of the Connecticut General Statutes.

(Del) **26.7.2 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

CHAPTER 27 RESERVED

(DEL) CHAPTER 28 NEW HOTELS AND DORMITORIES

(Del) Delete chapter in its entirety.

CHAPTER 29 (AMD) EXISTING HOTELS

(Amd) **29.1.1.1** The requirements of this chapter shall apply to buildings or portions thereof currently occupied as hotel or motel occupancies.

(Del) **29.1.1.4** Delete section.

(Amd) **29.1.4.2 Definitions.** Terms applicable to this chapter are defined in Chapter 3 of this code and include the terms in the list that follows:

- (1) Guest Room. See Section 3.3.136.
- (2) Guest Suite. See Section 3.3.285.1.
- (3) Hotel. See Section 3.3.153.

(Amd) **29.2.2.2.3** Sensor-Released electrical locking systems complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces.

(Amd) **29.2.4.1** Means of egress shall comply with all of the following, except as otherwise permitted by Section 29.2.4.2 and Section 29.2.4.3:

- (1) The number of means of egress shall be in accordance with Section 7.4.1.1 and Section 7.4.1.3 through Section 7.4.1.6, inclusive.
- (2) Not less than two separate exits shall be provided from every part of every story, including stories below the level of exit discharge and stories occupied for public purposes.

(Amd) **29.2.4.3** Buildings of four stories or less protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 29.3.5, with not more than four guest rooms or guest suites per floor, may have a single exit under the following conditions:

- (1) The stairway is completely enclosed or separated by barriers having a fire resistance rating of not less than 1 hour in accordance with Section 8.3.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a 1-hour fire resistance rating.
- (4) The travel distance from the entrance door of any guest room or guest suite to an exit does not exceed 35 feet (10.7 m).
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between guest rooms or guest suites.

(Amd) **29.2.5.3** Dead-end corridors shall not exceed 50 feet (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **29.3.2.2.2** The areas described in Table 29.3.2.2.2 shall be protected as indicated, except that residential-type heating appliances such as domestic hot water heaters, domestic furnaces

or domestic boilers may be unenclosed when located within an individual guest room or suite serving only that room or suite that is separated from all adjacent rooms or suites by construction having at least a ½-hour fire resistance rating.

(Amd) Table 29.3.2.2.2 Hazardous Area Protection

Hazardous Area Description	Separation/Protection^a
Boiler and fuel-fired heater rooms where any piece of equipment is greater than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers [†]
Gift or retail shops, >100 ft ² (>9.3 m ²)	1 hour or sprinklers ^b
Bulk laundries	1 hour or sprinklers
Guest laundries >100 ft ² (>9.3 m ²) outside of guest rooms or guest suites	1 hour or sprinklers ^b
Maintenance shops	1 hour or sprinklers
Rooms or spaces used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction ^c	1 hour or sprinklers
Trash collection rooms	1 hour or sprinklers

^a Minimum fire resistance rating

^b Where automatic sprinkler protection is provided, the separation specified in 8.7.1.2 and 29.3.2.2.3 shall not be required.

^c Where storage areas not exceeding 24 ft² (2.2 m²) are directly accessible from the guest room or guest suite, no separation or protection shall be required.

(Amd) 29.3.4.4 Detection.

(Add) 29.3.4.4.1 A corridor smoke detection system in accordance with Section 9.6 shall be provided, unless otherwise permitted by either of the following:

- (1) Where each guest room has direct exit to the outside of the building and the building is not over three stories in height.
- (2) In buildings protected throughout by an approved automatic sprinkler system in accordance with Section 29.3.5.

(Add) 29.3.4.5.3 Each hotel having 100 or more units or rooms shall install such equipment that, when activated, shall provide an approved visible alarm suitable to warn occupants, in at least one percent of the units or rooms in such establishments. In establishments having less than 100 units or rooms, at least one unit or room shall have such an alarm.

(Del) 29.3.4.6.5 Delete section.

(Amd) 29.3.5.1 An approved, supervised automatic sprinkler system shall be provided as required by Section 9.7.1.6.

(Del) **29.3.5.8** Delete section.

(Amd) **29.3.6.4.1** Transoms, louvers or transfer grilles shall be prohibited in walls or doors of exit access corridors, unless meeting the requirements of Section 29.3.6.4.2.

(Del) **29.3.6.4.3** Delete section.

(Del) **29.3.6.4.4** Delete section.

(Del) **29.7.3 Drills in Dormitories.** Delete section.

(Del) **29.7.8 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 3 0 NEW APARTMENT BUILDINGS

(Del) Delete chapter in its entirety.

C H A P T E R 3 1 (AMD) EXISTING APARTMENT AND DORMITORY BUILDINGS

(Amd) **31.1.1.1** The requirements of this chapter shall apply to buildings or portions thereof currently occupied as apartment or dormitory occupancies. In addition, the building shall meet the requirements of one of the following options:

- (1) Option 1 - Buildings without fire suppression or detection systems.
- (2) Option 2 - Buildings provided with a complete approved automatic fire detection and notification system in accordance with 31.3.4.4.
- (3) Option 3 - Buildings provided with automatic sprinkler protection in selected areas as described in 31.3.5.6.
- (4) Option 4 - Buildings protected throughout by an approved automatic sprinkler system.

(Add) **31.1.1.4.1** All buildings containing three or more individual living units shall be classified as apartment buildings, except where the building and living unit arrangement is in accordance with items numbered (1) through (4) of this section, then the entire building shall be exempt from the requirements of this chapter and the individual living units need only comply with the requirements for smoke alarms in Section 31.3.4.5 and each living unit shall be treated as a single family home for the purposes of section 29-305 of the Connecticut General Statutes:

- (1) Residential buildings containing three or more individual living units, in which the living units are arranged so that no living unit is located either above or below another living unit.
- (2) Each living unit has at least one independent exit, serving that unit only which leads

directly to the exterior of the building in one of the following manners:

- (a) An exit door that opens directly to the street or yard at ground level.
 - (b) An outside stair that leads directly to the street or yard at ground level.
 - (c) An interior stair that is part of the living unit served that leads directly to the street or yard at ground level.
- (3) Each living unit is separated from the adjoining unit by vertical fire barriers having at least a 1-hour fire resistance rating. Such walls shall extend from the lowest floor slab to the underside of the highest roof deck and shall be continuous through all spaces below the living unit, such as basements and crawl spaces, and all areas above the living unit, such as attics or other concealed spaces.
- (4) There are no spaces within the confines of the building's exterior perimeter walls that are subject to common occupant usage, including, but not limited to, corridors, hallways, laundry rooms, furnace or utility rooms, storage areas or recreation areas.

(Amd) **31.1.3.3** Multiple dwelling units may be located above a nonresidential occupancy only where one of the following conditions exists:

- (1) Where the dwelling units of the residential occupancy and exits therefrom are separated from the nonresidential occupancy by construction having a fire resistance rating of not less than 1 hour.
- (2) Where the nonresidential occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (3) Where the dwelling units are located above a nonresidential occupancy that is protected by an automatic fire detection system, with detection in the nonresidential occupancy and occupant notification throughout the building in accordance with Section 9.6.

(Add) **31.1.4.2.3 Dormitory.** See Section 3.3.66.

(Amd) **31.2.2.2.2** Door locking arrangements shall comply with Section 31.2.2.2.2.1, Section 31.2.2.2.2.2, Section 31.2.2.2.2.3 or Section 31.2.2.2.2.4.

(Amd) **31.2.2.2.3** Sensor-release of electrical locking systems complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces.

(Amd) **31.2.4.4** Any dwelling unit shall be permitted to have access to a single exit, provided that one of the following conditions is met:

- (1) The dwelling unit has an exit door opening directly to the street or yard at ground level.
- (2) The dwelling unit has direct access to an outside stair complying with Section 7.2.2.
- (3) The dwelling unit has direct access to an interior stair that serves only that unit and is separated from all other portions of the building by fire barriers having not less than a 1-hour fire resistance rating with no opening therein.

(Amd) **31.2.4.5** Any building of four stories or less protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 31.3.5 may have a single exit, provided the following conditions are met:

- (1) The stairway is separated from the rest of the building by barriers having not less than a 1-hour fire resistance rating in accordance with Section 8.3.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a ½-hour fire resistance rating.
- (4) There is not more than 50 feet (15 m) of travel distance from the entrance door of any dwelling unit to an exit.
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between dwelling units.

(Amd) **31.2.4.6** Any building of three stories or less in its entirety may have a single exit, provided the following conditions are met:

- (1) The stairway is separated from the rest of the building by barriers having not less than a 1-hour fire resistance rating in accordance with Section 8.3.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a ½ hour fire resistance rating.
- (4) The travel distance from the entrance door of any dwelling to an exit does not exceed 50 feet (15 m).
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between dwelling units.

(Amd) **31.2.5.3** Dead-end corridors shall not exceed 50 feet (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Add) **31.2.11.1.1** The provisions of Section 31.2.11.1 shall not apply to existing dormitories.

(Add) **31.3.2.1.1.1** Residential-type heating appliances such as domestic hot water heaters, domestic furnaces or domestic boilers may be unenclosed when located within an individual living unit and serving that living unit only.

(Amd) **Table 31.3.2.1.1 Hazardous Area Protection**

Hazardous Area Description	Separation/Protection*
Boiler and fuel-fired heater rooms where any piece of equipment is greater than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers
Gift or retail shops, >100 ft ² (>9.3 m ²)	1 hour or sprinklers [†]
Bulk laundries	1 hour or sprinklers
Laundries >100 ft ² (>9.3 m ²) outside of dwelling units	1 hour or sprinklers [†]
Maintenance shops	1 hour or sprinklers
Rooms or spaces used for storage of	1 hour or sprinklers

combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction[†]

Trash collection rooms

1 hour or sprinklers

* Minimum fire resistance rating

† Where automatic sprinkler protection is provided, the separation specified in 8.7.1.2 and 31.3.2.1.2 is not required.

(Add) **31.3.4.1.3** A fire alarm system is not required in buildings that do not have interior corridors serving dwelling units and are protected by an approved automatic fire sprinkler system installed in accordance with Section 9.7, provided dwelling units either have a means of egress door opening directly to an exterior exit access that leads directly to the exits or are served by exterior ways of exit access in accordance with Section 7.5.3.

(Add) **31.3.4.1.4** In dormitory occupancies, a fire alarm system in accordance with Section 9.6, except as modified by Sections 31.3.4.2. through 31.3.4.5 shall be provided in buildings, other than those where each guest room has exterior exit access in accordance with 7.5.3 and the building is three or fewer stories in height.

(Add) **31.3.4.2.6** In dormitory occupancies, the required fire alarm system shall be initiated by each of the following:

- 1) Manual means in accordance with 9.6.2, unless there are other effective means to activate the fire alarm system, such as complete automatic sprinkler or automatic detection systems, with manual fire alarm box in accordance with 31.3.4.2.5 (2) required.
- 2) Manual fire alarm box located at a central desk or other convenient central control point under continuous supervision by responsible employees.
- 3) Required automatic sprinkler system.
- 4) Required automatic detection system other than sleeping room smoke alarms.

(Del) **31.3.4.3.5** Delete section.

(Amd) **31.3.4.5.1** Approved single-station smoke alarms shall be installed in accordance with Section 9.6.2.10 outside every sleeping area, in the immediate vicinity of the bedrooms, and on all levels of the dwelling unit, including basements. Additionally, in dormitory occupancies, single or multiple station smoke alarms shall be provided in every guest room and in the living area and sleeping room within a guest suite.

(Del) **31.3.4.5.2** Delete section.

(Del) **31.3.4.5.3** Delete section.

(Del) **31.3.4.5.4** Delete section.

(Amd) **31.3.5.1** Automatic sprinkler protection shall be provided as required by Section 9.7.1.6.

(Amd) **31.3.5.6.2** An automatic sprinkler shall be installed within every dwelling unit that has a door opening to the corridor, with such sprinkler positioned over the center of the door.

(Amd) **31.3.6.3.2** Spaces may be unlimited in area and open to the corridor, provided all of the following criteria are met:

- (1) The spaces are not used for dwelling units or hazardous areas.
- (2) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 31.3.5.2.
- (3) The space does not obstruct access to required exits.

(Del) **31.7.4 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 3 2 NEW RESIDENTIAL BOARD AND CARE OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 3 3 EXISTING RESIDENTIAL BOARD AND CARE OCCUPANCIES

(Add) **33.1.1.1.1** It shall be recognized that, in buildings housing certain types of residents or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the State Fire Marshal shall make appropriate modifications to those sections of this code that would otherwise require means of egress to be kept unlocked.

(Amd) **33.1.1.4* Alternative Compliance.** Any facility meeting the requirements of Part III shall not be required to meet those of Chapter 33.

(Del) **33.1.1.6 Conversion.** Delete section.

(Amd) **33.1.8 Changes in Group Evacuation Capability.** A change in evacuation capability to a slower level shall be permitted where the facility conforms to one of the following:

- (1) The requirements of Part III of this code.
- (2) The requirements of Chapter 33 applicable to existing board and care facilities for the new evacuation capability, provided the building is protected throughout by an approved, supervised automatic sprinkler system complying with Section 33.3.3.5.
- (3) The requirements of Chapter 33 applicable to existing board and care facilities for the new evacuation capability, provided the building is protected throughout by an existing approved, supervised automatic sprinkler system complying with Section 33.2.3.5.3.2.

(Amd) **33.2.2.5.5.1** Delayed egress locks complying with Section 7.2.1.6.1 shall be permitted. A building occupant shall not be required to pass through more than one door equipped with a

delayed egress lock before entering an exit.

(Amd) **33.2.2.5.5.2** Sensor-released of electrical locking systems complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces.

(Amd) **33.2.2.5.5.3** Door-locking arrangements may be permitted by Section 33.1.1.1.1 where the clinical needs of residents require specialized security measures or where residents pose a security threat, provided all of the following conditions are met:

- (1) Staff can readily unlock doors at all times in accordance with 33.2.2.5.5.4.
- (2) The building is protected by an approved automatic sprinkler system in accordance with 33.2.3.5.

(Amd) **33.2.3.4.4.1** Approved smoke alarms shall be provided in accordance with Section 9.6.2.10.

(Del) **33.2.3.4.4.5** Delete section.

(Del) **33.2.3.4.4.6** Delete section.

(Del) **33.2.3.4.4.7** Delete section.

(Amd) **33.3.2.2.2 Doors.** Doors in means of egress shall be as follows:

- (1) Doors complying with 7.2.1 shall be permitted.
- (2) Doors within individual rooms and suites of rooms shall be permitted to be swinging or sliding.
- (3) No door in any means of egress, other than those meeting the requirement of 33.3.2.2.2(4), 33.3.2.2.2(5), or 33.3.2.2.2(6), shall be locked against egress when the building is occupied.
- (4) Delayed-egress locks in accordance with 7.2.1.6.1 shall be permitted.
- (5) Sensor-release of electrical locking systems in accordance with 7.2.1.6.2 shall be permitted.
- (6) Door-locking arrangements may be permitted in accordance with 33.1.1.1.1 where the clinical needs of residents require specialized security measures or where residents pose a security threat, provided both of the following conditions are met:
 - (a) Staff can readily unlock doors at all times in accordance with 33.3.2.2.2(7).
 - (b) The building is protected by an approved automatic sprinkler system in accordance with 33.3.3.5.
- (7) Doors located in the means of egress that are permitted to be locked under other provisions of Chapter 33, other than those meeting the requirement of 33.3.2.2.2(4) or 33.3.2.2.2(5), shall have adequate provisions made for the rapid removal of occupants by means such as remote control of locks, keying of all locks to keys carried by staff at all times, or other such reliable means available to staff at all times.
- (8) Only one such locking device, as described in 33.3.2.2.2(7), shall be permitted on each door.

(9) Revolving doors complying with 7.2.1.10 shall be permitted.

(Add) **33.3.2.2.1** Where permitted by Section 33.3.2.2.2, sensor-release of electrical locking systems egress doors complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces.

(Amd) **33.3.2.5.4** Dead-end corridors shall not exceed 50 feet (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **33.3.3.2.2** Hazardous areas, which shall include, but shall not be limited to, the following, shall be separated from other parts of the building by construction having a fire resistance rating of not less than 1 hour, with communicating openings protected by approved self-closing fire doors, or such area shall be equipped with automatic fire extinguishing systems:

- (1) Boiler and heater rooms where any piece of equipment is more than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower.
- (2) Laundries.
- (3) Repair shops.
- (4) Rooms or spaces used for storage of combustibile supplies and equipment in quantities deemed hazardous by the authority having jurisdiction.

(Amd) **33.3.3.4.7 Smoke Alarms.** Smoke alarms shall be provided in accordance with Section 33.3.3.4.7.1.

(Del) **33.3.3.4.7.2** Delete section.

(Del) **33.3.3.4.7.3** Delete section.

(Add) **33.3.3.5.3.1** Automatic sprinkler protection installed in accordance with Section 33.3.3.5 shall also be provided as required by Section 9.7.1.6.

(Del) **33.3.3.5.7** Delete section.

(DEL) CHAPTER 36 NEW MERCANTILE OCCUPANCIES

(Del) Delete chapter in its entirety.

CHAPTER 37 EXISTING MERCANTILE OCCUPANCIES

(Del) **37.1.1.5** Delete section in its entirety.

(Amd) **37.1.1.6** When a change in mercantile occupancy sub-classification occurs, either of the following requirements shall be met:

(1) When a mercantile occupancy changes from Class A to Class B or Class C, or from Class B to Class C, the provisions of this chapter shall apply.

(2) When a mercantile occupancy changes from Class C to Class A or Class B, or from Class B to Class A, the provisions of Part III of this code shall apply.

(Del) **37.1.1.7** Delete section.

(Amd) **37.1.3.2.1** The fire barrier separating parking structures from a building classified as a mercantile occupancy shall have a fire resistance rating of not less than 2 hours, or 1 hour when both structures are protected throughout by an automatic sprinkler system in accordance with Section 9.7.1.1(1).

(Amd) **37.2.2.2.6** Sensor-release of electrical locking systems complying with Section 7.2.1.6.2 shall be permitted in the means of egress on the entrance doors to buildings and to tenant spaces. The entrance doors shall not be secured from the egress side when the occupancy is open to the general public.

(Amd) **37.2.4 Number of Exits.**

(Amd) **37.2.4.1** Exits shall comply with the following except as otherwise permitted by Section 37.2.4.2 to Section 37.2.4.6, inclusive:

(1) The number of exits shall be in accordance with Section 7.4.

(2) Not less than two separate exits shall be provided on every story.

(3) Not less than two separate exits shall be accessible from every part of every story.

(Add) **37.2.4.6** A single exit shall be permitted for a maximum two-story single tenant space/building that has a maximum area per floor of 1,500 ft² (139 m²) and is protected throughout by an automatic fire detection system that includes smoke detection in all occupied spaces and heat detection in hazardous and unoccupied areas. Each occupied room on the second floor of the space/building shall be provided with a secondary means of escape in accordance with Section 24.2.2.3. The total travel distance to the outside shall not exceed 75 feet (23 m).

(Amd) **37.2.5.3*** Dead-end corridors shall not exceed 50 ft (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **37.2.6.2** In buildings not complying with Section 37.2.6.1, the travel distance shall not exceed 200 feet (61 m).

(Amd) **37.3.2.1.1** Hazardous areas shall be protected in accordance with Section 8.7. Furnace or boiler rooms shall be considered hazardous where any piece of equipment is greater than 400,000 BTU per hour input or any boiler is greater than 15 psi and 10 horsepower.

(Amd) **37.3.5.2** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Del) **37.3.5.3** Delete section.

(Amd) **37.3.6 Corridors.**

(Add) **37.3.6.1** Where access to exits is limited to corridors, such corridors shall be separated from use areas by fire barriers having a fire resistance rating of not less than 1 hour in accordance with Section 8.3, except under any of the following conditions:

- (1) Where exits are available from an open floor area.
- (2) Within a space occupied by a single tenant.
- (3) When the building is protected throughout by an approved supervised automatic sprinkler system installed in accordance with Section 9.7.1.
- (4) Building construction for which a permit was issued prior to April 15, 1987.

(Add) **37.3.6.2** Openings in corridor partitions required to have a fire resistance rating shall be protected in accordance with Section 8.3.

(Del) **37.4.4.7.3.2** Delete section.

(Del) **37.4.4.12.1** Delete section.

(Del) **37.4.4.12.2** Delete section.

(Amd) **37.4.5.3 Storage, Arrangement, Protection, and Quantities of Hazardous Commodities.** The storage, arrangement, protection, and quantities of hazardous commodities shall be in accordance with the applicable provisions of the following:

- (1) The Connecticut State Fire Prevention Code as adopted pursuant to section 29-291c of the Connecticut General Statutes.
- (2) NFPA 13
- (3) NFPA 30
- (4) NFPA 30B
- (5) NFPA 400, Chapter 14 for organic peroxide formulations
- (6) NFPA 400, Chapter 15 for oxidizer solids and liquids
- (7) NFPA 400, various chapters, depending on characteristics of a particular pesticide

(Add) **37.4.5.3.1 Retail Sales of Sparklers and Fountains, 1.4G.** Mercantile occupancies in which the retail sale of sparklers and fountains, 1.4G, is conducted shall comply with the Connecticut State Fire Prevention Code and NFPA 1124 2006 edition, Code for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles, as amended, and section 29-357 of the Connecticut General Statutes.

The provisions of NFPA 1124, 2006 edition, are amended for use in Connecticut as follows:

(Amd) **NFPA 1124, 7.3.7 Storage Rooms.** Storage rooms containing consumer fireworks, sparklers, or fountains regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, or separated from the retail sales area by a fire barrier having a fire resistance rating of not less than 1 hour. The quantity of fireworks permitted in storage shall not exceed 3,600 cubic ft (102 m³) including packaging. Such storage shall be segregated into areas of 1,200 cubic ft (34 m³) or less, separated by a minimum of 4 ft. (1.3 m) of clear space.

(Amd) **NFPA 1124, 7.5.3 Storage Rooms.** Storage rooms containing consumer fireworks, sparklers or fountains regardless of size, in a new or existing permanent store shall be protected with an automatic sprinkler system installed in accordance with NFPA 13, or separated from the retail sales area by a *fire barrier* having a *fire-resistance* rating of not less than 1 hour. The quantity of *fireworks* permitted in storage shall not exceed 3,600 cubic ft (102 m³), including packaging. Such storage shall be segregated into areas of 1,200 cubic ft (34 m³) or less, separated by a minimum of 4 ft (1.3 m) of clear space.

(Amd) **37.4.5.5 Extinguishing Requirements.** Bulk merchandising retail buildings shall be protected throughout by an approved supervised automatic sprinkler system in accordance with 9.7.1.1(1) and the applicable provisions of the following:

- (1) The Connecticut State Fire Prevention Code as adopted pursuant to section 29-291c of the Connecticut General Statutes.
- (2) NFPA 13
- (3) NFPA 30
- (4) NFPA 30B

(Amd) **37.7.3 Extinguisher Training.** Employees of mercantile occupancies shall be periodically instructed in the use of portable fire extinguishers where they are provided.

(Del) **37.7.8 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

(D E L) C H A P T E R 3 8 NEW BUSINESS OCCUPANCIES

(Del) Delete chapter in its entirety.

C H A P T E R 3 9 EXISTING BUSINESS OCCUPANCIES

(Amd) **39.1.1.1** The requirements of this chapter shall apply to buildings or portions thereof currently occupied as a business occupancy. A business occupancy shall also include a training and skill development not in a school or academic program.

(Del) **39.1.1.6** Delete section.

(Add) **39.1.2.1 In-home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit, that provide professional services and employ a

maximum of one employee within the dwelling in addition to the residents of the dwelling unit, shall be classified as a single-family residential occupancy.

(Add) **39.1.2.2 Group B Medical and Dental Occupancies.** Shall apply to Group B medical and dental occupancies that provide services or treatment for four or more patients who may simultaneously be rendered incapable of taking action for self-preservation under emergency conditions. The occupancy shall include, but not be limited to, the following:

- Outpatient clinics with general anesthesia or life-support equipment;
- Dental centers providing treatment under general anesthesia;
- One-day surgical centers;
- Physician's offices providing treatment under general anesthesia.

Facilities such as those listed above that do not provide general anesthesia or life-support equipment simultaneously to four or more patients shall be classified as Group B Business occupancy.

(Add) **39.1.2.3 Group B College Occupancies.** A building, structure, or portion thereof that is of a Group B Business occupancy classification and associated with a facility of higher education above the twelfth grade. This definition does not include training or skill development facilities.

(Amd) **39.1.3.2.1** The fire barrier separating parking structures from a building classified as a business occupancy shall be a fire barrier having a fire resistance rating of not less than 2 hours, or 1 hour when both structures are protected throughout by an automatic sprinkler system in accordance with Section 9.7.1.1(1).

(Amd) **39.2.4.1** Exits shall comply with the following, except as otherwise permitted by Section 39.2.4.2 to Section 39.2.4.7, inclusive:

- (1) The number of exits shall be in accordance with Section 7.4.1.1 and Section 7.4.1.3 though Section 7.4.1.6, inclusive.
- (2) Not less than two separate exits shall be provided on every story.
- (3) Not less than two separate exits shall be accessible from every part of every story.

(Amd) **39.2.4.3** A single exit shall be permitted for a room or area with a total occupant load of less than 100 persons, provided that the following criteria are met:

- (1) The exit shall discharge directly to the outside at the level of exit discharge for the building.
- (2) The total distance of travel from any point, including travel within the exit, shall not exceed 100 feet (30 m).
- (3) Such travel shall be on the same floor level or, if traversing of stairs is necessary, such stairs shall not exceed 15 feet (4.57 m) in height, and the stairs shall be provided with complete enclosures to separate them from any other part of the building, with no door openings therein. A communicating door shall be permitted in the exit stair enclosure at the level of exit discharge if the floor level of the communicating opening is protected throughout by either an automatic sprinkler system or fire detection system consisting of smoke detection that provides an alarm on the floor level served by the single exit.

(4) A single outside stair in accordance with Section 7.2.2 may serve all floors within the 15 feet (4.57 m) vertical travel limitation.

(Amd) **39.2.4.4** Any business occupancy three or fewer stories in height, and not exceeding an occupant load of 30 people per stories, shall be permitted a single separate exit to each story, provided the following criteria are met:

- (1) This arrangement shall be permitted only where the total travel distance to the outside of the building does not exceed 100 ft (30 m) and where the exit is enclosed in accordance with Section 7.1.3.2, serves no other levels, and discharges directly to the outside. A communicating door shall be permitted in the exit stair enclosure at the level of exit discharge if the floor level of the communicating opening is protected throughout by either an automatic sprinkler system or fire detection system consisting of smoke detection that provides an alarm on the floor level served by the single exit.
- (2) A single outside stair in accordance with Section 7.2.2 may serve all floors.
- (3) The exit shall discharge directly to the outside.

(Amd) **39.2.4.6** A single exit shall be permitted for a maximum two-story single tenant space/building that is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.1.1(1) and where the total travel distance to the outside does not exceed 100 feet (30 m).

(Add) **39.2.4.8** A single exit shall be permitted for a maximum two-story single tenant space/building that has a maximum area per floor of 1,500 ft² (139 m²) and is protected throughout by an automatic fire detection system that includes smoke detection in all occupied spaces and heat detection in hazardous and unoccupied areas. Each occupied room on the second floor of the space/building shall be provided with a secondary means of escape in accordance with Section 24.2.2.3. The total travel distance to the outside shall not exceed 75 feet (23 m).

(Amd) **39.2.5.3*** Dead-end corridors shall not exceed 50 feet (15 m), except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor.

(Amd) **39.3.2.1*** Hazardous areas, including, but not limited to, areas used for general storage, boiler or furnace rooms where any piece of equipment is greater than 400,000 BTU per hour input or any boiler greater than 15 psi and 10 horsepower, and maintenance shops that include woodworking and painting areas shall be protected in accordance with Section 8.7.

(Del) **39.3.4.4 Emergency Forces Notification.** Delete section.

(Amd) **39.3.5 Extinguishment Requirements.** Automatic sprinkler protection shall be provided as required by Section 9.7.1.6.

(Amd) **39.3.6. Corridors.** Where access to exits is limited to corridors, such corridors shall be separated from use areas by fire barriers having a fire resistance rating of not less than 1 hour in accordance with Section 8.3, except under any of the following conditions:

- (1) Where exits are available from an open floor area.

- (2) Within a space occupied by a single tenant.
- (3) When the building is protected throughout by an approved supervised automatic sprinkler system installed in accordance with Section 9.7.1.
- (4) Building construction for which a building permit was issued prior to September 1, 1981.

(Amd) **39.4.2.1** All high-rise business occupancy buildings shall be provided with a reasonable degree of safety from fire, and such degree of safety shall be accomplished by one of the following means:

- (1) Installation of a complete, approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (2) Installation of an engineered life safety system complying with all of the following:
 - (a) The engineered life safety system shall be developed by a registered professional engineer experienced in fire and life safety systems design.
 - (b) The life safety system shall be approved by the authority having jurisdiction and shall be permitted to include any or all of the following systems:
 - i. Partial automatic sprinkler protection
 - ii. Smoke detection alarms
 - iii. Smoke control
 - iv. Elevators
 - v. Compartmentation
 - vi. Other approved systems

(Amd) **39.7.3 Portable Fire Extinguisher Training.** Where portable fire extinguishers are provided, designated employees of business occupancies shall be trained periodically to the known location and proper use of portable fire extinguishers.

(Del) **39.7.8 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

CHAPTER 40 INDUSTRIAL OCCUPANCIES

(Amd) **40.1.1.1** The requirements of this chapter shall apply to industrial occupancies.

(Del) **40.1.1.6** Delete section.

(Amd) **40.1.2.1.3* High-Hazard Industrial Occupancy.** High-hazard industrial occupancies shall include all of the following:

- (1) Industrial occupancies that conduct industrial operations that use high-hazard contents as defined in 6.2.2.4 or processes or house high-hazard contents in excess of the

maximum allowable quantities (MAQ) as permitted by the Connecticut State Fire Prevention Code.

(2) Industrial occupancies in which incidental high-hazard operations in low- or ordinary-hazard occupancies that are protected in accordance with Sections 8.7 and 40.3.2 are not required to be the basis for overall occupancy classification.

(Del) **40.1.2.2** Delete section.

(Del) **40.2.1.3** Delete section.

(Amd) **40.2.4.1** The number of means of egress shall comply with Section 40.2.4.1.1, Section 40.2.4.1.2 or Section 40.2.4.1.3.

(Amd) **40.2.4.1.2** A single means of egress shall be permitted from any story or section in low and ordinary hazard industrial occupancies, provided the following limits are not exceeded:

(1) One story, 30 occupants and 100 feet (30 m) maximum travel distance.

(2) Two story, 30 occupants and 75 feet (23 m) maximum travel distance.

(Add) **40.2.4.1.3** In low and ordinary hazard industrial occupancies existing prior to May 7, 2000, a single means of egress shall be permitted from any story or section, provided the exit can be reached within the distance permitted as a common path of travel.

(Del) **40.2.4.2** Delete section.

(Amd) **40.2.5.1 General.** Means of egress, arranged in accordance with Section 7.5, shall not exceed that provided by Table 40.2.5.1, except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor; unless otherwise permitted by the Connecticut State Fire Prevention Code.

(Amd) **40.2.6.1** Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 40.2.6.1 except as otherwise permitted by 40.2.6.2 or the Connecticut State Fire Prevention Code.

(Amd) **40.3.5 Extinguishing Requirements.**

(Add) **40.3.5.1** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Del) **40.4.2.2** Delete section.

(Del) **40.4.2.3** Delete section.

(Del) **40.7.4 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

CHAPTER 42

STORAGE OCCUPANCIES

(Amd) **42.1.1.1** The requirements of this chapter shall apply to storage occupancies.

(Del) **42.1.1.4** Delete section.

(Amd) **42.1.5.2** Hazardous materials that exceed the maximum allowable quantities (MAQ) as permitted in the Connecticut State Fire Prevention Code shall be classified as high-hazard contents.

(Del) **42.2.1.3** Delete section.

(Amd) **42.2.4.1** The number of means of egress shall comply with any of the following:

- (1) In low and ordinary hazard storage occupancies, a single means of egress shall be permitted from any story or section provided the following limits are not exceeded:
 - (a) One story, 30 occupants and 100 feet (30 m) maximum travel distance; or
 - (b) Two story, 30 occupants and 75 feet (23 m) maximum travel distance.
- (2) In low hazard storage occupancies existing prior to May 7, 2000, a single means of egress shall be permitted from any story or section.
- (3) In ordinary hazard storage occupancies existing prior to May 7, 2000, a single means of egress shall be permitted from any story or section, provided the exit can be reached within the distance permitted as a common path of travel.
- (4) All buildings or structures not complying with Section 42.2.4.1(1), Section 42.2.4.1(2) or Section 42.2.4.1(3) and used for storage, and every section thereof considered separately, shall have not less than two separate means of egress as remotely located from each other as practicable.

(Amd) **42.2.5 Arrangement of Means of Egress.** Means of egress, arranged in accordance with Section 7.5, shall not exceed that provided by Table 42.2.5, except that a dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the narrowest width of the dead-end corridor; unless otherwise permitted by the Connecticut State Fire Prevention Code.

(Amd) **42.2.6** Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 40.2.6, unless otherwise permitted by the Connecticut State Fire Prevention Code.

(Amd) **Table 42.2.6 Maximum Travel Distance to Exits.**

Level of Protection	Low Hazard Storage Occupancy	Ordinary Hazard Storage Occupancy	High Hazard Storage Occupancy
Protected throughout by an approved, supervised automatic sprinkler system	400ft (122m)	400ft (122m)	100ft (30m)

in accordance with Section 9.7.1.1(1)			
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.1.1(1)	300ft (91m)	200ft (61m)	75ft (23m)
Flammable and combustibile liquid products stored and protected in accordance with NFPA 30.	Not applicable	Not applicable	150 feet (46 m)

(Amd) **42.3.5 Extinguishing Requirements.**

(Add) **42.3.5.1** Automatic sprinkler protection shall also be provided as required by Section 9.7.1.6.

(Amd) **42.8.3.5 Extinguishing Requirements.**

(Add) **42.8.3.5.1** An open-air parking structure or open-air facility located within a mixed occupancy building shall be protected throughout by an approved, automatic sprinkler system when the other occupancy of such building requires such protection throughout the building, unless the provisions of Section 42.8.3.5.2 are met.

(Add) **42.8.3.5.2** Those portions of a building deemed “open-air parking” shall not be required to be protected by automatic sprinklers if all of the following conditions are met:

- (1) Used only for the parking or storage of passenger motor vehicles designed to carry not more than nine persons.
- (2) There are no provisions for vehicle repair or fuel dispensing.
- (3) The open parking structure and other occupancy shall be separated, both horizontally and vertically, by fire resistive separation assemblies having at least a 2-hour fire resistance rating and may have openings as permitted by the exceptions to Section 37.1.3.2 and Section 39.1.3.2.
- (4) Means of egress for the other occupancy shall be separated from the parking area by fire barriers having at least a 2-hour fire resistance rating.

(Del) **42.8.4** Delete section.

(Del) **42.9.4 Integrated Fire Protection and Life Safety Systems.** Delete section in its entirety.

**(D E L) C H A P T E R 4 3
B U I L D I N G R E H A B I L I T A T I O N**

(Del) Delete chapter in its entirety.

END OF DOCUMENT