Capacity Factors and Usage Factors at Electric Generators: Electric Power Table 7.8b Sector (Percent)

|  | Capacity Factors <sup>a</sup>   |  |   |   |   |  |  |   |  |  |  |   | Usage Factors <sup>b</sup>   |   |
|--|---|--|---|---|---|--|--|---|--|--|--|---|--|---|
|  | Coal <sup>c,d</sup>   | Petro-<br>leum <sup>c,e</sup>  | Natural Gas <sup>f</sup>  |   |   | Conven-<br>tional  |  |   | Solar  |  | _  | Hvdro-  |  |   |
|  |   |  | Combi-<br>ned<br>Cycle  | Gas<br>Turbine  | Steam<br>Turbine  | Nuclear<br>Electric<br>Power <sup>g</sup>  | Hydro-<br>electric<br>Power  | Bio-<br>mass <sup>c,h</sup>   | Geo-<br>thermal  | Photo-<br>voltaic <sup>i</sup>   | Thermal  | Wind <sup>j</sup>   | electric<br>Pumped<br>Storage  | Battery<br>Storage  |
| 2008 Year<br>2009 Year<br>2010 Year<br>2011 Year<br>2012 Year<br>2013 Year<br>2014 Year<br>2015 Year<br>2016 Year<br>2017 Year<br>2018 Year<br>2019 Year<br>2019 Year<br>2020 Year | 72.6<br>64.4<br>67.3<br>62.9<br>56.4<br>59.5<br>60.7<br>54.3<br>52.9<br>53.2<br>47.5<br>40.5<br>49.2        | 9.4<br>9.1<br>7.1<br>7.1<br>6.3<br>6.4<br>6.3<br>5.6<br>6.4<br>5.0<br>5.4        | 39.5<br>43.5<br>43.6<br>51.7<br>48.0<br>48.0<br>55.5<br>54.9<br>50.6<br>54.6<br>57.0<br>56.8<br>54.8        | 5.2<br>4.4<br>5.1<br>6.0<br>5.0<br>5.8<br>6.6<br>9.3<br>8.3<br>8.3                                    | 11.6<br>10.4<br>10.6<br>11.2<br>12.7<br>10.4<br>9.5<br>10.8<br>11.6<br>10.1<br>11.9<br>13.2<br>13.3<br>11.4 | 91.1<br>90.3<br>91.1<br>89.1<br>86.6<br>90.8<br>91.7<br>92.3<br>92.3<br>92.3<br>92.5<br>93.4<br>92.4<br>92.8 | 37.0<br>39.5<br>37.5<br>45.7<br>39.5<br>38.6<br>37.1<br>35.6<br>38.1<br>43.0<br>41.8<br>41.1<br>40.7<br>35.9 | 65.5<br>64.6<br>63.4<br>62.5<br>63.4<br>60.0<br>61.5<br>59.5<br>59.2<br>60.2<br>59.5<br>58.9<br>61.8        | 74.3<br>73.0<br>71.6<br>71.5<br>68.3<br>71.8<br>72.0<br>71.9<br>71.6<br>73.2<br>76.0<br>68.9<br>68.4<br>69.5 | 19.7<br>20.3<br>19.0<br>20.4<br>24.7<br>25.8<br>25.7<br>25.7<br>25.7<br>25.2<br>24.4<br>24.3         | 19.5<br>23.6<br>24.5<br>23.9<br>23.6<br>17.4<br>18.3<br>21.7<br>22.1<br>21.8<br>23.6<br>21.2<br>20.6<br>20.5 | 31.7<br>29.8<br>32.1<br>32.4<br>32.4<br>34.0<br>32.2<br>34.5<br>34.6<br>34.6<br>34.4<br>35.3<br>34.4        | 9.8<br>10.2<br>10.2<br>11.2<br>11.4<br>10.8<br>10.4<br>10.5                            | -<br>-<br>-<br>1.7<br>3.6<br>3.8<br>6.9<br>5.3<br>5.5<br>5.2<br>6.2       |
| 2022 January   | 57.5<br>52.3<br>41.0<br>38.5<br>42.1<br>52.6<br>59.7<br>59.3<br>47.4<br>38.7<br>40.9<br>51.5<br><b>48.5</b> | 7.2<br>5.4<br>3.7<br>4.6<br>5.0<br>4.6<br>5.2<br>4.9<br>7.6<br><b>5.2</b>        | 55.2<br>52.0<br>46.1<br>43.7<br>49.3<br>61.1<br>70.7<br>72.5<br>64.0<br>52.6<br>51.5<br>56.5<br><b>56.3</b> | 7.9<br>6.2<br>5.0<br>6.6<br>9.4<br>13.7<br>16.8<br>15.1<br>10.5<br>7.2<br>8.1<br>9.4                  | 13.7<br>10.8<br>7.4<br>8.5<br>13.7<br>19.5<br>27.6<br>21.7<br>15.5<br>12.4<br>12.7<br>13.2<br><b>14.7</b>   | 99.4<br>96.5<br>89.0<br>80.5<br>89.3<br>96.4<br>97.8<br>93.5<br>83.7<br>91.0<br>98.1<br><b>92.7</b>          | 40.6<br>39.6<br>40.9<br>34.7<br>39.2<br>45.1<br>41.3<br>35.5<br>29.5<br>24.1<br>31.0<br>34.2<br><b>36.3</b>  | 58.9<br>61.1<br>56.9<br>53.3<br>54.5<br>60.3<br>62.6<br>61.6<br>58.3<br>53.5<br>56.1<br>59.3<br><b>58.0</b> | 75.1<br>70.3<br>65.7<br>67.1<br>67.4<br>67.0<br>67.1<br>67.9<br>68.6<br>65.3<br>72.6<br>74.1<br><b>69.0</b>  | 16.8<br>21.2<br>24.5<br>28.6<br>31.0<br>33.3<br>31.3<br>28.5<br>26.6<br>22.9<br>16.6<br>12.6         | 11.3<br>15.9<br>23.1<br>30.1<br>33.5<br>34.9<br>26.2<br>25.3<br>26.7<br>26.4<br>14.1<br>9.0<br>23.1          | 37.6<br>41.6<br>42.7<br>46.6<br>41.1<br>33.9<br>28.7<br>24.0<br>27.4<br>31.6<br>40.8<br>36.8<br><b>36.0</b> | 9.5<br>8.9<br>9.1<br>7.3<br>10.9<br>14.8<br>15.9<br>16.4<br>13.2<br>8.4<br>9.6<br>11.1 | 5.6 8 1 4 7 6.6 6.1 8 7 6.6 6.5 <b>6.5 6.5</b>                            |
| 2023 January February March April May June July August September October November December Average   | 44.3<br>37.1<br>35.9<br>30.3<br>32.4<br>44.2<br>58.2<br>57.9<br>46.1<br>38.4<br>39.4<br>41.7<br><b>42.2</b> | 3.6<br>4.0<br>3.6<br>3.9<br>3.7<br>4.9<br>6.8<br>6.7<br>4.4<br>3.2<br><b>4.5</b> | 56.6<br>56.3<br>52.6<br>47.3<br>52.1<br>62.6<br>72.7<br>72.9<br>64.8<br>52.3<br>53.6<br>58.8<br><b>58.6</b> | 5.9<br>5.4<br>7.0<br>9.5<br>10.8<br>13.9<br>20.4<br>19.6<br>12.0<br>11.3<br>8.9<br>6.3<br><b>10.9</b> | 8.7<br>8.8<br>10.4<br>12.4<br>14.6<br>20.2<br>30.0<br>29.0<br>20.6<br>15.5<br>13.1<br>9.4<br>16.1           | 100.7<br>95.6<br>89.2<br>83.2<br>87.3<br>99.1<br>97.9<br>95.1<br>86.2<br>90.3<br>96.7<br><b>93.1</b>         | 37.4<br>34.7<br>33.8<br>30.3<br>46.0<br>33.7<br>35.6<br>35.4<br>28.5<br>30.3<br>31.4<br>32.4<br><b>34.1</b>  | 60.1<br>57.9<br>52.9<br>46.1<br>54.5<br>55.3<br>58.1<br>57.9<br>51.7<br>43.8<br>50.8<br>51.0<br><b>53.3</b> | 78.4<br>72.6<br>69.4<br>69.6<br>68.5<br>65.7<br>65.2<br>67.1<br>69.8<br>70.7<br>72.8<br>70.5<br><b>70.0</b>  | 14.6<br>18.4<br>21.6<br>26.7<br>29.3<br>30.9<br>31.2<br>29.1<br>25.8<br>22.2<br>16.6<br>13.7<br>23.3 | 7.7<br>11.0<br>14.0<br>27.9<br>27.5<br>34.6<br>35.0<br>28.4<br>27.7<br>26.2<br>15.7<br>9.9<br><b>22.2</b>    | 37.1<br>43.9<br>41.4<br>41.5<br>29.8<br>26.3<br>25.9<br>26.4<br>27.0<br>33.6<br>35.3<br>35.0<br><b>33.5</b> | 9.2<br>9.6<br>9.2<br>8.8<br>11.0<br>13.8<br>15.6<br>13.3<br>8.7<br>8.3<br>8.1          | 5.6<br>5.9<br>5.7<br>5.2<br>5.5<br>5.7<br>5.6<br>6.1<br>5.7<br><b>5.7</b> |
| 2024 January<br>February<br>March  | 56.5<br>35.8<br>29.2  | 4.4<br>3.2<br>2.9  | 62.5<br>55.8<br>50.0  | 10.6<br>6.9<br>8.1  | 15.4<br>9.8<br>12.4   | 97.1<br>96.9<br>88.9   | 35.7<br>35.1<br>38.5   | 56.3<br>51.3<br>48.1  | 66.5<br>65.9<br>60.2   | 13.7<br>18.7<br>21.7   | 7.3<br>11.7<br>20.4  | 31.6<br>40.1<br>41.4  | 9.5<br>9.7<br>7.4  | 5.3<br>6.4<br>7.0   |

<sup>&</sup>lt;sup>a</sup> Capacity factors are a measure of how often electric generators operate over a specific period of time, using a ratio of actual output (net generation) to the maximum possible output over that same time period (using time-adjusted

other plants.

d Anthracite, bituminous coal, subbituminous coal, lignite, waste coal, and coal

synfuel.

Distillate fuel oil, residual fuel oil, petroleum coke, jet fuel, kerosene, other petroleum, waste oil, and, beginning in 2011, propane.

Natural gas, plus a small amount of supplemental gaseous fuels. Capacity other plants are not displayed.

g See Table 8.1 for nuclear capacity factors for 1957–2007.

sources, and tire-derived fuels).

<sup>1</sup> Solar photovoltaic (PV) energy at utility-scale facilities. Does not include small-scale solar photovoltaic generators.

<sup>1</sup> Onshore wind plants, and, beginning in 2017, offshore wind plants.

=No data reported.

Notes: 

• Data are for utility-scale facilities. See Note 1, "Coverage of Electricity Statistics," at end of section.

• Monthly factors are based on a time-adjusted total net summer capacity of generators in operation for the entire month. Annual factors net summer capacity of generators in operation for the entire month. Annual factors are based on a time-weighted average of the monthly time-adjusted capacity.

For plants that use multiple energy sources or technologies, capacity is assigned to the reported combination of predominant energy source and technology.

See EIA's Electric Power Annual, "Technical notes," for further information.

See "Capacity factor" in Glossary.

The electric power sector comprises electricity-only and combined-heat-and-power (CHP) plants within the NAICS 22 category whose primary business is to sell electricity, or electricity and heat, to the public.

Geographic coverage is the 50 states and the District of Columbia.

Web Page: See http://www.eia.gov/fotalenergy/data/monthly/#electricity (Excel

public. • Geographic coverage is the 50 states and the District of Columbia.

Web Page: See http://www.eia.gov/totalenergy/data/monthly/#electricity (Excel and CSV files) for all available annual and monthly data beginning in 2008.

Sources: U.S. Energy Information Administration (EIA), Form EIA-860, "Annual Electric Generator Report"; Form EIA-860M, "Monthly Update to the Annual Electric Generator Report"; and Form EIA-923, "Power Plant Operations Report.

b Usage factors are a measure of how often electric generators operate over a specific period of time, using a ratio of actual output (gross generation) to the maximum possible output over that same time period (using time-adjusted capacity).

<sup>c</sup> Steam turbine, gas turbine, internal combustion engine, combined-cycle, and

h Wood and wood-derived fuels, municipal solid waste from biogenic sources, landfill gas, sludge waste, agricultural byproducts, and other biomass. Through 2000, also includes non-renewable waste (municipal solid waste from non-biogenic